

June 29, 2014

2017 SANITARY SEWER CIP

**ADDENDUM NO. 1
REQUEST FOR INFORMATION/CLARIFICATION**

TO: ALL HOLDERS OF THE Plans and Specifications for the City of Millbrae's "**2017 Sanitary Sewer CIP**".

FROM: City of Millbrae – Public Works Department

The following information and/or clarification are provided and incorporated into the plans and specifications of the 2017 Sanitary Sewer CIP which is scheduled for bid opening on **July 11, 2017**:

A. TECHNICAL SPECIFICATIONS

1. SECTION 100 – DEFINITION OF BID ITEMS

- Modify section "J – Replacement of Existing Manhole with Precast Concrete Manhole (Bid Item No. 19)" as follows:

Contract unit price paid for "Replace Existing Manhole with Precast Concrete Manhole" shall include full compensation for furnishing all labor, materials, tools, equipment, and all incidentals necessary to remove the existing manhole and replace it with precast concrete manhole including **cast in place concrete manhole base with steel reinforcement**, restoration of lateral connections at the manhole, application of protective lining and removal and restoration of fences and other surrounding improvements to accommodate the work, in accordance with Technical Specifications Section 109, "Sanitary Sewer System" and no additional compensation will be allowed therefore.

Work shall be inclusive of demolition and off-hauling, excavation, backfilling, placement of concrete collar around manhole frame and surface improvement restoration (of whatever nature).

- Modify section "L – Installation of New Concrete Manhole (Bid Item No. 21)" as follows:

Contract unit price paid for "Install New Concrete Manhole" shall include full compensation for furnishing all labor, materials, tools, equipment, and all incidentals necessary to install precast concrete manholes including **cast in place concrete**

manhole base with steel reinforcement, connections of sewer pile laterals and mains at the manhole and application of protective lining, in accordance with Technical Specifications Section 109, "Sanitary Sewer System" and no additional compensation will be allowed therefore.

2. SECTION 109 – SANITARY SEWER SYSTEM

- Modify subsection A of Section 2.05 – "Concrete Manhole" as follows:
 - A. "Sanitary Sewer Manhole base shall be cast in place. The base of the manhole shall be a minimum of 9" thick. **Manhole base shall be constructed with steel reinforcement, No. 4 bars @ 6" O.C. each way.**"

EACH BIDDER SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM NO. 1:

- By completing the attached **ACKNOWLEDGEMENT** sheet marked as “**RETURN IMMEDIATELY TO**” and returning the completed sheet immediately to Public Works through mail or fax, **AND**
- By completing the attached **ACKNOWLEDGEMENT** sheet marked as “**RETURN WITH THE BID PROPOSAL**” and submitting the completed sheet with the bid proposal.
- Acknowledgement of this addendum on page 13 of the Bid Forms is also required.

Prepared By: Son Hoang, CSG Consultants

Approved By: Khee Lim, City Engineer



2017 SANITARY SEWER CIP

**ADDENDUM NO. 1
REQUEST FOR INFORMATION/CLARIFICATION**

ACKNOWLEDGEMENT

I have received Addendum No. 1 to the Contract Plans and Specifications titled, **"2017 SANITARY SEWER CIP"**. I have read and understood the information stated in the Addendum.

Bidder's Signature

Date

Bidder's Name (Printed)

Name of Company

RETURN IMMEDIATELY TO:

Public Works Department
621 Magnolia Avenue
Millbrae, CA 94030
Fax: (650) 259-2398

2017 SANITARY SEWER CIP

**ADDENDUM NO. 1
REQUEST FOR INFORMATION/CLARIFICATION**

ACKNOWLEDGEMENT

I have received Addendum No. 1 to the Contract Plans and Specifications titled, "**2017 SANITARY SEWER CIP**". I have read and understood the information stated in the Addendum.

Bidder's Signature

Date

Bidder's Name (Printed)

Name of Company

RETURN WITH THE BID PROPOSAL

Bidder's Fax No: _____