

August 1, 2017

**HIGHLINE CANAL TRASH CAPTURE HEADWALL PROJECT**

**ADDENDUM NO. 1  
REQUEST FOR INFORMATION/CLARIFICATION**

The prebid conference was held on July 26, 2017 at the project site, located at 185 Aviator Avenue, Millbrae, CA 94030.

The following information and/or clarification are provided and incorporated into the specifications of the Highline Canal Trash Capture Headwall Project which is scheduled for bid opening on August 8, 2017:

**The following specifications sections are being amended by Addendum #1 as described below.**

**SECTION 1  
GENERAL REQUIREMENTS**

**TP 1.01 GENERAL.** Add the following:

“Contractor shall be aware that installation of improvements is within tidal influence from the bay. Contractor shall schedule work and make necessary preparations to work around tidal influence. Newly poured concrete shall be protected from tidal influence until cured. Any damage or delay of work caused by the tidal influence shall be at the sole expense of the Contractor.”

**SECTION 3  
CONCRETE**

**TP 3.02 CONCRETE.** Add the following to 3<sup>rd</sup> paragraph:

“Alternatively, Contractor can propose the use of high early strength concrete. Prior to installation, high early strength concrete mix design shall be submitted to and approved by the Engineer.”

**TP 3.04 PROTECTION OF EXISTING UTILITIES.** Add the following:

“The Contractor shall be aware that there are existing overhead utility lines located adjacent to existing concrete channel on north side and exercise caution.”

**SECTION 4  
TRASH CAPTURE DEVICE**

**TP 4.01 GENERAL.** Add the following:

“Approximate weights of trash capture device segments: 5’ length = 600 lb and 10’ length = 1,100 lb.”

**EACH BIDDER SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM NO. 1:**

- By completing the attached **ACKNOWLEDGEMENT** sheet marked as “**RETURN IMMEDIATELY TO**” and returning the completed sheet immediately to Public Works through mail or fax.

Prepared By: Jane Kao, Senior Civil Engineer



Approved By: Khee Lim, City Engineer



**HIGHLINE CANAL TRASH CAPTURE PROJECT,**

**ADDENDUM NO. 1  
REQUEST FOR INFORMATION/CLARIFICATION**

**ACKNOWLEDGEMENT**

I have received Addendum No. 1 to the Contract Plans and Specifications titled, “**HIGHLINE CANAL TRASH CAPTURE HEADWALL PROJECT**”. I have read and understood the information stated in the Addendum.

\_\_\_\_\_  
Bidder's Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Bidder's Name (Printed)

\_\_\_\_\_  
Name of Company

**RETURN IMMEDIATELY TO:**

Public Works Department  
621 Magnolia Avenue  
Millbrae, CA 94030  
Fax: (650) 697-8158