



WATERSMART GUIDEBOOK



A Water-Use Efficiency Plan Review Guide for New Businesses



2008



Watersmart Guidebook



A Water-Use Efficiency Plan-Review Guide



for New Businesses

East Bay Municipal Utility District
2008

Copyright © 2008, East Bay Municipal Utility District. All rights reserved.

East Bay Municipal Utility District
375 11th Street, Oakland CA 94607
Phone: 510-287-1675
Fax: 510-287-1883
E-mail: rharris@ebmud.com

DISCLAIMER: This guidebook is provided exclusively for general education and informational purposes and as a public service by the East Bay Municipal Utility District (EBMUD). Although we at EBMUD try to ensure all information is accurate and complete, information can change without notice, and EBMUD makes no claims, promises, or guarantees about the accuracy, completeness, or adequacy of this guidebook, and all its information and related materials are provided “as is.” By using this guidebook, you assume the risk that the information and materials in the guidebook may be incomplete, inaccurate, or out-of-date, or may not meet your needs and requirements. Users should not assume the information in this guidebook to be completely error-free or to include all relevant information, or use it as an exclusive basis for decision-making. The user understands and accepts the risk of harm or loss to the user from use of this information. You are authorized to view this guidebook for your use and to copy any part of it. In exchange for this authorization: (i) you agree not to sell or publish the guidebook without first receiving written permission from EBMUD; and (ii) you waive, release, and covenant not to sue EBMUD and all others affiliated with developing this guidebook from any liability, claims, and actions, both known and unknown, for any losses, damage, or equitable relief you may now have a right to assert or later acquire, arising from such use or reliance on the guidebook. Unauthorized use of this guidebook is prohibited and a violation of copyright, trademark, and other laws. Nothing in this guidebook constitutes an endorsement, approval, or recommendation of any kind by any persons or organizations affiliated with developing this guidebook. The suitability and applicability of this information for given use depends on various factors specific to that use. These include, but are not limited to, laws and regulations applicable to the intended use, specific attributes of that use, and the specifications for any product or material associated with this information. All warranties, express or implied, are disclaimed, and the reader is strongly encouraged to consult with a building, product, and/or design professional before applying any of this information to a specific use or purpose. These disclaimers and exclusions shall be governed by and construed in accordance with California law. If any provision of these disclaimers and exclusions shall be unlawful, void, or for any reason unenforceable, then that provision shall be deemed severable and shall not affect the validity and enforceability of the remaining provisions.

Many of the designations used by manufacturers and sellers to distinguish their products are claimed as trademarks. Product names and services identified throughout this work are used in editorial fashion only, with no intention of infringement of the trademark. No such use, or the use of any trade name, is intended to convey endorsement or other affiliation with this publication.

Contents

Acknowledgments	INT1
Introduction	INT3
Water-Provider and Planning-Agency New Construction Plan-Review and Approval Process	INT7

BUSINESS TYPES

Office Buildings	3
Schools	7
Restaurants and Fast-Food Outlets	11
Commercial and Retail Centers	15
Hotels and Motels	17
Grocers	19
Hospitals	23
Laboratories	27
Coin- and Card-Operated Laundries	31
Industrial Laundries and Dry Cleaners	33
Vehicle Washes	37
Beverage Manufacturers	41
Bakery/Pastry Shops	43
Industrial Bakeries	47
Auto Service and Repair Shops	51
Fuel Service Stations and Convenience Stores	53
Commercial Printers	57
Metal Finishers	61
Paper Manufacturers	65
Water Features, Pools, and Landscapes	69

WATER-USING TECHNOLOGIES

Alternate On-Site Water Sources	ALT
Food-Service Operations	FOOD
Landscape Water-Use Efficiency	LAND
Laundries and Dry-Cleaning Operations	LAUND
Medical Facilities and Laboratories	MED
Metering of Individual Units	METER
Photo and Film Processing	PHOTO
Pools, Spas, and Fountains	POOLS
Process Water	PROC
Restrooms and Plumbing	REST
Thermodynamic Processes	THERM
Vehicle Washes	WASH
Water Treatment	TREAT

This page intentionally left blank.

Acknowledgements

This guidebook was made possible with a matching fund grant between the California Department of Water Resources and the East Bay Municipal Utility District (EBMUD) under Proposition 50, Chapter 7, Section B, Contract Number 4600004194.

This guidebook was prepared by the following team members of Chris Brown Consulting: Chris Brown, Bill Hoffman, Charlie Pike, Tony Gregg, and Susan Hughes, with special appreciation to Catherine Putsche and Katherine Zipp. Dick Bennett, EBMUD, served as project manager.

A Project Advisory Committee was formed to review the material and help guide the project. The interest and assistance of the following individuals is deeply appreciated:

- Al Dietemann, Seattle Public Utilities
- Bill Maddaus, Maddaus Water Management
- Cindy Moe, Denver Water
- Nancy Stalker and Michael Meagher, City of Calgary
- Kent Sovocool, Southern Nevada Water Authority
- Ted Jones, Consortium for Energy Efficiency
- Katie Shulte-Joung, California Urban Water Conservation Council
- Stu Feinglas, City of Westminster
- Richard Harris, EBMUD

###

This page intentionally left blank.

Introduction

This guidebook was developed to help businesses be more water efficient. It provides information on water-saving technologies applicable in the commercial, industrial, and institutional sectors and is intended for use as a resource by:

- existing and new businesses,
- developers, consultants, and designers,
- planning agencies, and
- water providers (for plan review and/or for reviewing and estimating water use at existing businesses respectively).

Since technology changes over time, the information in this guidebook is intended to be updated periodically.

It is hoped that water providers will consider adopting a plan-review program for water-use efficiency for new construction to capture all the potential benefits of efficient use. The business community can capture the benefits of reduced costs for water, energy, chemicals, wastewater, and on-site water- and wastewater-treatment facilities. In addition, developer system-capacity charges imposed by water providers (i.e., water-provider connection fees) may be reduced due to either smaller meter sizes or reduced water use resulting from the water-saving technology. Thus, planning for and incorporating water- (and energy-) efficient technology during the design and construction phase of a project can represent a win-win scenario for all stakeholders, including the environment. Lastly, requiring plan reviews for water efficiency and requiring certain water-efficiency standards is expected to be considerably more cost-effective for both water utilities and businesses than retrofitting businesses with water-efficient technology after construction.

13 water-using technologies have been applied to 19 different business types in this guidebook. Many of these technologies can also be applied to other business types not specifically addressed herein. For example, restroom fixtures, heating and cooling systems, and landscape technologies can also apply to many other business types. Some of this information can also be applied to the residential sector. Each business type has a summary fact sheet that includes a discussion of the end uses of water and references on where to find technical data for such information as the estimated life-cycle water savings, costs, and payback (cost-effectiveness) of the technology.

While it is left to each agency to decide what water-saving technologies might be appropriate for their service area under a plan-review or alternative conservation program, this guidebook includes examples of proven practices for superior performance, along with additional practices that achieve significant savings. “Proven practices” are those that have demonstrated water savings and represent a cost-effective technology for the business, for example, high-efficiency toilets, pre-rinse spray valves, and connectionless, i.e., boilerless, food steamers. “Additional Practices” are those technologies that have not been extensively field

tested for water savings and life-cycle cost-effectiveness, but which also may represent appropriate and cost-effective water-saving technologies.

Again, it is left to each water provider or planning agency to decide what technologies might be required as conditions of water service, if and when a plan-review program is implemented.

The guidebook also includes information on landscape water-use efficiency, since outdoor use is an important issue in many areas and may represent a considerable percent of the water use for any given business. Landscape standards can be developed using either a water budget or checklist approach or a combination of these. It remains up to the water provider or planning agency to decide what standards, if any, to adopt and in what form. For example, a water provider may choose to adopt a checklist approach as a requirement in the plan-review process or simply choose to use the checklist as a guideline that is passed on to a developer.

It was also decided to include information on such alternative water sources as recycled water, gray water, and cisterns for completeness. It is left to each water provider to choose whether these sources are practical measures for use in its service area and how to use that information in the plan-review process.

If a plan-review program for new construction is desired, an extremely important issue is that of program implementation. Thus, information is presented in the first chapter on the typical plan-review process of a planning agency. For a plan-review process to work, appropriate resources need to be allocated to the program and communication is needed between the community planning agency and the water provider. It is the responsibility of the water provider to ensure joint participation in the plan-review process.

How to Use This Guide

Business Types

Each of the 19 business-type summaries includes information that briefly discusses how water is typically used and by what types of hardware. There are specifics on water-using hardware and processes found at these businesses, and estimates of potential water savings and, if known, product costs are referred to and found in the coded appendices.

Water-Using Technologies

Following the 19 business-type summaries is a section containing detailed descriptions of the water-saving hardware and processes found in the business sector for 13 different end-use categories or measures, ranging from restrooms to irrigation systems. They also provide information on the water use and savings, costs, and cost-effectiveness of various product types and measures, along with descriptions of water-using processes. In addition, there are resource references for websites and for hardcopy material. Besides the information on water efficiency provided in this guidebook and the references cited in the sections on water-using technologies, information on green business building standards can be found at www.usgbc.org or at www.builditgreen.org.

It is hoped this guide will prove beneficial, and reader feedback is appreciated from those who gain experience with its use. Please provide comments to Dick Bennett via e-mail at dbennett@ebmud.com or write to EBMUD, CII Guidebook, 2130 Adeline St. MS48, Oakland, CA 94607.

Key to Water-Using Technology Section Abbreviations Used in the Business-Type Summaries

In the “Business-Type” summaries there are references to various “Water-Using Technology” sections of the guidebook, where more detailed information can be found. These references appear within the text in bold italics, for example, ***PROC*** for “Process Water,” ***REST*** for “Restrooms and Plumbing,” and ***TREAT*** for “Water Treatment.”

ALT Alternate On-Site Water Sources
FOOD . . . Food-Service Operations
LAND . . . Landscape Water-Use Efficiency
LAUND. . . Laundries and Dry-Cleaning Operations
MED Medical Facilities and Laboratories
METER. . . Metering of Individual Units
PHOTO . . Photo and Film Processing
POOL . . . Pools, Spas, and Fountains
PROC . . . Process Water
REST. . . . Restrooms and Plumbing
THERM. . . Thermodynamic Processes
TREAT . . Water Treatment
WASH . . . Vehicle Washes

NOTE: In order to keep this guidebook up-to-date, and to facilitate adding new materials and new sections as they become available, without reproducing the entire guidebook, the units have been individually numbered, rather than numbering the entire guidebook sequentially.

This page intentionally left blank.

Water-Provider and Planning-Agency New Construction Plan-Review and Approval Process

As part of a design and construction permitting process, a water provider or planning agency may want to adopt water-use efficiency standards that require review and approval of a developer's plans as a condition for water service. The goal of requiring such a review is to improve community water-use efficiency and water-supply reliability and to reduce developer/owner long-term costs for water, sewer, energy, and, if appropriate, on-site wastewater-treatment facilities. A plan-review program for water- (and energy-) use efficiency can thus present a win-win scenario for both the developer and the community.

In most cases, the primary objective of the water-provider application process is to determine conditions for services and fees. Fees, in turn, are usually dependent upon water demand, water-meter size, or projected use and on the water-distribution system facilities (main extensions, storage, pumping, etc.) needed to serve the new project. Thus a plan review for water-use efficiency may reduce a developer's cost if water demand is reduced.

An important part of the planning and permitting process is developer notification of requirements for project approval and ultimate occupancy. Projects are reviewed for provisions that include design standards, environmental impacts, and regulatory requirements. The review process requires communication among the planning agency and the other project stakeholders. The goal is to allow other stakeholders the opportunity to comment on the project and to notify the developer early in the planning and permitting process of a project's permit conditions. Since a developer's first contact in the project approval process is typically with a planning agency, the water utility, as a potential stakeholder, should strive to be included in a planning agency's design review and/or permitting process.

The plan review and permitting process varies somewhat among planning agencies, but the basic process is similar. Some planning agencies typically forward developer plans to the local water provider for review and comment. However, this practice appears to vary among planning agencies, so the water provider needs to verify the plan-review process with each planning agency in its service area. The time from a developer's initial contact with a planning agency to building occupancy varies widely from project to project, but can often take one to three years or more.

Planning-Agency Plan-Review Process (Phase 1)

A plan for a new facility goes through either a Tentative Map Plan (TMP) Review, a Design Review, or both. If the project involves a new subdivision, then a review of the TMP is often the first step in the planning process. If not, the first step is usually a Development or Design Review. At this point, the plans are sent

to other stakeholders for review and comment. These stakeholders may include such agencies as water and wastewater, fire service, air- and water-quality resources, and health departments. The stakeholders provide comments to the planning agency along with their requirements. The planning agency then determines the appropriate level of environmental review, if any. The developer then addresses project requirements and submits a draft Environmental Impact Report (EIR) to the planning agency, which, in turn, forwards it to the various stakeholders for further review. These requirements then become part of the permitting process, which ultimately leads to a certificate of occupancy, if all permitting conditions are met.

Plan Review Process



The Construction/Permitting Process (Phase 2)

The other opportunity to interact with a planning agency occurs in the construction phase of a project and involves building/inspection departments, which issue building permits and inspect the construction site for compliance with permit conditions. The water provider could request that one of the permitting conditions be approval for water-use efficiency. This would typically entail both a plan review and a site inspection. This request may or may not be granted by the planning agency, which would probably want some assurances that water-provider plan reviews (and site inspections) not delay the normal project schedule. The water provider may want to offer or may be asked to supply “sign-off” stamps signaling approval of meeting utility-permit conditions. To ensure compliance, an ideal goal for the water provider is to be included in both the planning and permitting processes.

The Water-Provider Application-for-Service Process

Most water providers will not issue a water meter until the conditions set forth in their regulations for water service are met. So, one obvious first step for the water provider may be to develop and adopt water-efficiency standards into their regulations as a condition for water service. Once efficiency standards are adopted, a top priority should be developer notification of these requirements as early in the planning

process as possible. Since a developer does not often contact the local water provider until much later (months or even years) in the planning process, it is important to develop a working relationship with the local planning agency and to integrate the need for a water-provider plan review into their planning process. Doing so may avoid problems for both the developer and the water provider, since it is not uncommon for a builder/developer to come into a water provider's business office expecting immediate issuance of a water meter. For a water meter to be issued, however, a "sign-off" by various departments is usually required. This may include review and approval by the water conservation office.

The primary objective of the water-provider application process is to determine conditions for service and to assess fees. Fees, in turn, are usually dependent upon water-meter size and the facilities (main extensions, storage, pumping, additional water supplies, etc.) needed to serve the new project. Therefore, a review of a developer's plans for water-use efficiency may save the developer money, if water demand (meter size) can be reduced.

In summary, an important goal of the water provider should be cooperation with the planning agency in notifying the developer of the provider's requirements. Developer notification of requirements can occur at either the planning or permitting stage of the project or both. Water-provider representatives should be prepared to undertake a number of measures to increase successful program implementation, including:

- preparing and sending pertinent material to the planning agency,
- making presentations to the planning agency,
- providing site inspections to verify compliance, and
- providing map stamps for utility sign-off (approval).

This page intentionally left blank.

Business Types

Office Buildings	3
Schools	7
Restaurants and Fast-Food Outlets	11
Commercial and Retail Centers	15
Hotels and Motels	17
Grocers	19
Hospitals	23
Laboratories	27
Coin- and Card-Operated Laundries	31
Industrial Laundries and Dry Cleaners	33
Vehicle Washes	37
Beverage Manufacturers	41
Bakery/Pastry Shops	43
Industrial Bakeries	47
Auto Service and Repair Shops	51
Fuel Service Stations and Convenience Stores	53
Commercial Printers	57
Metal Finishers	61
Paper Manufacturers	65
Water Features, Pools, and Landscapes	69

In the “Business-Type” summaries there are references to various “Water-Using Technology” sections of the guidebook, where more detailed information can be found. These references appear within the text in bold italics, for example, ***PROC*** for “Process Water,” ***REST*** for “Restrooms and Plumbing,” and ***TREAT*** for “Water Treatment.”

Key to Water-Using Technology Section Abbreviations Used in the Business-Type Summaries

ALT Alternate On-Site Water Sources
FOOD . . . Food-Service Operations
LAND . . . Landscape Water-Use Efficiency
LAUND. . . Laundries and Dry-Cleaning Operations
MED Medical Facilities and Laboratories
METER. . . Metering of Individual Units
PHOTO . . . Photo and Film Processing
POOL . . . Pools, Spas, and Fountains
PROC . . . Process Water
REST. . . . Restrooms and Plumbing
THERM. . . Thermodynamic Processes
TREAT . . . Water Treatment
WASH . . . Vehicle Washes

NOTE: In order to keep this guidebook up-to-date, and to facilitate adding new materials and new sections as they become available, without reproducing the entire guidebook, the units have been individually numbered, rather than numbering the entire guidebook sequentially.

Office Buildings

Office buildings may combine residential apartments, hotels, retail stores, and office space in the same structure. Each may have its own special needs for water. Typically, large buildings require water for HVAC, restrooms, food service, and maintenance.

Plumbing


Appropriate technologies include high-efficiency toilets requiring not more than 1.3 gallons per flush and urinals which flush with 1 gallon or less (no automatically timed flushing systems), as well as self-closing faucets with flows of 0.5 gallons per minute (gpm) for hand washing. If available, and where codes and health departments permit, non-potable water may be used for flushing, and waterless urinals should be evaluated for suitability. **REST**

Cooling Systems

Modern office buildings need to remove heat generated by computers, lights, people, and other operations. Energy-efficient equipment may reduce such waste heat, which is usually removed by a central refrigeration system and compressor. The compressor may be air-cooled or connected with a circulating loop to a cooling tower or evaporative condenser. As warm water from the compressor trickles through the cooling tower, some water evaporates, cooling the remaining water, which returns to cool the equipment. Measures to reduce water waste in cooling towers include:

- ◆ performing a life-cycle analysis, including all operating, capital, and personnel costs, to determine whether use of a cooling tower is more cost-effective than air cooling.
- ◆ equipping cooling towers with conductivity controllers, make-up and blowdown meters, and overflow alarms.
- ◆ operating towers at a minimum of five cycles of concentration using potable water, depending upon the chemistry of the make-up water used, including considerations for reclaimed water or on-site sources.
- ◆ avoiding once-through cooling with potable water. **FOOD**
- ◆ using high-efficiency drift eliminators that reduce drift loss to less than 0.002 percent of circulating water volume for cross-flow towers and 0.001 percent for counter-flow towers.

Modern office buildings need to remove heat generated by computers, lights, people, and other operations.



Typical water use in office buildings

- ◆ evaluating the processes in the plant for maximum energy efficiency and waste-heat recovery, since a more efficient building will reject less heat to the cooling tower.
- ◆ providing adequate training to cooling-tower operators.

THERM

Heating Systems

Steam boilers and hot-water boilers provide heat and hot water in some buildings. Closed-loop systems return water and steam condensate to the boiler for reuse, saving energy and water. Open-loop systems expend the water or steam without return to the boiler.

Several water-efficiency choices are available:

- ◆ recirculating hot-water systems for large buildings. **REST**
- ◆ steam boilers of 200 boiler horsepower (hp) or greater, equipped with conductivity controllers to regulate top blowdown.
- ◆ for closed-loop systems, condensate-return meters on steam boilers of 200 boiler hp or greater.
- ◆ closed-loop steam systems operating at twenty cycles of concentration or greater (5 percent or less of make-up water).
- ◆ steam-distribution lines and equipment with steam traps meeting all codes.
- ◆ make-up meters on feed-water lines:
 - » to steam boilers and water boilers of more than 100,000 Btus per hour.
 - » to closed-loop hot-water systems for heating.
- ◆ boiler-temperature and make-up meters that are clearly visible to operators.

Ensuring that facilities system operators are trained appropriately can help reduce water and energy waste and save money.



- ◆ discharge pipes that are easy to inspect for flow and visible indicators that will indicate whether the valve has activated, thereby reducing plumbing leaks due to repeated openings of water-temperature- and pressure-relief valves (TPRVs).

REST, THERM

Water Treatment

Measures to improve the efficiency of water treatment include:

- ◆ for all filtration processes, installing pressure gauges to determine when to backwash or change cartridges, followed by backwash based upon pressure differential.

- ◆ for all ion-exchange and softening processes, setting recharge cycles by volume of water treated or using conductivity controllers.
- ◆ avoiding the use of timers for softener-recharge systems.
- ◆ using water treatment only when necessary. **TREAT**



Ice Machines

Ice machines use water for ice and sometimes for cooling the compressor. Select:

- ◆ ice-making machines that are air-cooled, using remote heads to expel warm air outside the work space and customer areas. Air-cooled machines are preferred over cooling-tower loops.
- ◆ energy-efficient flake or nugget machines rather than cube-ice machines. If cube-ice machines are used, those that meet CEE Tier 2 efficiency standards are preferred. Tier 3 machines are even more efficient (CEE Commercial Kitchens). **FOOD**

Floor Cleaning

Floor-cleaning efficiency measures include:

- ◆ low-flow, high-pressure nozzles on hoses or water brooms for floor and mat washing where a flow of water is needed. **FOOD, PROC**
- ◆ drains placed close to areas where liquid discharges are expected in order to minimize the need to use a hose as a broom. **PROC**

Submetering

Separate metering of individual units (tenants), water-using systems, or building areas — is recommended where possible in order to ensure that the costs of water use and, where feasible, wastewater disposal are equitably dispersed and accounted for accurately. Reflecting actual use and costs often offers a reliable incentive for water-use efficiency. **METER**

Other

Other recommendations include:

- ◆ installing automatic shutoff and solenoid valves on all hoses and water-using equipment. **PROC**
- ◆ installing faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**

Reflecting actual use and costs can offer a reliable incentive for water-use efficiency, especially since many modern buildings house residences, hotels, retail stores, and business offices, each with its own special needs for water.

Refer to the following summaries for additional water-efficiency measures:

- ◆ **Restaurants and Fast-Food Outlets**
- ◆ **Hotels and Motels**
- ◆ **Water Features, Pools, and Landscapes**

TIP: Conspicuously mark fire-protection plumbing so no connections will be made other than those for fire protection. Install flow-detection meters on fire services to reveal unauthorized water flows. **REST**



Schools

Schools, colleges, and vocational institutions use water in many ways, including some similar to those of the following industries and processes: hospitality, food service, industrial laundry, image processing, water purification, vacuum systems, cooling towers and boilers, and cleaning, as well as industrial processes in vocational classes.

Plumbing

Appropriate water-saving technologies include high-efficiency toilets requiring not more than 1.3 gallons per flush and urinals that use 1 gallon or less per flush, with no automatically timed flushing systems. Choose self-closing faucets with flows of 0.5 gpm for hand washing. If available, and where codes and health departments permit, non-potable water may be used for flushing. **REST**

Other recommendations include:

- ◆ installing automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**
- ◆ installing faucets on set tubs and janitorial sinks, with flows not to exceed 2.2 gpm. **REST**

Cooling Systems


Generally, choose energy-efficient equipment to reduce waste heat, which could otherwise require larger water technologies such as cooling towers. Other water-efficiency practices include the following:

- ◆ prefer air cooling over recirculating cooling-water systems.
- ◆ use water treatment only when necessary. **TREAT**
- ◆ avoid once-through cooling with potable water. **FOOD**

Cooling towers may be required for some facilities. If such need is determined, there are numerous operational efficiency measures:

- ◆ conduct a life-cycle analysis, including all operating, capital, and personnel costs, to determine whether the use of a cooling tower is more cost-effective than air cooling.
- ◆ equip all cooling towers with conductivity controllers, make-up and blowdown meters, and overflow alarms.
- ◆ operate towers at a minimum of five cycles of concentration in regions with high water quality (low TDS) for towers using potable water, depending upon the chemistry of the make-up water, including considerations for reclaimed water or on-site sources.

Schools use water in ways similar to many other operations, such as laboratories, office buildings, hotels, food service, and industrial processes.



Typical water use in schools



- ◆ install high-efficiency drift eliminators that reduce drift loss to less than 0.002 percent of circulating water volume for cross-flow towers and 0.001 percent for counter-flow towers.
- ◆ avoid using cooling towers of less than 100 tons for air-conditioning systems.
- ◆ evaluate entire buildings or processes for maximum energy efficiency, since more efficient buildings will reject less heat to cooling towers.

- ◆ evaluate waste-heat recovery for beneficial uses rather than rejecting it to the tower. **THERM**

Highly efficient toilet and lavatory equipment is critical, since restrooms are the major water consumers in schools.

Heating Systems

Steam boilers and hot-water boilers provide heat and hot water in some buildings. Closed-loop systems return water and steam condensate to the boiler for reuse, saving energy and water. Open-loop systems expend the water or steam without return to the boiler.

Several water-efficiency measures are available:

- ◆ equip steam boilers of 200 boiler-horsepower (hp) or greater with conductivity controllers to regulate top blowdown.
- ◆ install condensate-return meters on closed-loop-system steam boilers of 200 boiler hp or greater.
- ◆ design closed-loop steam systems to operate at twenty cycles of concentration or greater (5 percent or less of make-up water).
- ◆ equip steam-distribution lines and equipment with steam traps meeting all codes.
- ◆ install make-up meters on feed-water lines to:
 - » steam boilers and water boilers of more than 100,000 Btus per hour.
 - » closed-loop hot-water systems for heating.
 - » make sure boiler-temperature and make-up meters are clearly visible to operators.
 - » make discharge pipes easy to inspect for flow, and incorporate visible indicators that will reveal whether the valve has been activated. **REST, THERM**

Special Purposes

For laboratories, choose dry-vacuum systems rather than liquid-ring pumps. For vacuum and compressor systems, use air-cooled, radiator-cooled, or chilled-loop or cooling-tower systems. **MED**

For photography and medical and other imaging, employ digital technologies that allow images to be displayed on electronic video screens and stored in computer files. Where film imaging is required, use self-contained “mini-lab” developing units that require no plumbing or washing to develop the film. For paper or film image copies use laser or ink-jet printing. **PHOTO**

Floor Cleaning

Wet methods may be used for floor cleaning, but open hoses are discouraged as being wasteful. To increase water-use efficiency:

- ◆ install drains close to areas where liquid discharges are expected. **PROC**
- ◆ arrange equipment for easy use of mop and squeegee systems or floor-cleaning machines.
- ◆ install self-closing nozzles, limiting flow of washdown hoses to 5 gpm. **FOOD**

Submetering

Separate metering of individual water-using systems or building areas is recommended where possible in order to ensure that the costs of water use and, where feasible, wastewater disposal are equitably dispersed and accounted for accurately. Reflecting actual use and costs often offers a reliable incentive for water-use efficiency. **METER**

Other

In addition to the water-efficiency measures identified here, refer to the following summaries for other efficiency practices:

- ◆ for water features, therapeutic pools, swimming pools, and landscapes, refer to the summary “**Water Features, Pools, and Landscapes.**”
- ◆ for kitchens and food service areas, refer to “**Restaurants and Fast-Food Outlets.**”
- ◆ for dormitories refer to “**Hotels and Motels.**”

Mark fire-protection plumbing conspicuously to ensure no connections are made other than those for fire protection.



Wise practices to reduce waste heat can avoid the need for larger water technologies, such as cooling towers.

- ◆ for laboratories refer to “**Laboratories.**”
- ◆ for vocational campuses, refer to “**Auto Service and Repair Shops,**” “**Metal Finishers,**” “**Hospitals,**” “**Hotels and Motels,**” and “**Industrial Bakeries.**”

TIP: Conspicuously mark fire-protection plumbing so no connections will be made other than those for fire protection, and install flow-detection meters on fire services to reveal unauthorized water flows. **REST**

Restaurants & Fast-Food Outlets

Restaurants and fast-food outlets serve many varieties of food, snacks, beverages, and sometimes bakery products. In these businesses, water has many uses: as a product ingredient and for cooking, cooling, cleaning, and sanitizing.

Kitchen Equipment

Selecting energy-efficient equipment helps reduce waste heat, which has implications for water use. Because of particular practices in the restaurant and food-service business, energy-efficient equipment offers significant water savings. Choose refrigerators and freezers that have adequate refrigerator space for thawing food and use air-cooling rather than recirculating cooling-water systems. **FOOD**

Cooking and Serving Systems

Cooking and warming devices have many opportunities for improved water efficiency:

- ◆ select combination ovens that use no more than 15 gallons of water per hour and comply with the California energy rebate list prepared by Fisher-Nickel.
- ◆ instead of steam tables, install dry heating tables.
- ◆ return and reuse condensate for all boiler-type steam kettles.
- ◆ size steam traps for proper operation to avoid dumping condensate.
- ◆ insulate condensate-return lines.
- ◆ use pasta cookers with a simmer mode and automatic overflow-control valves. Restrict flow to a half a gallon per minute.
- ◆ use connectionless or boilerless steamers consuming no more than 3 gallons per hour.
- ◆ install in-line restrictors that reduce “dipper well” flow to under 0.3 gpm. **FOOD**


Scullery Operations

Scullery operations, including dishwashing, are water intensive.

Reduce use with:

- ◆ pre-rinse spray valves (1.5 gpm max) for dish rinsing.
- ◆ strainer (scrapper) baskets in place of garbage disposals (grinders).

Restaurants use water to create their products, as well as for cooling, cleaning, and sanitizing.



Typical water use in restaurants and fast-food outlets



- ◆ dishwashers meeting efficiency standards set by the Consortium for Energy Efficiency (CEE).
- ◆ steam doors on dishwashers.
- ◆ dishwashing equipment that meets Energy Star standards.

FOOD

Ice Machines

Ice machines use water for ice and sometimes for cooling the compressor. Select:

- ◆ ice-making machines that are air-cooled, using remote heads to expel warm air outside the work space and customer areas. Air-cooled machines are preferred over a cooling-tower loop.
- ◆ energy-efficient flake or nugget machines rather than cube machines. If cube-ice machines are used, select those that meet Energy Star standards. CEE Tier 3 machines are even more efficient. **FOOD**

Plumbing

Appropriate technologies include high-efficiency toilets requiring not more than 1.3 gallons per flush and urinals which flush with 1 gallon or less (no automatically timed flushing systems), as well as self-closing faucets with flows of 0.5 gallons per minute (gpm) for hand washing. If available, and where codes and health departments permit, non-potable water may be used for flushing. **REST**

Cooling and Heating Systems

Refer to the “Office Buildings” and “Schools” summaries for recommendations on evaluating cooling towers *versus* air-cooling, open- *versus* closed-loop systems, and heat and hot-water system practices.

Water Treatment Systems

Measures to improve the efficiency of water treatment include:

- ◆ for all filtration processes, install pressure gauges to determine when to backwash or change cartridges, then backwash based upon pressure differential.
- ◆ for all ion-exchange and softening processes, set recharge cycles by volume of water treated or based upon conductivity controllers.
- ◆ avoid the use of timers for softener recharge systems.

TREAT



When planning scullery operation installations, strive to maximize efficiency, while minimizing water and energy consumption.

Floor Cleaning

Floor cleaning may use wet methods, but wasteful open hoses are discouraged. Install drains close to areas where liquid discharges are expected. **PROC** Arrange equipment for easy use of a mop and squeegee system or floor-cleaning machine. Install self-closing nozzles, limiting flow to 5 gpm on washdown hoses. **FOOD**

Submetering

Separate metering of individual units (tenants), water-using systems, or building areas — is recommended where possible in order to ensure that the costs of water use and, where feasible, wastewater disposal are equitably dispersed and accounted for accurately. Reflecting actual use and costs often offers a reliable incentive for water-use efficiency. **METER**

Other

Additional water savings can be realized by using:

- ◆ automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**
- ◆ faucets on set tubs and janitorial sinks with flows not exceeding 2.2 gpm. **REST**

Refer to the summaries for “**Bakery/Pastry Shops,**” “**Industrial Bakeries,**” and “**Water Features, Pools, and Landscapes**” for additional water-efficiency measures specific to restaurant and food-service businesses.

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, flow-detection meters should be installed on fire services to signal unauthorized water flows. **REST**



Refrigerators should have adequate space for thawing food. Avoid thawing food under running water.

This page intentionally left blank.

Commercial & Retail Centers

The larger and more complex the retail center, the more water-uses are employed. They may include those of medical and dental offices, the hospitality industry, food-service outlets, laundries, photo processing, grocery stores, cooling towers and boilers, and maintenance cleaning.

Plumbing

Appropriate technologies include high-efficiency toilets requiring not more than 1.3 gallons per flush and urinals which flush with 1 gallon or less (no automatically timed flushing systems), as well as self-closing faucets with flows of 0.5 gallons per minute (gpm) for hand washing. If available, and where codes and health departments permit, non-potable water may be used for flushing. **REST**

Cooling and Heating Systems

Refer to the “**Office Buildings**” and “**Schools**” summaries for recommendations on evaluating cooling towers *versus* air-cooling, open- *versus* closed-loop systems, and heat and hot-water system practices.

Floor Cleaning

Floor cleaning may use wet methods, but wasteful open hoses are discouraged. Install drains close to areas where liquid discharges are expected. **PROC** Arrange equipment for easy use of a mop and squeegee system or floor-cleaning machine. Install self-closing nozzles, limiting flow to 5 gpm on washdown hoses. **FOOD**


Submetering

Separate metering of individual units (tenants), water-using systems, or building areas is recommended where possible in order to ensure that the costs of water use and, where feasible, wastewater disposal are equitably dispersed and accounted for accurately. Reflecting actual use and costs often offers a reliable incentive for water-use efficiency. **METER**

Special Purposes

For photography and medical and other imaging, employ digital technologies that allow images to be displayed on electronic

Use climate-appropriate landscaping and irrigation systems to reduce water consumption in multi-use centers.



Typical water use in commercial and retail centers



Types of water uses can vary greatly in commercial and retail centers, so sub-metering may be more important than in some other facilities.

video screens and stored on computer files. Where film imaging is required, use self-contained “mini-lab” image-developing units that require no plumbing or washing to develop the film. For paper or film copies of the image, produce images using laser or ink-jet printing technology. **PHOTO**

Other

Other summaries identify additional water-efficiency practices for such centers.

- ◆ For water features, therapeutic pools, swimming pools and landscape, refer to “**Water Features, Pools, and Landscapes.**”
- ◆ For kitchens and food service areas, see “**Restaurants and Fast-Food Outlets**” and “**Bakery/Pastry Shops.**”
- ◆ For medical and dental offices and laboratories, refer to “**Hospitals**” and “**Laboratories.**”
- ◆ For laundries, see “**Coin- and Card-Operated Laundries.**”
- ◆ For take-home food sales, refer to “**Grocers.**”
- ◆ For vehicle maintenance and sales, refer to “**Auto Service and Repair Shops**” and “**Vehicle Washes.**”

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, flow-detection meters should be installed on fire services to signal unauthorized water flows. **REST**



Hotels & Motels

Large hotels may combine residential apartments, retail stores, elaborate recreation facilities, lavish landscaping, and office space at the same site. Each purpose may have its own special needs for water. Smaller motels may have similar guest-room water uses, plus recreation facilities and irrigated landscapes. Typically, large buildings require water for HVAC, restrooms, food service, and maintenance.

Plumbing

Appropriate water-saving technologies include high-efficiency toilets requiring not more than 1.3 gallons per flush and urinals that use 1 gallon or less per flush, with no automatically timed flushing systems. Choose self-closing faucets with flows of 0.5 gpm for hand washing. If available, and where codes and health departments permit, non-potable water may be used for flushing. **REST**

In guest rooms, limit faucets to flows of 1.5 gpm or less and shower heads to flows of 2.0 gpm or less. Install only one shower head per personal shower stall. Substitute showers for bathtubs. Where bathtubs are necessary, use low-volume tubs.

Cooling and Heating Systems


Refer to the “Office Buildings” and “Schools” summaries for recommendations on evaluating cooling towers *versus* air-cooling, open- *versus* closed-loop systems. Heat and hot-water system practices are also discussed in these summaries.

Floor Cleaning

Recommendations for floor cleaning include:

- ◆ floor cleaning may use wet methods, but wasteful open hoses are discouraged.
- ◆ install drains close to areas where liquid discharges are expected. **PROC**
- ◆ arrange equipment for easy use of a mop and squeegee system or floor-cleaning machine.
- ◆ install self-closing nozzles, limiting flow to 5 gpm on wash-down hoses. **FOOD**

Showers in guest rooms should have only one shower head per personal shower stall. Avoid installing bathtubs when possible.



Typical water use in hotels and motels



Ice Machines

Ice machines use water for ice and sometimes for cooling the compressor. Select:

- ◆ ice-making machines that are air-cooled, using remote heads to expel warm air outside the work space and customer areas. Air-cooled machines are preferred over cooling-tower loops.
- ◆ energy-efficient flake or nugget machines rather than cube-ice machines. If cube-ice machines are used, those that meet CEE Tier 2 efficiency standards are preferred. Tier 3 machines are even more efficient (CEE Commercial Kitchens). **FOOD**

Many hotels have lavish landscaping. Ensure use of climate-appropriate plant materials. Carefully monitor irrigation systems to apply only the amount of water necessary.

Submetering

Separate metering of water-using systems and building areas is recommended where possible in order to ensure that the costs of water use and, where feasible, wastewater disposal are equitably dispersed and accounted for accurately. Reflecting actual use and costs often offers a reliable incentive for water-use efficiency. **METER**

Other

Other recommendations include:

- ◆ installing automatic shutoff and solenoid valves on all hoses and water-using equipment. **PROC**
- ◆ installing faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**
- ◆ encourage guests to engage in “green” practices for bed linens and towels to avoid unnecessary laundry use.

For water features, therapeutic pools, swimming pools, and landscapes, refer to the summary for “**Water Features, Pools and, Landscapes.**” For kitchens and food service areas, refer to “**Restaurants and Fast-Food Outlets**” and “**Industrial Bakeries.**”

TIP: Conspicuously mark fire-protection plumbing so no connections will be made other than those for fire protection. Install flow-detection meters on fire services to reveal unauthorized water flows. **REST**



Grocers

Grocery-stores typically use water for a variety of operations: spraying fresh vegetables with cold water, ice machines, deli operations, food preparation and restaurant service, photo processing, floor cleaning, and cooling refrigeration equipment with cooling towers/evaporative condensers.

Cooling and Heating Systems

Freezers, refrigeration and cooler operations, and comfort air conditioning equipment are often linked to remote refrigeration equipment. It can be air-cooled or cooled by a cooling tower. A cooling tower functions by directing warm water from the compressor to trickle through the cooling tower, where some evaporates, cooling the remaining water, which then returns to cool the equipment.

According to recent studies of grocery stores in California, half the water used at facilities with cooling towers is used by the cooling towers themselves. In other parts of the South and Southwest, air cooling, typically with multiple rooftop units, is much more common.

The use of multiple rooftop units allows a grocery to continue to operate even if one or two units are down for repair. The use of air cooling also eliminates the cost of building and operating a cooling tower, but air-cooled units are generally less energy-efficient than systems using cooling towers, especially under full- or base-load conditions.


The type of mechanical refrigeration and air-conditioning equipment chosen has four implications for water use:

- ◆ if direct exchange air-cooled refrigeration and air conditioning are used, a grocery's water consumption could be reduced by half or more.
- ◆ if cooling towers are used, their good energy efficiency is one of the grocery's most significant water-conserving tools.

THERM

- ◆ even a partial use of air cooling, such as for air conditioning, could significantly reduce water use.

Grocery operations have diversified to include fresh prepared foods, restaurants, photo processing, and more. Water uses have multiplied, too.



Typical water use in grocery stores



◆ if cooling towers are used, operate them as efficiently as possible to maximize cycles of concentration. **THERM**

Refer to the “**Office Buildings**” and “**Schools**” summaries for recommendations on evaluating cooling towers *versus* air-cooling, open-*versus* closed-loop systems, and heat and hot-water system practices.

Ice and direct water-sprays are often used in vegetable displays both to maintain the products’ freshness and to enhance their appeal. Vegetables appear crisp, cool, and “dew-drop” fresh.

Kitchen Equipment

Some grocers offer prepared food, both for take-out and eat-in, in addition to traditional groceries. Preparation of food for sale and scullery operations, in particular, are areas where large amounts of water are used. Selecting energy-efficient kitchen equipment helps reduce waste heat, which also has implications for water use.

Planners of kitchen facilities should choose refrigerators that have adequate space for thawing food. Thawing food under running water should be avoided. **FOOD**

Water consumption for scullery operations, including dishwashing, can be reduced by using the following:



- ◆ pre-rinse spray valves (1.5 gpm maximum) for dish rinsing.
- ◆ strainer (scraper) baskets in place of garbage disposals (grinders).
- ◆ dishwashers meeting efficiency standards set by the Consortium for Energy Efficiency (CEE).
- ◆ steam doors on dishwashers.
- ◆ dishwashing equipment that meets Energy Star standards.

FOOD

Where cooking is involved, cooking and warming devices offer many opportunities for improved water efficiency.

- ◆ Select combination ovens that use no more than 15 gallons of water per hour and comply with the California energy rebate list.
- ◆ Instead of steam tables, install dry heating tables.
- ◆ Return and reuse condensate for all boiler-type steam kettles.
- ◆ Size steam traps for proper operation to avoid dumping condensate.
- ◆ Insulate condensate-return lines.
- ◆ Use pasta cookers with a simmer mode and automatic overflow-control valves. Restrict flow to half a gallon per minute.
- ◆ Use connectionless or boilerless steamers consuming no more than 3 gallons per hour.
- ◆ Install in-line restrictors that reduce “dipper well” flow to under 0.3 gpm. **FOOD**



Water quality is of primary concern in all food preparation and service processes.

Store Operations

Limit sprays to fresh vegetables to the amount necessary.

Photo processing should use self-contained “mini labs” that require no plumbing or washing. **PHOTO**

Ice Machines

Ice machines use water for ice and sometimes for cooling the compressor. Select:

- ◆ ice-making machines that are air-cooled, using remote heads to expel warm air outside the work space and customer areas. Air-cooled machines are preferred over cooling-tower loops.
- ◆ energy-efficient flake or nugget machines rather than cube-ice machines. If cube-ice machines are used, those that meet CEE Tier 2 efficiency standards are preferred. Tier 3 machines are even more efficient (CEE Commercial Kitchens). **FOOD**

Choosing energy-efficient equipment helps reduce energy waste, which has implications for water conservation both at the site of use and at the site of generation.

Plumbing

Appropriate technologies include high-efficiency toilets requiring not more than 1.3 gallons per flush and urinals which flush with 1 gallon or less (no automatically timed flushing systems), as well as self-closing faucets with flows of 0.5 gallons per minute (gpm) for hand washing. If available, and where codes and health departments permit, non-potable water may be used for flushing. **REST**

Floor Cleaning

Recommendations for floor cleaning include:

- ◆ floor cleaning may use wet methods, but wasteful open hoses are discouraged.
- ◆ install drains close to areas where liquid discharges are expected. **PROC**
- ◆ arrange equipment for easy use of a mop and squeegee system or floor-cleaning machine.
- ◆ install self-closing nozzles, limiting flow to 5 gpm on wash-down hoses. **FOOD**

Submetering

Separate metering of individual units, water-using systems, or building areas is recommended where possible in order to ensure that the costs of water use and, where feasible, wastewater disposal are equitably dispersed and accounted for accurately. Reflecting actual use and costs often offers a reliable incentive for water-use efficiency. **METER**

Other

Additional water savings can be realized by using:

- ◆ automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**
- ◆ faucets on set tubs and janitorial sinks with flows not exceeding 2.2 gpm. **REST**

The summaries for “**Restaurants and Fast-Food Outlets,**” “**Bakery/Pastry Shops,**” and “**Industrial Bakeries**” offer additional water-efficiency measures, including some specific to grocery operations.

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, flow-detection meters should be installed on fire services to signal unauthorized water flows. **REST**

Hospitals

Large hospitals employ many water-use functions, such as those of the hospitality industry, food service, industrial laundry, image processing for x-rays, morgue, sterilizing, water purification, vacuum systems, cooling towers and boilers, as well as hygiene practices for patients, staff, and facilities.

Plumbing

Appropriate technologies include high-efficiency toilets requiring not more than 1.3 gallons per flush and urinals which flush with 1 gallon or less (no automatically timed flushing systems), as well as self-closing faucets with flows of 0.5 gallons per minute (gpm) for hand washing. If available, and where codes and health departments permit, non-potable water may be used for flushing. **REST**

Cooling and Heating Systems

Refer to the “Office Buildings” and “Schools” summaries for recommendations on evaluating cooling towers *versus* air-cooling, open- *versus* closed-loop systems, and heat and hot-water system practices.

Water Treatment

Use water treatment only when necessary. **TREAT**


Special Purposes and Equipment

All stand-alone steam sterilizers should be equipped with condensate-tempering systems. All vacuum sterilizers should be equipped with mechanical vacuum systems. Promote use of condensate-return systems for sterilizers. **MED**

For X-rays, MRI, CT scans, and other imaging, employ digital technologies that allow images to be displayed on electronic video screens and stored on computer files. Where film imaging is required, use self-contained “mini-lab” image-developing units that require no plumbing or washing to develop the film. Produce paper or film copies of images using laser or ink-jet printing technology. Where large x-ray film technologies are retained, employ Water Saver/Plus™ recycling technology to vastly reduce water waste.

PHOTO

Hospitals combine the functions of hotels, food service operations, industrial laundries, and more. With so many water uses, efficiency can result in significant savings.



Typical water use in hospitals



Install dry-vacuum systems instead of liquid-ring pumps. All vacuum and compressor systems should be air-cooled or use a radiator cooler or a chilled-loop or cooling-tower system. **MED**

Generally, all equipment should be energy-efficient to reduce waste heat, which may otherwise require larger water technologies such as cooling towers.

Air cooling is more water efficient rather than recirculating cooling-water systems. Absolutely avoid once-through cooling with potable water. **FOOD**

Cleaning and sanitation are important operations in hospitals and clinics of all sizes. Equipment used in floor cleaning should be designed for efficiency in use, as well as effectiveness for sanitation purposes.

Ice Machines

Ice machines are located in many places throughout hospitals. Select:

- ◆ ice-making machines that are air-cooled, using remote heads to expel warm air outside the work space and customer areas. Air-cooled machines are preferred over cooling-tower loops.
- ◆ energy-efficient flake or nugget machines rather than cube-ice machines. If cube-ice machines are used, those that meet CEE Tier 2 efficiency standards are preferred. Tier 3 machines are even more efficient (CEE Commercial Kitchens). **FOOD**

Floor Cleaning

Recommendations for floor cleaning include:

- ◆ may use wet methods, but wasteful open hoses are discouraged.
- ◆ install drains close to areas where liquid discharges are expected. **PROC**
- ◆ arrange equipment for easy use of a mop and squeegee system or floor-cleaning machine.
- ◆ install self-closing nozzles, limiting flow to 5 gpm on wash-down hoses. **FOOD**



Submetering

Major water-using systems and building areas should be separately metered. **PROC** Submetering helps ensure that the costs of water use and, where feasible, wastewater disposal are equitably dispersed and accounted for accurately. Reflecting actual use and costs often offers a reliable incentive for water-use efficiency. **METER**

Other

Other recommendations include:

- ◆ installing automatic shutoff and solenoid valves on all hoses and water-using equipment. **PROC**
- ◆ installing faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**

As well as the measures identified here, additional water-efficiency practices are covered in other summaries. For therapeutic pools and landscapes, refer to the summary for “**Water Features, Pools and, Landscapes.**” For kitchens and food service areas, refer to “**Restaurants and Fast-Food Outlets.**” Relevant recommendations are also found in the summary for “**Laboratories.**”

TIP: Conspicuously mark fire-protection plumbing so no connections will be made other than those for fire protection. Install flow-detection meters on fire services to reveal unauthorized water flows. **REST**



Many modern imaging techniques use electronic technologies that go straight to film or computer files that can be displayed or printed on paper. These avoid using water-based processes, saving both water use and wastewater generation.

This page intentionally left blank.

Laboratories

The term “laboratory” refers to a broad range of facilities, including those for medical research and analysis, research and analytical testing, industrial and commercial activities, and imaging. New technology has benefited all these facilities and considerably reduced water consumption.

Standards and Practices

Cleaning and sterilizing instruments — Equip all stand-alone steam sterilizers with condensate-tempering systems. Promote the use of condensate-return systems for sterilizers.

Equip all vacuum sterilizers with mechanical vacuum systems. Install dry-vacuum systems that do not use water for the pump seal.

MED

Fume hoods should employ dry hood-exhaust systems wherever possible. Use recirculating systems in hood scrubbers. Perchlorate hoods should employ self-closing valves on fume-hood washdown systems. **MED**

For X-rays, MRIs, CT scans, and other imaging, employ digital technologies that allow images to be displayed on electronic video screens and stored on computer files. Where film imaging is required, use self-contained “mini-lab” image-developing units that require no plumbing or washing to develop the film. Produce paper or film copies of images using laser or ink-jet printing technology. Where large x-ray film technologies are retained, employ Water Saver/Plus™ recycling technology to vastly reduce water waste. **PHOTO**



Cooling Systems

Have adequate refrigerator space for thawing frozen materials. Avoid thawing under running water.

All vacuum and compressor systems should be air-cooled or use a radiator cooler or a chilled-loop or cooling-tower system.

There are many types of laboratories with varied purposes and many types of water use. Water quality is often of significant importance for laboratory operations, regardless of the type or function.



Modern medical imaging systems employ digital technologies that allow images to be displayed on video screens and stored in computer files, minimizing consumption of a variety of resources.

Dry (air) cooling is more water efficient rather than recirculating cooling-water systems and should be used wherever possible.

Install a closed-loop system, such as a chilled-water or cooling-tower system, or install a recirculating chiller unit.

Absolutely avoid once-through cooling with potable water. **FOOD**

Heating Systems

Boiler-water efficiency — Closed-loop systems return water and steam condensate to a boiler for reuse, saving energy and water. Open-loop systems expend the water or steam without return to the boiler. Install make-up meters on feed-water lines to steam boilers and water boilers of more than 100,000 Btus per hour and closed-loop hot-water systems for heating. Situate boiler-temperature and make-up meters to be clearly visible to operators. Equip steam boilers of 200 boiler hp or greater with conductivity controllers to regulate top blowdown.

For closed-loop steam systems, install condensate-return meters and operate at twenty cycles of concentration or greater (5 percent or less of make-up water). Reduce plumbing leaks due to repeated openings of water-temperature and pressure-relief valves (TPRVs). Make discharge pipes easy to inspect for flow and ensure that valve activations are visibly indicated. **REST, THERM**

Water Reuse and Recirculation

Recover and reuse sources such as reverse-osmosis reject water, air-conditioner condensate, rainwater, foundation drain water, and any other applicable source for use as irrigation water, scrubber-water make-up, and cooling-tower make-up. **MED** Water used for heat-transfer usually remains relatively clean and is an excellent source of water for reuse. **PROC**

Water Treatment

Measures to improve efficiency in water treatment include:

- ◆ using water treatment only when necessary.
- ◆ for all filtration processes, install pressure gauges, then back-wash or change cartridges based upon pressure differential. Avoid use of timers for softener recharge systems.

- ◆ for all ion-exchange and softening processes, set recharge cycles by volume of water treated or based upon conductivity controllers.
- ◆ use reverse-osmosis and nanofiltration systems with the lowest reject rate for size.
- ◆ if distillation equipment is required, choose equipment that uses air-cooled coils. If water-cooled, the still should recover at least 85 percent of the feed water. **TREAT**

Ice Machines

Select:

- ◆ ice-making machines that are air-cooled, using remote heads to expel warm air outside the work space and customer areas. Air-cooled machines are preferred over cooling-tower loops.
- ◆ energy-efficient flake or nugget machines rather than cube-ice machines. If cube-ice machines are used, those that meet CEE Tier 2 efficiency standards are preferred. Tier 3 machines are even more efficient (CEE Commercial Kitchens). **FOOD, MED**

Plumbing

In restrooms use high-efficiency toilets using not more than 1.3 gallons per flush and urinals that use 1 gallon or less per flush, with no automatically timed flushing systems. Choose self-closing hand washing faucets with flows of 0.5 gpm. If available, and where codes and health departments permit, use non-potable water for flushing. **REST**

Floor Cleaning

Recommendations for floor cleaning include:

- ◆ floor cleaning may use wet methods, but wasteful open hoses are discouraged.
- ◆ install drains close to areas where liquid discharges are expected. **PROC**
- ◆ arrange equipment for easy use of a mop and squeegee system or floor-cleaning machine.
- ◆ install self-closing nozzles, limiting flow to 5 gpm on wash-down hoses. **FOOD**

Submetering

Major water-using systems and building areas should be separately metered. **PROC** Submetering helps ensure that the costs of water

All stand-alone steam sterilizers should be equipped with condensate-tempering systems and should provide for condensate return.

Technologies are available to treat and reuse many water resources, such as reverse osmosis, collection of air conditioner condensate, rain, foundation drain water, and scrubber-water make-up.

use and, where feasible, wastewater disposal are equitably dispersed and accounted for accurately. Reflecting actual use and costs often offers a reliable incentive for water-use efficiency. **METER**

Other

Other recommendations include:

- ◆ installing automatic shutoff and solenoid valves on all hoses and water-using equipment. **PROC**
- ◆ installing faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**

Many energy- and water-efficiency practices for laboratories are common to those described in the summaries for “**Office Buildings**” and “**Schools.**” Where irrigated landscaping is present, refer to “**Water Features, Pools, and Landscapes.**”

TIP: Conspicuously mark fire-protection plumbing so no connections will be made other than those for fire protection. Install flow-detection meters on fire services to reveal unauthorized water flows. **REST**

Coin- & Card-Operated Laundries

Coin- and card-operated laundries range from those in apartment-complex common rooms to busy commercial laundromats.

Standards and Practices

Currently the Federal Energy Policy Act Standards of 2005 for commercial coin- and card-operated single-load, soft-mount, residential-style laundry equipment specify a water factor of 9.5, while the US EPA Energy Star criteria level as of 2007 is 8.0. This applies to clothes washers with capacities up to 3.5 cubic feet for horizontal-axis machines and 4.0 cubic feet for top-loading machines. For greater efficiency, a water factor of less than or equal to 8.0 is desirable for single-load soft-mount washers. **LAUND**

Laundry operators are installing more large, multi-load machines. The majority of these are hard-mount or solid-mount machines that are bolted to the floor. All multi-load washers can be set to operate at a number of cycles, including flush, wash, bleach, rinse, scour, and sizing. Also, water levels can be set differently for each cycle, so water use varies greatly depending upon the setting. It is important to specify that washers be preset to meet the water factor, which can be done by the factory or by the route operator who leases the equipment. A water factor of 8.0 for all equipment is achievable and recommended. **LAUND**

Heating Systems

Hot-water boilers (heaters) provide hot water to clothes-washing machines. No water is returned to the water heater for reuse. The two major water-saving actions related to hot-water boilers are water-efficient washers and preventing plumbing leaks. **THERM** Temperature- and water-pressure-relief valves (TPRVs) may open or leak. Make discharge pipes easy to inspect for flow, and ensure that there are visible indicators of whether a valve has activated. **REST**

Water Treatment

If water softeners are used, equip all softener systems with controllers that activate based

Laundry operators are installing large, multi-load washing machines that offer more options for cycles and water levels, as well as opportunities for water savings.



Where spills are likely to happen or where floors must be washed frequently, it is wise to install floor drains.

upon the volume of water treated. Alternatively, some controllers actually measure water hardness. Use water softeners and other treatments only when necessary, and don't recharge softener systems based upon a timer. Where filtration systems are employed, require pressure gauges to determine when to backwash or change cartridges, and backwash based upon pressure differential. **TREAT**

Plumbing

Appropriate technologies include high-efficiency toilets requiring not more than 1.3 gallons per flush and urinals which flush with 1 gallon or less. Use no automatically-timed flushing systems. Use self-closing faucets with flows of 0.5 gpm for hand washing. If available, and where codes and health departments permit, use non-potable water for flushing. **REST**

Spaces where regular water use may result in spills or where floors may be washed frequently often have floor drains. Plumbing codes require traps to prevent gases and odors from seeping from sanitary sewers into rooms through the drains. The gas is blocked by water trapped below the drain in an "S" shaped pipe called a "P trap." To sustain water in the trap in less frequently used spaces, additional water must be added with a device called a trap primer — a valve or other connection from a water source that allows a small amount of water to flow through pipes to recharge traps of one or more drains. Avoid continuous flow to trap primers. Instead, install pressure-activated or electronic trap primers, each serving several drains. **REST**

Install automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**

Install faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**

Floor Cleaning

Employ these floor-cleaning efficiency practices:

- Use low-flow, high-pressure nozzles on hoses or water brooms used for floor and mat washing where a flow of water is needed. **PROC, FOOD**
- Minimize the need to use a hose as a broom by installing drains close to areas where liquid discharges are expected. **PROC**

TIP: Conspicuously mark fire-protection plumbing so no connections will be made other than those for fire protection. Install flow-detection meters on fire services to reveal unauthorized water flows. **REST**

Industrial Laundries & Dry Cleaners

Industrial laundry equipment and processes serve many applications, from dry-cleaning establishments, to institutions and commercial facilities for hotels, prisons, hospitals, nursing homes, and athletic programs. Such laundries offer uniforms, diaper, and linens services to the same set of users as on-premise operations.

LAUND

Commercial dry-cleaning operations are changing since chemical cleaning agents are being phased out due to air-quality concerns. Replacement technologies include wet cleaning, silicon-based technology, and supercritical carbon dioxide. Wet cleaning is a laundry operation using water as the cleaning agent. If air cooling is used, the other two technologies can use no water; so they should be encouraged. **LAUND**

Standards and Practices


Industrial laundry operations use multi-load washer extractors with numerous control settings and load capacities up to hundreds of pounds. Washer-extraction technology has high water-efficiency capability (2 to 4 gallons per pound), depending upon the degree of soil of the goods being cleaned. Tunnel washers are major pieces of equipment that operate on a continuous (rather than batch-load) basis to wash very large volumes of soiled goods. The high efficiency of tunnel washers invites their use where large volumes of laundry can be sustained. **LAUND**

The majority of large, multi-load machines are hard-mount or solid-mount machines that are bolted to the floor. All multi-load washers can be set to operate at a number of cycles, including flush, wash, bleach, rinse, scour, and sizing. Water levels can be set differently for each cycle, so water use varies greatly depending upon the setting. For water and energy efficiency, specify that washers be preset to meet the water factor of 8.0 or better. **LAUND**

Heating Systems

Hot-water boilers (heaters) provide hot water to clothes-washing machines. No water is returned to the water heater for reuse. The two major water-saving actions related to hot-water boilers are water-efficient washers and preventing plumbing leaks. **THERM**

Large tunnel washers operate on a continuous basis, where volumes of laundry are very large, for example, hotels and hospitals.



Typical water use in industrial laundries

Instead, install pressure-activated or electronic trap primers, each serving several drains. **REST**

Floor Cleaning

Floor cleaning may use wet methods, but wasteful open hoses are discouraged. Alternative methods include installing self-closing nozzles that limit flow to 5 gpm on washdown hoses. Employ these floor-cleaning efficiency practices:

- ◆ use low-flow, high-pressure nozzles on hoses or water brooms for floor and mat washing where a flow of water is needed. **REST, PROC, FOOD**
- ◆ minimize the need to use a hose as a broom by installing drains close to areas where liquid discharges are expected. **PROC**

Submetering

The nature of the technology makes these facilities water-intensive, and water meters should be employed in each major segment of the process. **PROC** Separate metering of individual water-using systems or building areas is recommended where possible in order to ensure that the costs of water use and, where feasible, wastewater disposal are equitably dispersed and accounted for accurately. Reflecting actual use and costs often offers a reliable incentive for water-use efficiency. **METER**

Other

Install automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**

Install faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, flow-detection meters should be installed on fire services to indicate unauthorized water flows. **REST**

Air-quality concerns are causing the commercial dry-cleaning industry to change technologies and processes.



Large open pocket, end-loading washer/extractor



Dry cleaning machine

This page intentionally left blank.

Vehicle Washes

Water efficiency can be achieved in commercial vehicle washes (conveyor, in-bay automatic, and self-service) through a combination of both proper equipment and operational measures. New-vehicle dealers, fleet-vehicle operators, and rental agencies should also use these water-efficiency measures. In all new vehicle-wash businesses, except for self-service, reclaim systems can save 50 percent or more of potable water use. In vehicle washes on industrial sites with limited public access, wash systems can be designed to capture rainfall and use aerobic treatment systems, reducing the use of potable water for washing to less than 10 percent.

Standards and Practices

The important water efficiency measures pertinent to vehicle washing are:

- proper choice of cleaning equipment, settings, and orientation.
- spray nozzles on arches which produce a fan-shaped spray, oriented parallel to the spray bar.
- friction components for wash cycles in every vehicle wash.

Components such as mitters or brushes are more efficient than “touchless” washes, which use higher pressure and, therefore, usually discharge more water. **WASH**

Based upon the pump’s designed optimum operating pressure, nozzle flow-rate for self-service vehicle washes should be no more than 3 gallons per minute. **WASH**


Water Reuse and Recycling

Recycling wash water can replace 50 percent or more of the fresh-water use:

- gun-type and undercarriage nozzles should be used only with reclaimed water.
- provide reclaimed water to the pre-soak, undercarriage, and initial wash cycles, at a minimum.
- preferred reclaim systems will have sufficient filtration capacity to provide reuse water for all cycles except the final rinse.
- where reverse osmosis is used, the reject water should be re-used in the washing process or applied to landscape irrigation.

WASH

Industrial vehicle washes can be designed to reduce use of potable water to less than 10 percent, by capturing rainfall and using advanced treatment systems.



Typical water uses in vehicle washes



Vehicle washes offer excellent opportunities to employ recycled and on-site reclaimed water.

Water Treatment

Water softeners are often used to remove water hardness for washing. Softening recharge replaces calcium or magnesium in the water with a salt solution containing sodium or potassium. Softeners are recharged and flushed with water to make the brine solutions and to purge the softener of brine prior to being returned to service.

All softener systems should be equipped with controllers that activate based upon the volume of water treated. Alternatively, use controllers that actually measure the hardness. Prohibit timers for softener recharge systems. Where filtration systems are employed, require pressure gauges to determine when to backwash or change cartridges, and backwash based upon pressure differential. Evaluate opportunities to reuse backwash waste streams. Use water softeners and other treatment only when necessary. **TREAT**

Washes including a spot-free rinse option should use deionization equipment, rather than water-softening or reverse-osmosis systems. **WASH**

Plumbing

Use high-efficiency toilets requiring not more than 1.3 gallons per flush and urinals which flush with 1 gallon or less. Use no automatically timed flushing systems. Use self-closing faucets with flows of 0.5 gpm for hand washing. If available, and where codes and health departments permit, use non-potable water for flushing. **REST**

Floor Cleaning

Employ these floor-cleaning efficiency practices:

- use low-flow, high-pressure nozzles on hoses or water brooms for floor and mat washing where a flow of water is needed. **REST, FOOD, PROC**
- minimize the need to use a hose as a broom by installing drains close to areas where liquid discharges are expected. **PROC**



Other

For on-site towel washing, high-efficiency machines with a CEE rating of Tier 3, indicating a water factor of 4.5 gallons per cubic foot of washer capacity, should be used. **WASH, LAUND**

Install automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**

Install faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**

Other water-efficiency measures apply to customer convenience and structure plumbing.

Where irrigated landscaping or water features are present, refer to “**Water Features, Pools, and Landscapes.**”

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, install flow-detection meters on fire services to indicate unauthorized water flows. **REST**

For spot-free rinsing, vehicle washes should use deionization equipment.



This page intentionally left blank.

Beverage Manufacturers

The beverage industry uses a wide variety of processes to make and package such products as beer, milk, wine, soft drinks, and fruit juices. Water quality and purity are of primary concern, since water is usually a major component of the consumed products. Water is also used to clean and sanitize floors, processing equipment, containers, vessels, and the raw food products. Some older bottling plants use more water for cleaning than for product. With current technologies, one can design and build a facility that has a reduced requirement for water. **PROC**

Standards and Practices

Principles include the following:


- ◆ provide adequate metering, including submetering, at all major water-using areas and for process control.
- ◆ design the facility for ease of cleaning.
- ◆ take advantage of dry methods for cleanup and transport.
- ◆ use product and by-product recovery systems.
- ◆ consider all possible opportunities for water recovery and reuse and for alternative water supplies, such as filtration and membrane processes and capturing condensate drain water from air-conditioning and refrigeration systems. **ALT 4**
- ◆ design for minimal or no water use. **PROC**

Larger equipment that cannot be disassembled easily must be cleaned and sanitized in place. Use pigging as part of the clean-in-place system for process pipes. **PROC**

Water Treatment

Water is softened and mixed with biocides and soaps before it is sprayed onto conveyors, so cans and bottles can “slip” easily on the high-speed conveyor belts and not tip over. To minimize the use of and need for water-lubricated conveyor belts, ensure that the spray nozzles are properly sized, well-aligned, and equipped with automatic shutoffs. **PROC**

Beverages range from milk and fruit juice to wine and beer. Water quality is important, since water is often a component of the consumed product, in addition to its use in the manufacturing process.



Typical water uses in beverage manufacturing



Water Reuse and Recycling

Water is used as a heat-transfer agent in a variety of applications. This water remains relatively clean and is an excellent source of water for reuse. **PROC**

Heating Systems

Steam boilers and hot-water boilers provide heat and hot water for many purposes. Closed-loop systems return water and steam condensate to the boiler for reuse, saving energy and water. Open-loop systems expend the water or steam without return to the boiler. Several water-efficiency choices are available:

- ◆ steam boilers of 200 boiler horsepower (hp) or greater, equipped with conductivity controllers to regulate top blowdown.
- ◆ for closed-loop systems, condensate-return meters on steam boilers of 200 boiler hp or greater.
- ◆ closed-loop steam systems operating at twenty cycles of concentration or greater (5 percent or less of makeup water) where chemistry of the water allows.

Closed-loop systems save water and energy.

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, install flow-detection meters on fire services to indicate unauthorized water flows. **REST**



Bakery & Pastry Shops

Bakery shops not only bake bread and pastry products, but they are similar to restaurants, often serving a variety of sandwiches, beverages, and other foods. Water has many uses: as a product ingredient, to heat and cool products, and to clean and sanitize floors, processing equipment, containers, vessels, and the raw food products.

Standards and Practices

Principles for designing and building a facility that has a reduced requirement for water include:

- ◆ design the facility for ease of cleaning.
- ◆ provide adequate metering, including submetering at all major water using areas and for process control.
- ◆ consider all possible opportunities for water recovery and re-use or alternative water supplies, such as filtration and membrane processes and capturing condensate drain water from air-conditioning and refrigeration systems. **ALT**
- ◆ design for minimal or no water use.
- ◆ use product and by-product recovery systems. **PROC**

Kitchen Equipment

Select energy-efficient refrigerators and freezers that have adequate refrigerator space for thawing food and use air-cooling rather than recirculating cooling-water systems. **FOOD**

If combination ovens are used, select those that use no more than 15 gallons per hour and comply with the California energy rebate list prepared by Fisher-Nickel. **FOOD**

If steamers are used, select those that are either connectionless or boilerless and consume no more than three gallons of water per hour. **FOOD**

Dishwashing is a water-intensive process for cleaning and sanitizing.

- ◆ Use pre-rinse spray valves (1.5 gpm maximum) for dish rinsing. **FOOD**
- ◆ Install strainer (scraper) baskets instead of garbage disposals (grinder). If a water-using grinder

Many bakery and pastry shops now offer more than baked goods and are much like small restaurants with a variety of product offerings.



is selected, install a water-saver kit or choose a grinder that tailors the water use to the load. **FOOD**

- ◆ Avoid “dump and fill” dishwashing machines; use dishwashers meeting Energy Star efficiency standards. **FOOD**
- ◆ Install steam doors to reduce evaporation.

Ice Machines

Ice machines use water for ice and sometimes for cooling the compressor. Select:

- ◆ ice-making machines that are air-cooled, using remote heads to expel warm air outside the work space and customer areas. Air-cooled machines are preferred over cooling-tower loops.
- ◆ energy-efficient flake or nugget machines rather than cube-ice machines. If cube-ice machines are used, those that meet CEE Tier 2 efficiency standards are preferred. Tier 3 machines are even more efficient (CEE Commercial Kitchens). **FOOD**

Heating Systems

Steam boilers and hot-water boilers provide heat and hot water. Closed-loop systems return water and steam condensate to the boiler for reuse, saving both energy and water. Open-loop systems expend the water or steam without return to the boiler. Several water efficiency measures are available:

- ◆ reduce plumbing leaks due to repeated opening of water temperature- and pressure-relief valves (TPRVs).
- ◆ make discharge pipes easy to inspect for flow, and insert visible indicators of valve activation. **REST**

Water Reuse and Recycling

Water is used as a heat-transfer agent in a variety of applications. This water remains relatively clean and is an excellent source of water for reuse. **PROC**

Water Treatment

Measures to improve the efficiency of water treatment include:

- ◆ for all filtration processes, install pressure gauges to determine when to backwash or change cartridges, then backwash based upon pressure differential.
- ◆ for all ion-exchange and softening processes, set recharge cycles by volume of water treated or use conductivity controllers.
- ◆ avoid the use of timers for softener-recharge systems.
- ◆ use water treatment only if and when necessary. **TREAT**

Dishwashing is a water intensive practice, although it is necessary for cleaning and sanitizing. Run only full loads to conserve water and energy.



Plumbing

Use high-efficiency toilets requiring not more than 1.3 gallons per flush and urinals which flush with 1 gallon or less. Use no automatically timed flushing systems. Use self-closing faucets with flows of 0.5 gpm for hand washing. If available, and where codes and health departments permit, use non-potable water for flushing. **REST**

Floor Cleaning

Employ these floor-cleaning efficiency practices:

- ◆ low-flow, high-pressure nozzles on hoses or water brooms used for floor and mat washing where a flow of water is needed. **REST, FOOD, PROC**
- ◆ minimize the need to use a hose as a broom by installing drains close to areas where liquid discharges are expected. **PROC**

Other

Install automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**

Install faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, install flow-detection meters on fire services to indicate unauthorized water flows. **REST**



This page intentionally left blank.

Industrial Bakeries

Water quality is of primary concern in industrial bakery processes since bakery products are made for human consumption. Water is used to heat and cool products, to transport raw product, and to clean and sanitize: floors, processing equipment, containers, vessels, and raw food products.

Standards and Practices

With modern technologies, it is possible to design and build a facility that has a reduced requirement for water. **PROC**

- ◆ Provide adequate metering, submetering at all major water using areas, and for process control.
- ◆ Use product and by-product recovery systems.
- ◆ Consider all possible opportunities for water recovery and reuse, or alternative water supplies, such as filtration and membrane processes, capturing condensate drain water from air conditioning and refrigeration systems. **ALT**
- ◆ Design for minimal or no water use.
- ◆ Design the facility for ease of cleaning.
- ◆ Take advantage of dry methods for cleanup and transport.

PROC

If applicable, minimize the use of water on water-lubricated conveyor belts by ensuring that spray nozzles are properly sized, well-aligned, and equipped with automatic shutoffs. **PROC**

Larger equipment that cannot be disassembled easily must be cleaned in place and sanitized in place. Use pigging in the clean-in-place system for process pipes. **PROC**

Cooling Systems

Cooling towers remove heat generated in a manufacturing process or by air-conditioning or refrigeration equipment. Energy-efficient equipment may reduce such waste heat, which is usually removed by a central refrigeration system and compressor. The compressor may be air-cooled or connected with a circulating loop to a cooling tower or evaporative condenser. As warm water from the compressor trickles through the cooling tower, some water evaporates, cooling the remaining water, which returns to cool



To ensure a supply of high-quality water, consider all reasonable opportunities for water recovery and reuse, such as capturing condensate and using filtration and membrane processes.

Cleaning process pipes in-place requires use of a “pig” — a device that fits snugly inside a pipe and is sent through it to clean the inside.

the equipment. Measures to reduce water waste in cooling towers include:

- ◆ performing a life-cycle analysis, including all operating, capital, and personnel costs, to determine whether use of a cooling tower is more cost-effective than air cooling.
- ◆ equipping cooling towers with conductivity controllers, make-up and blowdown meters, and overflow alarms.
- ◆ operate towers at a minimum of five cycles of concentration in regions with high water quality (low TDS) for towers using potable water, depending upon the chemistry of the make-up water, including considerations for reclaimed water or on-site sources.
- ◆ avoiding once-through cooling with potable water. **FOOD**
- ◆ using high-efficiency drift eliminators that reduce drift loss to less than 0.002 percent of circulating water volume for cross-flow towers and 0.001 percent for counter-flow towers.
- ◆ evaluating the processes in the plant for maximum energy efficiency and waste-heat recovery, since a more efficient building will reject less heat to the cooling tower.
- ◆ providing adequate training to cooling-tower operators.

THERM

Heating Systems

Steam boilers and hot-water boilers provide heat and hot water for many purposes. Closed-loop systems return water and steam condensate to the boiler for reuse, saving energy and water. Open-loop systems expend the water or steam without return to the boiler.

Several water-efficiency choices are available:

- ◆ steam boilers of 200 boiler horsepower (hp) or greater, equipped with conductivity controllers to regulate top blowdown.
- ◆ for closed-loop systems, condensate-return meters on steam boilers of 200 boiler hp or greater.
- ◆ closed-loop steam systems operating at twenty cycles of concentration or greater (5 percent or less of makeup water) where chemistry of the water allows.
- ◆ steam-distribution lines and equipment with steam traps meeting all codes.
- ◆ make-up meters on feed-water lines:
 - » to steam boilers and water boilers of more than 100,000 Btus per hour.
 - » to closed-loop hot-water systems for heating.

- ◆ boiler-temperature and make-up meters that are clearly visible to operators.
- ◆ discharge pipes that are easy to inspect for flow and visible indicators that will indicate whether the valve has activated, thereby reducing plumbing leaks due to repeated openings of water-temperature- and pressure-relief valves (TPRVs).

REST, THERM

Plumbing

Use high-efficiency toilets requiring no more than 1.3 gallons per flush and urinals which flush with 1 gallon or less. Avoid automatically timed flushing systems. Use self-closing faucets with flows of 0.5 gpm for hand washing. If available, and if codes and health departments permit, flush with non-potable water. **REST**

Floor Cleaning Equipment

Employ these floor-cleaning efficiency practices:

- ◆ use low-flow, high-pressure nozzles on hoses or water brooms for floor and mat washing where a flow of water is needed. **REST, FOOD, PROC**
- ◆ minimize the need to use a hose as a broom by installing drains close to areas where liquid discharges are expected. **PROC**

Reuse and Recycling

Water is used for a variety of applications as a heat-transfer agent. This water remains relatively clean and is an excellent source of water for reuse. **PROC**

Water Treatment

Measures to improve the efficiency of water treatment include:

- ◆ for all filtration processes, installing pressure gauges to determine when to backwash or change cartridges, followed by backwash based upon pressure differential.
- ◆ for all ion-exchange and softening processes, setting recharge cycles by volume of water treated or using conductivity controllers.
- ◆ avoiding the use of timers for softener-recharge systems.
- ◆ using water treatment only when necessary.
- ◆ use a reverse osmosis and nanofiltration systems with the lowest reject rate for its size.
- ◆ choose distillation equipment that recovers at least 85 percent of the feed water. **TREAT**



<http://www.freefoto.com/browse/09-05-0?ffid=09-05-0>

Industrial bakeries should use product and byproduct recovery systems.

Other

Install automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**

Install faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, install flow-detection meters on fire services to indicate unauthorized water flows. **REST**

Auto Service & Repair Shops

Automotive service and repair is one of the most common types of commercial enterprises in any city. Establishments include: service stations, oil change/lubrication, body repair, tune-up shops, full-service repair shops, fleet maintenance, and tire services. The design of a water-efficient shop depends to some extent upon the type of service offered. New air-quality regulations have also meant that shops have switched from solvent-based parts- and brake-cleaning systems to aqueous-based systems.

Standards and Practices

Operational measures to be recommended at the time of permitting to reduce water use for cleanup include the following:

- ◆ use mopping or dry cleaning where possible.
- ◆ use pressure-washing equipment instead of hoses.
- ◆ place drip pans under vehicles.
- ◆ provide proper facilities for the capture, storage, and recycling of spent fluids, oils, and fuels, including antifreeze and radiator flush water.
- ◆ provide secondary containers to catch drips, leaks, and spills from stored liquids and solvents.

Floor Cleaning

Floor-cleaning with dry methods, preventing spills and leaks from entering the wastewater discharge system, and proper design of oil separators have as much to do with pollution prevention as they do with water conservation. **PROC** To achieve this:


- ◆ install recirculating filtration equipment to minimize the need to dump water from aqueous parts- and brake-cleaning equipment.
- ◆ seal shop floors to ensure easy cleanup.
- ◆ properly identify all drains.
- ◆ if hoses are used, install automatic-shutoff and solenoid valves on all hoses and water-using equipment, where applicable.

Water Treatment

Measures to improve the efficiency of water treatment include:

Shops have switched from solvent-based to water-based brake- and parts-cleaning systems to comply with new air-quality regulations.





- for all filtration processes, installing pressure gauges to determine when to backwash or change cartridges, followed by backwash based upon pressure differential.
- for all ion-exchange and softening processes, setting recharge cycles by volume of water treated or using conductivity controllers.
- avoiding the use of timers for softener-recharge systems.
- using water treatment only when necessary. **TREAT**

Always seal shop floors to facilitate easy clean-up, and clearly identify all drains.

Plumbing

Use high-efficiency toilets requiring no more than 1.3 gallons per flush and urinals which flush with 1 gallon or less. Avoid automatically timed flushing systems. Use self-closing faucets with flows of 0.5 gpm for hand washing. If available, and if codes and health departments permit, flush with non-potable water. **REST**

Other

Install automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**

Install faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**

Water-efficiency measures for vehicle cleaning are described in the summary sheet for “**Vehicle Washes.**”

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, install flow-detection meters on fire services to indicate unauthorized water flows. **REST**



Fuel Service Stations & Convenience Stores

Gasoline and diesel fuel stations often sell snacks, fast food, and vehicle supplies. Restrooms and are often available to customers, and truck stops often include showers. These stations are among the most common types of commercial enterprises.

Plumbing

Restrooms are one of the frequently used facilities that consume water at these locations. Use high-efficiency toilets requiring no more than 1.3 gallons per flush and urinals which flush with 1 gallon or less. Avoid automatically timed flushing systems. Use self-closing faucets with flows of 0.5 gpm for hand washing. If available, and if codes and health departments permit, flush with non-potable water. **REST**

For facilities with showers:

- ◆ use shower heads that allow flow of not more than 2.0 gallons per minute.
- ◆ install only one shower head per personal shower stall.
- ◆ install individual valves to control each shower head. **REST**

Spaces where regular water use may result in spills or where floors may be washed frequently often have floor drains. Plumbing codes require traps to prevent gases and odors from seeping from sanitary sewers into rooms through the drains. The gas is blocked by water trapped below the drain in an “S” shaped pipe called a “P trap.”

To sustain water in the trap in less frequently used spaces, additional water must be added with a device called a trap primer. A trap primer is a valve or other connection from a water source that allows a small amount of water to flow through pipes to recharge traps of one or more drains.

Avoid continuous flow to trap primers. Instead, install pressure-activated or electronic trap primers, each serving several drains.

REST



Restrooms consume a large portion of the water used in fuel service stations and convenience stores. Some truck stops even offer showers for their customers' use.



Kitchen Equipment

In food-service preparation and cleanup areas, employ the following principles:

- ◆ variable-flow aerators on food-service faucets should have a flow not exceeding 2.2 gpm. **REST**
- ◆ hand-washing faucets should be self-closing and flow at 0.5 gpm. **REST**
- ◆ dipper wells should have in-line restrictors that reduce flow to under 0.3 gallons per minute. **FOOD**

Select energy-efficient refrigerators and freezers that:

- ◆ have adequate refrigerator space for thawing food.
- ◆ use air-cooling rather than recirculating cooling-water systems. **FOOD**

Dishwashing is a water intensive process for cleaning and sanitizing.

- ◆ Use pre-rinse spray valves (1.5 gpm maximum) for dish rinsing.
- ◆ Strainer (scraper) baskets are preferred to garbage disposals (grinders). If a water-using grinder is selected, install a water-saver kit or choose a grinder that tailors the water use to the load.
- ◆ Avoid “dump and fill” dishwashing machines. Use dishwashers meeting Energy Star efficiency standards. **FOOD**

Ice Machines

Ice machines use water for making ice and sometimes for cooling the compressor. Select:

- ◆ ice-making machines that are air-cooled, using remote heads to expel warm air outside the work space and customer areas. Air-cooled machines are preferred over cooling-tower loops.
- ◆ energy-efficient flake or nugget machines rather than cube-ice machines. If cube-ice machines are used, those that meet CEE Tier 2 efficiency standards are preferred. Tier 3 machines are even more efficient (CEE Commercial Kitchens). **FOOD**

Water Treatment

Measures to improve the efficiency of water treatment include:

- ◆ for all filtration processes, installing pressure gauges to determine when to backwash or change cartridges, followed by backwash based upon pressure differential.
- ◆ for all ion-exchange and softening processes, setting recharge cycles by volume of water treated or using conductivity controllers.

- ◆ avoiding the use of timers for softener-recharge systems.
- ◆ using water treatment only when necessary.
- ◆ use a reverse osmosis and nanofiltration systems with the lowest reject rate for its size.
- ◆ choose distillation equipment that recovers at least 85 percent of the feed water. **TREAT**



Floor Cleaning

Employ these floor-cleaning efficiency practices:

- ◆ use low-flow, high-pressure nozzles on hoses or water brooms used for floor and mat washing where a flow of water is needed. **REST, FOOD, PROC**
- ◆ minimize the need to use a hose as a broom by installing drains close to areas where liquid discharges are expected. **PROC**

Other

Make discharge pipes easy to inspect for flow and insert visible indicators that will show if the water pressure relief or temperature relief valves have activated. **REST**

Install automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**

Install faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**

TIP: Conspicuously mark fire protection plumbing so no connections will be made except for fire protection. Additionally, install flow-detection meters on fire services to indicate unauthorized water flows. **REST**

Variable-flow aerators on faucets help conserve water in kitchen operations.

This page intentionally left blank.

Commercial Printers

Commercial printing is a major business. Printing establishments include photocopy shops, offset printers, large newspapers, and book publishers. All of them potentially use photographic techniques that once used large amounts of water.

Standards and Practices

Basic water-efficiency measures include the following:

- design the layout of the equipment for easy access.
- provide nondrying aerosol sprays to keep ink fountains from drying.
- ensure that the printing press has proper controls, such as automatic ink levelers. **PROC**

Some photo water-efficiency measures take advantage of new technology. Photo processing using self-contained “mini lab” units requires no plumbing or washing. Digital technology in large print shops now allows printers to process images directly from computer to plate. **PHOTO**

Cooling and Heating Systems

Heat generated in a manufacturing process is removed by use of cooling towers or by air-conditioning or refrigeration equipment. Energy-efficient equipment may reduce such waste heat, which is usually removed by a central refrigeration system and compressor. The compressor may be air-cooled or connected with a circulating loop to a cooling tower or evaporative condenser.

As warm water from the compressor trickles through the cooling tower, some water evaporates, cooling the remaining water, which returns to cool the equipment. Measures to reduce water waste in cooling towers include:

- performing a life-cycle analysis, including all operating, capital, and personnel costs, to determine whether use of a cooling tower is more cost-effective than air cooling.
- equipping cooling towers with conductivity controllers, make-up and blowdown meters, and overflow alarms.
- operate towers at a minimum of five cycles of concentration in regions with high water quality (low TDS)

Digital and photo processing technologies have advanced so much that printers can now process images directly from computer to plate.



Nondrying aerosol sprays and automatic ink levelers are among the advances employed by the printing industry.

for towers using potable water, depending upon the chemistry of the make-up water, including considerations for reclaimed water or on-site sources.

- ◆ avoiding once-through cooling with potable water. **FOOD**
- ◆ using high-efficiency drift eliminators that reduce drift loss to less than 0.002 percent of circulating water volume for cross-flow towers and 0.001 percent for counter-flow towers.
- ◆ evaluating the processes in the plant for maximum energy efficiency and waste-heat recovery, since a more efficient building will reject less heat to the cooling tower.
- ◆ providing adequate training to cooling-tower operators.

THERM

Additional water-efficiency measures include the following:

- ◆ operate closed-loop steam systems at twenty cycles of concentration or greater (5 percent or less of make-up water) where water chemistry allows.
- ◆ equip steam distribution lines and equipment with steam traps meeting all codes.
- ◆ install make-up meters on feed-water lines to:
 - » steam boilers and water boilers of more than 100,000 Btus per hour.
 - » closed-loop hot-water systems for heating.
- ◆ situate boiler temperature and make-up meters to be clearly visible to operators.
- ◆ reduce plumbing leaks due to repeated opening of water-temperature and pressure-relief valves (TPRVs).
- ◆ make discharge pipes easy to inspect for flow and there should be visible indicators of any valve activation. **REST, THERM**

Water Reuse and Recycling

Consider all possible opportunities for water recovery and reuse or alternative water supplies, such as filtration and membrane processes and capturing condensate drain water from air-conditioning systems. **PROC, ALT**

Water Treatment

In some cases water treatment may be used to ensure an attractive quality for the finished images. Measures to improve water efficiency in water treatment include:

- ◆ for all filtration processes, install pressure gauges to determine when to backwash or change cartridges, followed by backwash based upon pressure differential.

- ◆ for all ion-exchange and softening processes, set recharge cycles by volume of water treated or by using conductivity controllers.
- ◆ avoid use of timers for softener-recharge systems.
- ◆ use water treatment only when necessary.
- ◆ use reverse osmosis and nanofiltration systems with the lowest reject rate for their size.
- ◆ choose distillation equipment that recovers at least 85 percent of the feed water. **TREAT**



Other

Install automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**

Install faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, install flow-detection meters on fire services to indicate unauthorized water flows. **REST**

Water treatment may be used to ensure an attractive quality for the finished images.

This page intentionally left blank.

Metal Finishers

The metal-finishing industry includes electroplating, solution plating, and anodizing, but also printed circuit (wire) board and plastic plating. Chrome, zinc, copper, tin, nickel, gold, and silver are among the more common metals plated onto objects. In some processes objects are plated with two layers of metals, such as an under layer of copper followed by chrome. One common process in this industry is for the parts to be plated to be moved sequentially from a treatment tank to a rinse or wash tank, then to another treatment tank and to another rinse tank, until the desired number of plating steps has been accomplished. Water is used for the following process purposes: chemical and plating solution make-up, rinsing, fume-hood scrubbing, and equipment cleaning.

Special Purposes

In the metal-plating industry, water-savings measures often have multiple benefits, including reducing water and wastewater costs, reducing pretreatment costs, reducing energy costs, reducing chemical cost, increasing chemical- and metals-recovery rates, and reducing pollution emissions.

Effective water-efficiency measures include the following:

- ◆ meter make-up water in all new facilities.
- ◆ plumb facilities for countercurrent rinsing.
- ◆ use conductivity controllers for rinse tanks.
- ◆ install automatic shutoff valves on all hoses.
- ◆ recirculate water and/or use waste streams as make-up water for fume scrubbers.
- ◆ employ good tank design.
- ◆ mix or air-agitate tank contents.
- ◆ use multiple drag-out reduction methods.
- ◆ use filtration and water-treatment equipment where applicable.
- ◆ employ reactive rinsing.

Cooling Systems

Use energy-efficient equipment to reduce waste heat, which might otherwise require larger water technologies such as cooling towers.

Air cooling is more water efficient than recirculating cooling-water systems. Avoid once-through cooling with potable water. **FOOD**

Water saving measures can positively influence wastewater, pretreatment, energy, and chemicals costs, all the while increasing chemicals and metals recovery rates and reducing pollution emissions.



Heating Systems

Steam boilers and hot-water boilers provide heat and hot water for many purposes. Closed-loop systems return water and steam condensate to the boiler for reuse, saving energy and water. Open-loop systems expend the water or steam without return to the boiler.

Several water-efficiency choices are available:

- ◆ steam boilers of 200 boiler horsepower (hp) or greater, equipped with conductivity controllers to regulate top blowdown.
- ◆ for closed-loop systems, condensate-return meters on steam boilers of 200 boiler hp or greater.
- ◆ closed-loop steam systems operating at twenty cycles of concentration or greater (5 percent or less of makeup water) where chemistry of the water allows.
- ◆ steam-distribution lines and equipment with steam traps meeting all codes.
- ◆ make-up meters on feed-water lines:
 - » to steam boilers and water boilers of more than 100,000 Btus per hour.
 - » to closed-loop hot-water systems for heating.
- ◆ boiler-temperature and make-up meters that are clearly visible to operators.
- ◆ discharge pipes that are easy to inspect for flow and visible indicators that will indicate whether the valve has activated, thereby reducing plumbing leaks due to repeated openings of water-temperature- and pressure-relief valves (TPRVs). **REST, THERM**

Recirculate water and use waste streams as make-up water for fume scrubbers.



Water Treatment

Use water treatment only if and when necessary. **TREAT**

Measures to improve water efficiency in water treatment include:

- ◆ for all filtration processes, installing pressure gauges to determine when to backwash or change cartridges, followed by backwash based upon pressure differential.
- ◆ for all ion-exchange and softening processes, setting recharge cycles by volume of water treated or using conductivity controllers.
- ◆ avoiding the use of timers for softener-recharge systems.
- ◆ using water treatment only when necessary.
- ◆ use a reverse osmosis and nanofiltration systems with the lowest reject rate for its size.

- ◆ choose distillation equipment that recovers at least 85 percent of the feed water. **TREAT**

Plumbing

Use high-efficiency toilets requiring no more than 1.3 gallons per flush and urinals which flush with 1 gallon or less. Avoid automatically timed flushing systems. Use self-closing faucets with flows of 0.5 gpm for hand washing. If available, and if codes and health departments permit, flush with non-potable water. **REST**

Floor Cleaning

Employ these floor-cleaning efficiency practices:

- ◆ use low-flow, high-pressure nozzles on hoses or water brooms for floor and mat washing where a flow of water is needed. **REST, FOOD, PROC**
- ◆ minimize the need to use a hose as a broom by installing drains close to areas where liquid discharges are expected. **PROC**

Other

Install automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**

Install faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST**

If water features or irrigated landscaping is on the site, refer to the summary: “**Water Features, Pools, and Landscapes.**”

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, install flow-detection meters on fire services to indicate unauthorized water flows. **REST**



Commonly, parts to be plated are moved sequentially from one tank to another through a series of processes — treating, washing, rinsing — with multiple iterations.

This page intentionally left blank.

Paper Manufacturers

Paper manufacturing ranges from making paper to manufacturing converted paper products, such as paper containers, cups, boxes, bags, coated paper, envelopes, and stationery products. Producing paper from pulpwood and other fiber sources is highly water- and energy-intensive. Recycling paper and cardboard products can cut this energy and water use in half.

Special Purposes

Water efficiency can be achieved by minimizing paper and other product wastes. Collect the waste that does occur to use as fiber sources in recycled products (non-post-consumer recycled content).

PROC

Before applying aqueous cleaning techniques, scrape equipment and vessels to remove as much waste as possible. **PROC**

Refer to the “**Commercial Printers**” summary for more information on the printing aspects of this industry.

Cooling and Heating Systems

Energy-efficient equipment reduces waste heat, which may in turn reduce the demand for larger water technologies such as cooling towers. **PROC**

Air cooling is more water efficient than recirculating cooling-water systems. If water is used for cooling, at a minimum use a recirculating system. **FOOD**

Additional water-efficiency measures include the following:

- consider all possible opportunities for water recovery and reuse or alternative water supplies, such as filtration and membrane processes and capturing condensate drain water from air-conditioning systems. **PROC, ALT**
- operate closed-loop steam systems at twenty cycles of concentration or greater (5 percent or less of make-up water) where water chemistry allows.

Producing paper from pulpwood and other “first-generation” sources is both water- and energy-intensive.



- ◆ equip steam distribution lines and equipment with steam traps meeting all codes.
- ◆ install make-up meters on feed-water lines to:
 - » steam boilers and water boilers of more than 100,000 Btus per hour.
 - » closed-loop hot-water systems for heating.
- ◆ situate boiler temperature and make-up meters to be clearly visible to operators.
- ◆ reduce plumbing leaks due to repeated opening of water-temperature and pressure-relief valves (TPRVs).
- ◆ make discharge pipes easy to inspect for flow and ensure there are visible indicators of any valve activation. **REST, THERM**

Water Treatment

Use water treatment only if and when necessary. **TREAT**

Measures to improve water efficiency in water treatment include:

- ◆ for all filtration processes, installing pressure gauges to determine when to backwash or change cartridges, followed by backwash based upon pressure differential.
- ◆ for all ion-exchange and softening processes, setting recharge cycles by volume of water treated or using conductivity controllers.
- ◆ avoiding the use of timers for softener-recharge systems.
- ◆ using water treatment only when necessary.
- ◆ use a reverse osmosis and nanofiltration systems with the lowest reject rate for its size.
- ◆ choose distillation equipment that recovers at least 85 percent of the feed water. **TREAT**

Plumbing

Use high-efficiency toilets requiring no more than 1.3 gallons per flush and urinals which flush with 1 gallon or less. Avoid automatically timed flushing systems. Use self-closing faucets with flows of 0.5 gpm for hand washing. If available, and if codes and health departments permit, flush with non-potable water. **REST**

Floor Cleaning

Employ these floor-cleaning efficiency practices:

- ◆ use low-flow, high-pressure nozzles on hoses or water brooms for floor and mat washing where a flow of water is needed. **REST, FOOD, PROC**

Choosing energy-efficient equipment saves on recurring energy costs, but, as well, can obviate the need for larger water-consuming technologies such as cooling towers.

- ◆ minimize the need to use a hose as a broom by installing drains close to areas where liquid discharges are expected. **PROC**

Submetering

Meter major water-using systems and building areas separately. **PROC, METER**

Other

Install automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**

Install faucets on set tubs and janitorial sinks with flows not to exceed 2.2 gpm. **REST** If water features or irrigated landscaping are used on a site, refer to the summary on “**Water Features, Pools, and Landscapes.**”

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, install flow-detection meters on fire services to indicate unauthorized water flows. **REST**

Reclaiming pre-consumer waste materials and recycling paper and cardboard products can cut energy and water use in half.

This page intentionally left blank.

Water Features, Pools, & Landscapes

These general categories of water use are associated with many commercial establishments and some industrial sites. Not all sites have all these water uses. Careful consideration of actual need for such features should be given prior to design and construction, and the options requiring the least water should be carefully examined.

Standards and Practices

If water features, pools, or irrigated landscapes are included in a plan, consider the following elements:

Meter landscape areas, major water-using systems, and building areas separately. **PROC, METER** Use water treatment only if and when necessary. **TREAT**

Landscaping Water-Efficiency Measures — In many locations, landscape irrigation accounts for more than 50 percent of local water demands. Water-efficient landscape practices are increasingly important to free up water supplies for basic indoor water uses and businesses. Obtaining landscape water-use efficiency over the long term requires proper planning (design) for various landscape elements. **LAND**

Functionality

Address how landscape is going to be used: **LAND**

- ◆ play, sports field (is artificial turf appropriate?)
- ◆ park
- ◆ median strip
- ◆ availability and appropriateness of reclaimed water or alternative supplies. **ALT**

Soil Preparation

Conduct a soil analysis. Amend the soil to a depth of at least six inches with organic material to provide needed plant nutrients. **LAND**

Minimize runoff through use of pervious material, swales, terracing, rain gardens, and berms, as appropriate. **LAND**

Choose water feature and landscape options that require the least water. Apply the right amount of water to the right place at the right time.





Emphasize use of native plant materials in all landscapes, and ensure others are well adapted to local climatic conditions. Carefully avoid any and all invasive varieties. Ensure that maintenance personnel understand and can comply with these standards.



Plant Selection and Groupings

- ◆ Use plants appropriate to the climate of the region.
- ◆ Group plants into hydrozones (irrigated areas reflecting plant water requirements).
- ◆ Use water-efficient varieties of turf.
- ◆ Avoid use of invasive species. **LAND**

Irrigation Systems

Irrigation systems replace water in the soil that is used by shrubs, trees, and grass, where natural moisture is inadequate for the intended landscape. The primary guideline for landscape irrigation design is to avoid over watering by applying the **right** amount of water, to the **right** place, at the **right** time. **LAND**

More specific irrigation design and construction water-efficiency measures follow:

- ◆ install separate irrigation meters for landscaped areas.
- ◆ install irrigation equipment that meets the Irrigation Association design guidelines for maximum irrigation operational uniformity.
- ◆ for all new nonresidential landscapes not required to have a separate water-service meter, install a private irrigation sub-meter and backflow prevention valve between the point of connection on the domestic water service and the first irrigation valve.
- ◆ design for potential installation of irrigation hardware approved for reclaimed water, should it become available and if appropriate.
- ◆ design all irrigation systems to avoid runoff, overspray, low head drainage, and similar conditions.
- ◆ install a non-irrigated buffer along side areas where water flows off-site onto adjacent property, non-irrigated areas, walks, roadways, or structures.
- ◆ employ drip or low-volume irrigation equipment in buffers and medians strips and other areas where it is determined that overhead spray irrigation would result in waste of water due to excessive runoff or overspray.
- ◆ follow proper hydrozoning principles when designing irrigation systems to separately water turf and bedded areas.
- ◆ install a pressure regulator if water-supply pressure exceeds 80 psi.
- ◆ match precipitation rates on sprinkler heads within a hydrozone.
- ◆ install anti-drain check valves as needed to minimize or prevent low head drainage.

- ◆ use Irrigation Association approved “smart controllers” — with dual or multiple programming capability, multiple start times, a percent switch, etc. — along with rain sensors, or use weather-based (ET) controllers.

Water losses occur through evaporation, splash out, backwashing the filter, and leaks.

Three elements govern good practice:


- ◆ design of the mechanical equipment to filter, clean, and operate the pool.
- ◆ design of the pool to minimize water loss.
- ◆ evaluating alternatives that use less water. **POOL**

Specific water efficiency measures for water features and pools include:

- ◆ equip all pools, spas, and fountains with recirculating filtration equipment.
- ◆ design ground pools with splash troughs around the perimeter that drain back into the pool.
- ◆ install water meters on the make-up line. Monitor water use for abnormal flow increases that may indicate leaks that should be identified and repaired.
- ◆ use coated media filters where cost effective.
- ◆ use cartridge filters for smaller spas where the cost of the filters and cleaning make them economically feasible.
- ◆ for all filtration processes, install pressure gauges to determine when to backwash or change cartridges, then backwash based upon pressure differential. **TREAT**
- ◆ use water treatment only when necessary. **TREAT**
- ◆ reuse backwash water for irrigation or re-treat the water and reuse it in the pool.
- ◆ consider alternatives to pools, such as shallow spray “scapes.”
- ◆ install pool covers to reduce evaporation. Retracting mechanisms promote regular use of the covers.
- ◆ use shrubs or fences to shade the pool and block winds that increase evaporation. **POOL**

Install automatic-shutoff and solenoid valves on all hoses and water-using equipment. **PROC**

TIP: Conspicuously mark fire-protection plumbing so no connections will be made except for fire protection. Additionally, install flow-detection meters on fire services to indicate unauthorized water flows. **REST**



Design any pool or water feature to minimize water loss from evaporation, splash out, filter backwashing, or leaks.

This page intentionally left blank.

Water-Using Technologies

This page intentionally left blank.

Alternate On-Site Water Sources

Many large commercial and industrial facilities can use water that is less than-potable quality for processes. There are a number of opportunities for various sizes and types of businesses to develop alternate on-site water sources. Some processes, however, require very high quality source water, so some types of reuse water require additional treatment to remove contaminants or constituents. Even typical disinfection by-products found in potable water must often be removed by specialized filtration, so such sophisticated processes can as readily begin with non-potable source water.

Alternative sources of water, which can be found on-site and used in these processes, may include:

- rainwater and stormwater
- air-conditioner condensate
- filter and membrane reject water
- foundation drain water
- cooling-tower blowdown
- on-site treated gray water and wastewater

Potential uses of alternate on-site sources of water include:

- irrigation
- cooling-tower makeup
- toilet and urinal flushing
- makeup for ornamental ponds, pools, or fountains
- swimming pools
- laundries
- processes
- any other use not requiring potable water

The use of treated effluent or reuse water provided by a publicly-owned water-treatment facility is not addressed in this section.

The initial step in determining the potential for alternate water sources is to identify the requirements — including water quality — that non-potable water can satisfy. After verifying that some demands can be met by non-potable water, determine the volume and quality requirements for the potential use. Each section below provides criteria for evaluating a potential water supply and includes basic considerations for system design, although, due to the site-specific nature of both non-potable water demand and potential supply, these are necessarily broad. The final section discusses the potential and design considerations for conjunctive use.

Source design and evaluation considerations include:

Potable water from a municipal water supply is often not necessary for commercial and industrial facilities. Either they require water of lesser quality or their processes require water that must be of much higher quality.

- determining volume and quality of the available on-site source
- identifying possible uses
- matching water quality to type of use
- deciding the type of treatment, if needed
- considering other basic factors for system design

Due to the unique circumstances of site size and orientation, air-conditioning loads, impervious cover, and water-quality constraints of the proposed end use *versus* the source water, cost-effectiveness evaluations are unique to each proposed business or industrial process. As a result, a number of techniques require a feasibility study at the proposed site to determine cost implications and payback period.

Rainwater Harvesting

Rainwater falls on large and small facilities alike. However, facilities with large areas of impervious cover can capture runoff and use the water for various non-potable purposes with little treatment. This section deals with methods available to facilities that capture water from their roofs. Those that capture water from paved surfaces are dealt with in the “Stormwater” section. Harvested rainwater can also be combined with air-conditioner condensate, the next option.

The type of roof surface impacts the quality of the rainwater runoff. For the highest quality rain water, especially if the water is to be used for drinking purposes or in-building uses such as flushing toilets and urinals, harvesting should employ smooth metal roofs and non-toxic, non-leaching surface finishes. Gutter design should employ at least a 1 percent slope and route water to a central collection point for transfer to a cistern or storage tank. The system will need a “roofwasher” or “first-flush diverter” to minimize the debris and detritus from the roof surface that enters the cistern.

For rainwater destined for landscape watering, consideration should be given to diverting water directly into landscaped areas, with swales and berms to capture and direct the flow. Care must be taken in designing such landscape rainwater harvesting to avoid long-term pooling of water and creation of potential insect vectors. Costs are considerably lower for systems which do not include tanks or cisterns, and slowing the water down to allow it to percolate into the landscape has stormwater runoff reduction benefits as well.

Approximately 0.62 gallons of water can be collected per square foot of collection surface per inch of rainfall. In practice, however, most installers assume an efficiency of 80 percent. Some rainwater is lost to first flush, evaporation from the roof surface, or splash-out from the gutters. Rough collection surfaces are less efficient at conveying water, and water captured in pore spaces is lost to evaporation.

The inability of the system to capture all water during heavy storms also affects practicable efficiency. For instance, spillage may occur if the flow-through capacity of a filter-type roofwasher is exceeded, and overflow rainwater will be lost after storage tanks are full.

The use of rainwater collection systems, also referred to as cisterns, is most practical in regions with periodic precipitation throughout a plant’s growing season. For example, in California, since most regions don’t receive precipitation during the summer, early fall, and late spring, cisterns are far less practical than in other parts of the country, because very large storage capacities are needed to capture enough water to use at any length into the irrigation season. Stated another way, the more frequent the precipitation, the smaller the needed storage facility and the less the capital costs.

Calculations

Annual production potential:

$$\text{gallons} = \text{roof area (sq. ft.)} \times \text{annual precipitation (in.)} \times (0.62 \times 0.8)$$

Required annual storage capacity for the planned landscape should be determined as follows:

- Calculate the monthly water budget for the planned landscape using the water budget calculations in the section, “Landscape Irrigation Efficiency.”
- Estimate the monthly average rainfall quantities that could be harvested, based upon roof area and rainfall for the location.
- Estimate the amount of rainwater storage that would be cost-effective to construct, based upon monthly inflows from rainfall and outflows based upon the landscape water budget.

Recommendations

Proven Practices for Superior Performance

- Plumb gutter systems to facilitate rainwater catchment at commercial facilities.

Additional Practices That Achieve Significant Savings

- Have new commercial developments with more than 20,000 square feet of roof area to provide a preliminary feasibility study, including cost analysis, to determine whether rainwater harvesting is viable at the site.

Stormwater

Stormwater capture and reuse offers many unique opportunities and should be examined when stormwater systems are being designed. All new properties are now required to integrate stormwater management for water-quality purposes into the design (USEPA). The section, “Landscape Irrigation Efficiency,” discusses this topic in detail. Stormwater can be a valuable source for landscape irrigation, but only if it can be captured and held. The overall concept is to keep the rain on the site where it falls to the maximum extent possible. The water captured and held can displace part or all of the potable water otherwise used for irrigation and can optimize groundwater infiltration, water quality, and slow-release augmentation of local streams.

There are three ways this can occur:

- storage in the soil profile
- capture in on-site features, such as berms, swales, rain gardens, or terraces
- capture in a detention structure, such as a pond, from which it can be pumped back to the landscape

The first two rainwater-harvesting methods offer capture and reuse in relationship with stormwater control systems. Therefore, these often least-costly methods of harvesting rainwater also maximize the potential for stormwater to infiltrate groundwater resources. The section on “Landscape Irrigation Efficiency” includes design considerations. The newer Best Management Practices (BMPs) for stormwater control also enhance the ability to use stormwater as a resource for the landscape, even in more arid climates.

Recommendations

Proven Practices for Superior Performance

- Include capture in on-site features, such as berms, swales, rain gardens, or terraces, and the use of soil as a water-storage medium jointly in the design of landscape and stormwater facilities.

- Require stormwater ponds to be established or enlarged to accommodate long-term storage for landscape irrigation and other uses.

Additional Practices That Achieve Significant Savings

- Examine the potential of captured and stored stormwater along with other on-site water sources.

Air-conditioner Condensate

Require plumbing of heating, ventilation, and air-conditioning (HVAC) systems such that commercial and other types of facilities can collect air-conditioner condensate. Clarify in local ordinances the specific plumbing uses of alternative sources of water and their relationships to the potable-water system. This can be combined with previously described options for rainwater harvesting.

Condensate-recovery water can be used as make-up water for cooling towers. Due to its high water quality, it increases the cycles of concentration achievable in cooling towers. Condensate can also be used for irrigation and other non-potable uses. In the past, regulations have required that condensate be plumbed to the sanitary sewer. If it is used for landscape irrigation, provisions may have to be made to divert water collected during coil cleaning to the sewer, if copper concentrations would be of concern.

Since air-conditioning condensate production depends upon cooling load, relative humidity, and make-up-air volumes, someone familiar with psychometric relationships and air-conditioner system design must carefully calculate the amount of condensate produced.

Examples combining harvested rainwater and air-conditioner condensate include:

- The University of Texas, where combined sources provide an estimated average of 110,000 gallons of water a day, of which air-conditioner condensate makes up as much as half
- The Austin Resource Center for the Homeless (ARCH), where toilet flushing and landscape irrigation use rainwater and air-conditioner condensate.

Recommendations

Proven Practices for Superior Performance

- Change regulations that require condensate to be discharged into a sewer to allow for other alternative uses.
- Commercial sites with more than 100-tons of air-conditioning must examine the feasibility of diverting all condensate drain water to a common point where it could easily be captured.

Filter and Membrane Reject-Water Recovery

Require plumbing of large and very-large filter and membrane systems to recover water that can then be used for landscape irrigation and other purposes. The product stream of membrane filters is water destined for the filtered end use and a reject stream traditionally routed to the sanitary-sewer system. However, other than elevated TDS, this water is often usable for other on-site purposes. When used in landscape irrigation, proper selection of landscape materials with high salinity tolerance is necessary. In specific circumstances, filter reject water may be used in other processes within a plant. Refer to sections on “Pools, Spas, and Fountains” and “Landscape Irrigation Efficiency” for additional information.

Examples of the use of filter-backwash and membrane reject water include:

- Swimming-pool backwash water at several City pools in Austin, Texas, is used to irrigate parkland.

- RO reject water, combined with water from a stormwater pond, is used for landscape irrigation at a major microelectronics manufacturing plant in Austin, Texas.
- Many industries use RO-reject water for cooling-tower make-up.

Recommendations

Proven Practices for Superior Performance

- New projects that employ filtration and membrane processes must provide a feasibility summary study of how these sources might be employed.

Foundation Drain Water

Foundation drain water, another source on large commercial campuses, is captured to preserve foundation integrity. It is typically routed through French drains to a common sump, where it can be gathered and pumped to replace potable water for uses such as landscape irrigation.

The purpose of a foundation drain is to remove water that could potentially harm the foundation and funnel it, by gravity flow, away from the building to a low spot in the landscape. A traditional foundation-drain system does not concern itself with the water after it leaves the drain outlet. Depending upon the location, this can involve very large quantities of water. Proper use of filter cloth or drain tile is necessary to prevent clogging of the drain lines. If designed in connection with a subsurface pipe system similar to a leach field, foundation drain water can be distributed over a larger area. Combined with appropriate landscaping, this can reduce or eliminate the need to use potable water for irrigation.

Recommendations

Proven Practices for Superior Performance

- New projects that employ filtration and membrane processes should provide a feasibility summary study of how these sources might be used.

Cooling-tower Blowdown

Evaluate the feasibility of reusing cooling-tower blowdown water for another purpose, such as diversion for compressors, vacuum pumps, and other equipment with water-cooled air-condenser units. A detailed analysis is beyond the scope of this section, but any such project should be closely coordinated with local stormwater and water-quality officials, since the type of cooling-tower water treatment will determine the quality of the blowdown water. Using blowdown water may offer a classic example of tradeoffs. In the section, “Thermodynamic Processes,” achieving the maximum numbers of cycles of concentration was a goal. This was based on a stand-alone cooling-tower operation. In this case though, if the need for irrigation water exceeds blowdown volumes at the site, the designer may wish to consider reducing the cycles of concentration and, instead, choose treatment that will produce blowdown suited for irrigation purposes. This also avoids water-quality problems for streams receiving runoff from the property. The net benefits of using blowdown are that it makes use of all the water entering the tower, displaces potable water use for irrigation, and eliminates wastewater discharge from the tower.

Another option is to use nanofiltration or RO to treat tower make-up water so that extremely high cycles of concentration can be achieved. Reject water can then be used for irrigation.

Recommendations

Proven Practices for Superior Performance

- New projects that employ filtration and membrane processes should provide a feasibility summary study of how these sources might be used.

On-site Treatment of Gray Water and Wastewater

Gray water is defined in California law as “untreated waste water which has not come into contact with toilet waste. Gray water includes waste water from bathtubs, showers, bathroom wash basins, clothes-washing machines, and laundry tubs, or an equivalent discharge as approved by the Administrative Authority. It also does not include waste water from kitchen sinks, photo-lab sinks, dishwashers, or laundry water from soiled diapers,” in Title 24 section 5 of the Code. The use of gray water or on-site treatment of wastewater for on-site reuse requires a project-by-project analysis and is beyond the scope of this document. However, many commercial projects have employed technologies ranging from simply using septic tanks and near-surface dosing of the effluent for subsurface irrigation to the installation of full-capacity wastewater-treatment plants, followed by conventional landscape irrigation. Another example is treating effluent to a quality sufficient for toilet and urinal flushing.

As an example, the 250-unit Solaire Apartments in Battery Park was a private-public partnership and is the first “green” residential high-rise building that incorporates advanced materials, energy conservation, and water reuse in an urban setting. The Solaire Apartments selected the ZENON Membrane Solutions proprietary ZeeWeed MBR (membrane bioreactor) process to treat, store, and reuse wastewater for toilet flushing, irrigation, and cooling towers. This approach reduces the fresh water taken from the city’s water supply by more than 75 percent and significantly decreases energy costs, since less drinking water is pumped from the city’s treatment plant and wastewater is not transferred to the city’s wastewater treatment system. The system is the first on-site water-recycling system in the U.S. built inside a multi-family, residential building.

Gray water from wash basins, bathing and showers, and laundry operations has also been considered.

A primary concern is to involve health-department, code-enforcement, and stormwater-quality officials in the design and development of any project to ensure that all applicable environmental concerns are taken into account, that appropriate technologies are employed, and that regulations are met.

Recommendations

Proven Practices for Superior Performance

- New projects that employ filtration and membrane processes should provide a feasibility summary study of how these sources might be used.

Multiple Sources

Plumbing of rainwater, gray water, drain water, and blowdown from various sources to common end uses, like landscape irrigation, or non-potable indoor uses, such as toilet flushing, is not common, but is recommended. Cost effectiveness of such “hybrid” systems is improved by diversifying the sources of water and improving the consistency of water availability, since rainfall episodes, often the largest and most significant single source of water, are sometimes separated by long dry periods.

Gray water generally does not contain fecal matter and, thus, can more easily be treated and reused on-site. Gray water requires simple filtration to remove suspended particles and, when stored, requires only treatments such as chlorination for odor or aeration for nutrients in the water.

Recommendations

Proven Practices for Superior Performance

- Clarify in local ordinances the specific plumbing uses of alternative sources of water and their relationships to the potable-water system

This page intentionally left blank.

Food Service Operations

Most locations where large numbers of people assemble have food-service facilities. Restaurants and pastry/doughnut shops are obvious members of this category. Most schools, hospitals, hotels, service stations with stores, and convenience stores have food-service operations. Larger office buildings, factories, and institutional facilities provide food service of some type to their employees. Because food-service facilities are characterized by many kinds of water uses and high energy and water consumption, they are prime targets for incentives or requirements for water-efficient equipment, both for new construction and for retrofit of existing facilities. This report focuses on efficient equipment that should be required or at least considered for new construction.

Water-using technologies that have specific potential for water conservation include:

Refrigeration Equipment

- Refrigerators and freezers
- Ice-making machines

Cooking and Food-Service Equipment

- Steam tables
- Steam kettles
- Pasta cookers
- Steamers
- Combination ovens (a new product in development)
- Dipper wells
- Woks

Scullery Operations

- Garbage disposers
- Pre-rinse spray valves
- Dishwashers

Washing and Sanitation

- Floor washing
- Hood washing

Refrigeration Equipment

Refrigerators and Freezers

Refrigeration includes both coolers and freezers used to preserve food. Three major considerations for minimizing water use in refrigeration operations are:

Food service operations are found in many businesses and institutions, including hospitals, schools, hotels, convenience stores, specialty shops, grocery stores, office buildings, and, of course, restaurants.

- having adequate refrigeration equipment to minimize the need for thawing food under flowing water
- eliminating once-through cooling
- encouraging air-cooling, especially with remote (outside) compressors that exhaust waste heat outside the building

Description of End Use

Potential water savings from refrigeration equipment fall into three categories:

- sizing refrigerators to provide adequate capacity for thawing frozen food. The California Uniform Retail Food Facilities Law requires that food be defrosted in a refrigerator or be thawed under constantly flowing water that remains below 75° F. Thawing under flowing water is always wasteful and should be avoided whenever possible by designing for adequate refrigeration equipment to be installed in food-service facilities.
- eliminating once-through or pass-through water-cooling by installing air-cooled equipment. Reach-in refrigeration equipment (smaller display cases, glass- and solid-door coolers, etc.) is almost exclusively air-cooled, but large walk-in units and large display cases can be either air- or water-cooled. Some facilities use recirculating cooling water from either a chilled-water loop or a cooling tower. Although more efficient than once-through cooling, it is usually less economical than air-cooling.
- air-cooling, especially with remote (outside) compressors that exhaust waste heat outside the building, not into the working space. Energy use for air-cooled equipment is primarily a function of the size and capacity of the refrigerator or freezer, combined with the energy efficiency of the equipment.

Water-Savings Potential

Water savings from installing adequate refrigeration varies greatly. Some restaurants can use thousands of gallons a day thawing food under running water in a sink. The typical kitchen faucet turned on half way has a flow rate of about 3.0 gpm and may be left on for an hour or more a day for thawing. Using equipment with once-through cooling saves approximately 145 gallons per ton hour. A three-ton refrigerator uses 5,000 gallons of water a day for once-through cooling.

Cost-Effectiveness Analysis

Example: Thawing under water in a sink *versus* extra refrigeration space.

- Equipment capital costs: \$27 per cubic foot.
- Estimated equipment life: 8 years (Nadel, 2002).
- Water and energy savings: Compare the cost of water and wastewater used to thaw in a sink with the cost of purchasing and maintaining extra refrigeration space. Three faucets flowing at 3.0 gpm, used one hour each day, consume 200,000 gallons a year. The combined water and sewer cost savings equals \$1,400 a year.
- Incremental cost per AF of efficient equipment: The average operating cost of refrigeration is approximately \$7.50 per cubic foot (for solid doors, Energy Star). The PV of the operating savings and amortized capital costs justify purchasing an additional 121 cubic feet of refrigeration. This change would save 0.6 AF of water per year at no additional cost.

Example: Once-through water-cooled vs. air-cooled.

- Equipment capital costs: The incremental cost for a water-cooled unit *versus* a remote-head unit is \$2,000 for even the largest units.
- Estimated equipment life: 10 years (Energy Star).

- Water and energy savings: An air-cooled unit uses 145 gallons of water per ton-hour, at a cost of \$1.00 per ton-hour. A water-cooled three-ton refrigeration unit working 4,000 hours a year would use 1.74 million gallons a year (5.4 AF), for an annual water and wastewater cost of \$12,400. The additional energy cost for an air-cooled unit would be \$300 a year.
- Incremental cost per AF of efficient equipment: The simple payback for the additional capital costs of a remote-head unit would be two months. The positive benefit per AF is \$1,900.

Recommendations

Proven Practices for Superior Performance

- Provide adequate refrigerator space for thawing food.
- Choose energy-efficient equipment.
- Prohibit once-through cooling with potable water.

Additional Practices That Achieve Significant Savings

- Choose air-cooling rather than recirculating cooling-water systems.
- Follow requirements in the cooling tower section of this report.

Ice-Making Machines

Description of End Use

Ice makers are an extension of the refrigeration-equipment category, but unique in many ways. As with refrigeration, both water-cooled and air-cooled equipment are available, with air-cooled being much more water-efficient. There are two basic types of commercial ice equipment: flake-ice and cube-ice machines. Ice-making machines are rated by the hundreds of pounds of ice the machine can make per day. One hundred pounds of ice is equal to 12 gallons of water, but actual water use depends upon the efficiency of the particular machine. Many local utilities in California provide rebates for efficient ice machines.

Flake-ice machines, including the new nugget machines, are the most energy- and water-efficient equipment available. Nugget machines press flake ice into a small cylindrical shape. Flake ice is crunchy and tends to melt quickly in drinks; it is often used to ice down food in serving lines. Nugget ice melts more slowly, can be used in most drink applications, and is increasingly being used instead of cube ice. Nugget ice is appealing in soda-fountain drinks, since the whole nugget becomes flavored with the soda and is easy to chew.

Cube-ice machines produce clear cubes of ice by washing the cubes as they freeze, so any minerals that may precipitate on the forming cubes are washed away. Cube-ice machines are the most common commercial ice-making equipment.

According to the Consortium for Energy Efficiency (CEE), hospitals account for 39.4 percent of all commercial ice-maker purchases, followed by hotels (22.3 percent), restaurants (13.8 percent), retail outlets (8.5 percent), schools (8.5 percent), offices (4.3 percent), and grocery stores (3.2 percent).

Water-Savings Potential

Flake/nugget machines purge the cylindrical tubes with water two or three times a day to flush out any precipitated minerals, using 10 to 30 gallons each time. It takes 20 gallons of water to make 100 pounds of flake/nugget ice. Cube machines use water to wash the cubes so they are crystal clear, increasing water use to 30 or more gallons per 100 pounds of ice in some cases. Water-cooled units use from 72 to 240 gallons of water for every hundred pounds (12 gallons) of ice produced. Once-through systems simply dump this water into the sanitary sewer.

The USEPA's Energy Star program has published standards for cube-making ice machine equipment. These standards do not yet include flake and nugget machines. Once separate flake and nugget ice machine standards are developed, they should be followed also. In the interim, the Food Service Technology Center has published a list of qualifying ice machines that include both cube-making and flake and nugget ice machines.

When cube-making ice machines are installed, the installer will set the purge rate, the rate at which water flows over the ice plate surface to remove precipitating minerals. Having the installer set this rate to the lowest level possible will also save water.

Cost-Effectiveness Analysis

Example: 700-pound air-cooled vs. water-cooled ice machines:

- Equipment capital costs: \$1,000 additional for an air-cooled unit.
- Estimated equipment life: 7 years, depending on usage.
- Water and energy savings: An air-cooled machine producing 700 pounds of ice per day will save 1,350 gallons per day *versus* a water-cooled machine. The net annual operating cost savings is \$1,600 to \$2,300 for an air-cooled *versus* a water-cooled machine, depending upon the air-cooled configuration. Simple payback for selecting an air-cooled machine is 12 months.
- Incremental cost per AF of efficient equipment: The savings is 10.2 to 10.7 AF over the life of the machine. The net PV of the operating savings is \$12,100 for an air-cooled unit in air-conditioned space and \$9,200 for a remote-head. The positive benefit ranges from \$880 to \$1,180 per AF.

Example: 700-pound nugget/flake-ice *versus* a cube-ice machine:

- Equipment capital costs: Flake- and nugget-ice machines cost from \$500 to \$1,200 more, depending upon size, due to the cost of a mechanical auger, which removes the flakes of ice from the tubes surrounded by liquid refrigerant.
- Estimated equipment life: 6 years.
- Water and energy savings: Compared with cube machines, air-cooled flake-ice machines reduce water use by about 15 gallons and electricity use by a kilowatt hour for every 100 pounds of ice made. An air-cooled flake machine that makes 700 pounds of ice daily will use 105 gallons and 7.0 kilowatt hours (kWh) a day fewer than a cube machine. In a year, this equals 38,000 gallons and 2,555 kilowatt hours, resulting in an annual operating savings of \$475 per year. The simple payback is five months.
- Incremental cost per AF of efficient equipment: The savings will be 0.7 AF over the life of the equipment. There is a positive PV benefit of \$1,800 per AF.

Recommendations

Proven Practices for Superior Performance

- Prohibit once-through water-cooled ice makers.
- Cube-ice machines must meet USEPA Energy Star standards for cube-ice machines. Consider requiring Tier 3 (CEE Commercial Kitchens).
- Nugget- and flake-making ice machines should be selected from the Food Service Technology Center list of qualifying ice machines.

Additional Practices That Achieve Significant Savings

- Ensure that installers set the amount of purge water to the lowest level possible for the quality of water being used.

- Choose energy-efficient flake or nugget machines rather than cube machines. Nugget machines should be adequate for most restaurant and food-service operations, as well as for drinks in convenience stores.
- Mount compressor units outside so rejected heat is not dumped into work or living spaces. “Remote-head” is the term used to describe these outside units.
- Prefer air-cooled units to those using a cooling-tower loop, which increases water use by evaporating 7 to 9 gallons of water per 100 pounds of ice made.

Cooking and Food-Service Equipment

Steam Tables

Description of End Use

Steam tables, used to keep food hot while serving, are filled with water and heated to keep the food at 140° F or higher (California Uniform Retail Service Law). At the end of the day, they are drained. The major consideration regarding water efficiency is whether a steam table is actually needed. Though indispensable in large cafeterias and many institutional settings, they are not needed in every food-service operation. Some tables have both wet and dry options, and others use direct-heating equipment, such as electrically heated serving wells, which use no water at all;

Water-Savings Potential

Steam tables require 20 to 100 gallons of water or more per day, depending upon their design and size.

Cost-Effectiveness Analysis

Steam table prices range from a few hundred to \$4,000, depending upon size and capacity. The decision, in terms of water use, is whether a steam table is needed.

Recommendations

Proven Practices for Superior Performance

- None

Additional Practices That Achieve Significant Savings

- For smaller applications, choose dry heating tables that use no water.
- Prefer non-water-using equipment to steam tables, if feasible.
- Use hot water from the steam table for end-of-day mopping.

Steam Kettles

Description of End Use

Steam kettles are often selected for use in large facilities because, as with steam tables, temperatures can be more easily controlled, thereby preventing scorching the food. They should be installed only where large-volume food preparation justifies this water and energy use. Some steam kettles have their own heat source, but where a central boiler is used to supply the steam, the condensate should be returned to the boiler for reuse. Stand-alone steam kettles, which can use either electricity or gas as a heat source and do not require a separate boiler, are the most common type found in restaurants. Large steam kettles are more commonly found in institutional settings.

Water-Savings Potential

The major water-savings potential for steam kettles is for the condensate to be retained and returned to the boiler, if such a system is used.

Cost-Effectiveness Analysis

- Equipment capital costs: Steam traps and condensate return are the only water-saving features available. Condensate return systems cost about \$3,000. There is a one-time cost for piping.
- Estimated equipment life: Assume 10 years.
- Water and energy savings: The type of steamer used depends upon the availability of a commercial boiler to produce steam. For example, a 40-gallon kettle using steam at 30 pounds per square inch of pressure will use 214 pounds (25.7 gallons of water) an hour. Operating 12 hours a day, it would dump 308 gallons of water at 212° F. In a year it would consume 133 Mcf (thousand cubic feet) of gas and 113,000 gallons of water, which could cost as much as \$2,000 a year (Bowser). Assuming a 20 percent blowdown rate and 30 percent energy savings from recirculating heated water, the annual water and energy cost savings is \$1,000. The net PV of the incremental cost and water and energy saving is \$4,800.
- Incremental cost per AF of efficient equipment: The recirculating system will save 0.35 AF per year at a net PV positive cost of \$1400 per AF.

Recommendations

Proven Practices for Superior Performance

- Return condensate for all boiler-type kettles.

Additional Practices That Achieve Significant Savings

- Size steam traps to operate properly and not inadvertently dump condensate.
- Insulate condensate-return lines.

Pasta Cookers

Pasta cookers look much like fryers, but are used to heat and boil water instead of oil. Strainer baskets, similar to those used in fryers, hold the pasta. Pasta cookers have an overflow to skim off foam and either a manual or automatic fill valve. While in full operation, the fill valve is opened slightly to add fresh water. This helps reduce evaporation that occurs during a rolling boil. Many pasta cookers can be put into a standby or simmer mode when not in active use. Steam kettles and pots on the stove are the alternatives to this equipment.



Source: Cleveland

Water-Savings Potential

Pasta cookers can be made more water-efficient by using automatic control valves to minimize overflow during the cooking process. The valves should shut off when the cooker is in simmer mode. Pasta cookers need not be completely refilled with water regularly, like a pot on a stove, so they can save some water, so long as the overflow is properly controlled.

Cost-Effectiveness Analysis

- Equipment capital costs: N/A
- Estimated equipment life: N/A
- Water and energy savings: Costs for all of the above are similar. Water and energy savings depend more upon how they are operated than on the types of controls installed. Having auto-



matic overflow controls provides the opportunity to use the equipment more efficiently.

- Incremental cost per AF of efficient equipment: N/A

Recommendations

Proven Practices for Superior Performance

- Require pasta cookers to have a simmer mode.
- Require automatic overflow controls.

Additional Practices That Achieve Significant Savings

- Minimize overflow by restricting flow to one-half gpm.

Steamers

Description of End Use

Steamers are used to cook food with steam. There are two basic types. The first uses a boiler. Water is turned into steam and the left-over steam is vented. These systems require both water and wastewater connections. Water is continuously flushed through the boiler to prevent scale buildup. The boiler must be de-limed on a regular basis.

The second type is the connectionless steamer. It heats water in a reservoir at the bottom of the steamer, and the steam produced is recondensed and returned to that reservoir. These systems do not require water and wastewater connections. Boiler de-liming is not needed since there is no boiler. At the end of the day the reservoir is simply wiped out with a cloth soaked in vinegar.

Other boilerless systems do have water connections. One refills the reservoir as needed and does not dump water; its water efficiency is similar to the connectionless steamer. Another, just like the boiler type, dumps water, requires both water and sewer connections, and has similar water and energy use characteristics.

Water-Savings Potential

Both water and energy consumption vary significantly by steamer type. In a recent study, boiler steamers averaged over 450 gallons of water and 89 kWh a day, while comparable boilerless steamers used only 14 gallons and 17 kWh a day. Connectionless steamers use approximately 3 gallons of water per hour of operation, while boiler types use 40 gph or more (Fisher-Nickle).

Cost-Effectiveness Analysis

- Equipment capital costs: The costs of connectionless and boiler steamers vary little. However, boiler steamers must have both water and sewer hookups and a reduced-pressure zone (RPZ) backflow preventer, which can add several thousand dollars to the total cost. In addition, the backflow preventer must be tested annually.
- Estimated equipment life:
- Water and energy savings: The cost of operating a boiler steamer is substantially higher for both water and energy. Water consumption is about 175,000 gallons per year, compared with 13,000 for a connectionless steamer (Fisher Nickle). Water savings is 0.5 AF per year. Energy usage is almost four times that of a boiler steamer. Annual savings in operating cost is \$1,800 for the water and energy, after deducting the annual testing cost for an RPZ.

- Incremental cost per AF of efficient equipment: After deducting the cost of the RPZ, the savings is \$2,600 per AF.

Recommendations

Proven Practices for Superior Performance

- All steamers must be either connectionless or boilerless and consume no more than three gph.

Combination Ovens

Description of End Use

Combination ovens help keep food from drying out while baking or roasting. Both gas and electric models are available in several configurations. One has a boiler that produces steam which is injected into the oven chamber. Others achieve high humidity with sprays, and some models have closed systems that recondense steam to achieve higher energy and water savings (Alto-Shaam). The cooking capacity of a typical oven is significant. One six-pan model can cook as many as 32 chickens at a time (Sorensen).

Water-Savings Potential

A heavily used ten-pan boiler combination oven can consume 30 to 40 gallons of water per hour, while a boilerless misting oven uses only 10 to 15, resulting in an annual savings greater than 110,000 gallons (Reed).

Gas and electric combination ovens vary widely in energy efficiency. Some models are 40 to 60 percent more energy efficient than their conventional counterparts. Inefficient models consume 360 to 480 gpd, while efficient models use only 120 to 180 gpd.

Cost-Effectiveness Analysis

- Equipment capital costs: Combination ovens are expensive; small units start in the \$10,000 range, while larger units can cost as much as \$50,000. Energy Star examples show prices for larger, more-efficient equipment to be approximately \$8,400 higher than for conventional models.
- Estimated equipment life: 10 years.
- Water and energy savings: The energy savings is 12,450 kWh per year in this example. Combine this with an estimated savings of 130,000 gallons of water per year, and the annual operating savings is \$1,700. Over the life of the equipment, this saves \$17,000 in energy costs and 4 AF of water (Energy Star).
- Incremental cost per AF of efficient equipment: When both energy and water savings are considered, the net benefit to the customer is \$1,360 per AF or a total of \$5,500.

Recommendations

Proven Practices for Superior Performance

- Combination ovens must use no more than 15 gph.

Additional Practices That Achieve Significant Savings

- All combination ovens should comply with the rebate list prepared by Fisher Nickel for energy rebates in California (www.fishnick.com/saveenergy/rebates/combis/combis.pdf).

Dipper Wells

Dipper wells are used for applications such as rinsing ice-cream scoops on the serving line. Most have a single faucet or spigot and can be supplied with either hot or cold water.

Water-Savings Potential

The faucet or valve can be adjusted by the server. Typical flow rates are 0.5 to 1.0 gpm. For smaller dipper wells, a flow rate of 0.25 gpm should be adequate. In-line flow restrictors can be installed on the supply line to the dipper well. These can be set at the minimum adequate flow and locked so that employees cannot increase flow.

Cost-Effectiveness Analysis

- Equipment capital costs: N/A
- Estimated equipment life: N/A
- Water and energy savings: As many as several hundred gpd.
- Incremental cost per AF of efficient equipment: N/A

Recommendations

Proven Practices for Superior Performance

- In-line restrictors that reduce flow to under 0.3 gpm.

Woks

Wok stoves commonly used in oriental restaurants rely on a constant flow of water over the surface of the stove to keep it cool for the comfort of the cook. Efforts are underway in Australia to develop a “waterless wok” which employs better insulation and air cooling. For new construction, the waterless wok should be used as soon as it becomes available (Sydney, 2005). As of 2007, waterless woks can be ordered from Australia, but most American kitchen appliance dealers were unaware of them when called in a November 2007 survey.

Cost-Effectiveness Analysis

- Equipment capital costs: N/A
- Estimated equipment life: N/A
- Water and energy savings: N/A
- Incremental cost per AF of efficient equipment: N/A

Scullery Operations

Garbage Disposers

The process of scraping dishes and disposing of waste prior to dishwashing can use from zero to very large quantities of water and energy, depending upon the design of the equipment selected. Commonly found equipment includes garbage disposers, sluice troughs, and pulpers.

Garbage disposers grind food and other items that enter the grinder and send them down the sewer. This waste material adds to the solids and grease entering the sewer and the grease trap. If a grinder is used, it should be equipped with a solenoid to shut off the flow of water when not needed.

Sluice troughs are usually built into the stainless-steel table systems. Water flows continuously into the top end of the trough at 5 to 15 gpm and flushes food waste from pots, pans, dishes, etc. into a garbage disposer. Large flows of water are required. A variation of this is the recirculating system that passes the waste through a grinder, strains out the solids for flushing down the drain, and returns the water to the

sluice trough to flush down more waste. These systems use only two to three gallons of make-up water a minute, but are expensive.

Pulpers strain the solids from the grinder waste stream and compact them to make disposal more convenient. These systems have the advantage of removing solid waste, fats, oils, greases, and other components from the wastewater. According to manufacturers' literature, they can also recirculate up to 75 percent of the water to the head of a sluice-trough system, as described above.

The main consideration with any of this equipment is whether it is needed in the first place. Many restaurants and food-service establishments are eliminating garbage disposers from their design, in favor of more thorough scraping into garbage cans and the use of strainers or "scraper baskets" to collect food solids for solid-waste disposal. In a typical operation, upwards of 80 percent of solids are already collected in the solid-waste disposal system. Some restaurants, however, may still prefer to have a garbage disposer. In these cases, disposers should be linked to pulpers, recirculating trough-collection systems, and related systems that use no more than 2 gpm of fresh water, or systems with a load-sensing device that regulates the water use to 1 gpm in a no-load situation and 8 gpm in a full-load situation. Only cold water should be supplied to the disposer, and a 15-minute shutoff timer should be installed.

Water-Savings Potential

Strainer (scraper) baskets can eliminate the energy and water associated with grinders, pulpers, and related systems, saving as many as 1,000 gpd, depending upon the grinder's size and hours of use. A typical grinder in a restaurant or food-service setting has a 2- to 8-horsepower (hp) motor and a water-flow rate of 5 to 10 gpm. Some food-service operations report using their grinders 2 to 3 hours a day. Water-saver kits can cut grinder water-use in half. The Aqua Saver grinder reports to tailor energy and water use to the load. It costs several thousand dollars, but can reportedly cut water use by up to 70 percent. Another major savings realized by installing a scraper or strainer system is that grease traps do not need to be pumped as often, and greases, solids, and biochemical oxygen demand (BOD) loadings are reduced at wastewater treatment plants.

Where a food-service or restaurant operation may deem it necessary to install a garbage-grinder-type system, the following guidelines should be followed:

- Use cold water — common code requirement.
- Equip the system with a load-sensing device that regulates the water use to 1 gpm in a no-load situation and 8 gpm in a full-load situation, *or* use a pulper or trough system with a make-up rate of no more than 2 gpm of fresh water.
- Employ a time shutoff — after 15 minutes (option: after 15 minutes of idle use or no-load) the operator must push a button to reactivate.

Cost-Effectiveness Analysis

Example: Strainer system *versus* a scrap basket

Grinders cost from a few hundred to over \$3,000. Huge savings are possible if a strainer system is used. Strainer-basket systems often eliminate pretreatment charges for grease and suspended solids, and grease traps do not have to be pumped as often.

- Equipment capital costs: For this example, the capital cost for a 4 hp grinder is \$750. Pulper systems, recirculating sluice troughs, and similar equipment cost over \$10,000. Additional equipment can be added to grinders that adjust water flow to the load, but they cost several thousand dollars, while strainer baskets cost about \$350 and eliminate energy and water use.
- Estimated equipment life: One scrap basket should have a life equal to two grinders: 10 years for a scrap basket; 5 years for a grinder.

- Water and energy savings: Estimating 3 hours of operation a day, 365 days a year, with water running at 6 gpm, daily use would be 1,080 gallons and 9 kWh. Potential annual water savings are 395,000 gallons or 1.2 AF and 3300 kWh. Personnel costs of approximately \$1,600 per year for emptying the scrap basket into a dumpster may be absorbed by existing personnel.
- Incremental cost per AF of efficient equipment: The benefit over the life of the scrap basket is \$1,600 per AF.

For savings related to the use of pulpers or trough-recirculation systems using no more than 2 gpm, information and calculators are available on manufacturers' web sites such as www.salvajor.com/troughCollector.aspx or www.insinkerator.com/foodservice/aquasaver.php and related systems.

Recommendations

Proven Practices for Superior Performance

- Use strainer (scraper) baskets in place of grinders.

Additional Practices That Achieve Significant Savings

- If a water-using grinder is selected, install a water-saver kit or choose a grinder that tailors the water use to the load.
- Use a trough or pulper system that uses no more than 2 gpm of fresh water.
- Supply only cold water to such systems and install a timer to shut the system down after 15 minutes of operation or no-load, so that it requires the user to reactivate the system.

Pre-Rinse Spray Valves

Description of End Use

Pre-rinse spray valves are used to spray dishes and cooking ware prior to placement in a dish washer. The spray knocks off solid food and rinses soluble residues down the drain or into the garbage grinder, usually after the items have been placed in a holding rack that can be inserted into the dish washer. Prior to 2006, there were no restrictions on spray-valve flow rates. The Federal Energy Policy Act of 2005 now restricts flow rates to 1.6 gpm, however, unlike the California Energy Commission standard, the Federal standard does not include cleanability criteria. The spray-valve replacement program in California used valves that met ASTM test standards F2324-03 for flow and cleanability.

Spray valves now becoming available could reduce flow rates to as low as 1.3 gpm and achieve cleanability standards. Since 1.6 gpm is now the standard, new facilities will benefit from these savings. Additional information on spray valves, including the new 1.3 gpm models, can be found at both www.fishnick.com and www.EnergyStar.gov.

As a word of caution, some restaurants have been observed using equipment other than pre-rinse spray valves for spray cleaning, for example, garden hoses and garden-hose sprayers, which may use in excess of 7 gpm. To avoid this, pre-rinse spray valves should be required.

Water-Savings Potential

Since the national standard is now 1.6 gpm, all new facilities will have the more efficient spray valve. New spray valves are now on the market that reduce water use to as low as 1.3 gpm and still pass the ASTM standards F2324-03. The new lower-flow spray valves should be field tested before they are mandated. Since hot water is used, the new valve consumes both energy and water. In a very-large restaurant serving breakfast, lunch, and dinner, such a valve may have as many as four hours of continuous use. Studies done by the California Urban Water Conservation Council show that average savings in a

restaurant are 137 gpd and 0.93 therms for gas hot-water heating per day. If a garden-hose sprayer were used instead, additional water consumption could be as much as 5.0 gpm or 1,000 gpd.

Cost-Effectiveness Analysis

- Equipment capital costs: N/A.
- Estimated equipment life: 5 years.
- Water and energy savings: Both water and energy savings accrue. When compared with older devices no longer allowed, the savings is approximately 137 gpd. The 1.3 gpm valves would reduce water use by another 15 to 20 percent.
- Incremental cost per AF of efficient equipment: N/A.

Recommendations

Proven Practices for Superior Performance

- Use pre-rinse spray valves for dish rinsing.
- Require pre-rinse spray valves that use less than 1.6 gallons per minute.

Additional Practices That Achieve Significant Savings

- Conduct a test program of the 1.3 gpm pre-rinse spray valves to determine their acceptability and performance.
- If test results are acceptable, offer incentives for installation of the 1.3 gpm spray valves.

Dishwashers

Description of End Use

Commercial dishwashers are very different from those found in homes. Residential dishwashers use 3 to 10 gallons per load, and the wash cycle lasts for half an hour or more. Commercial dishwasher run times are typically 1 to 3 minutes, and one machine may wash hundreds of loads per day. The majority of smaller commercial machines are leased by the companies that supply chemicals and detergent to the market; these machines tend to be less efficient. Three technical variations make a significant difference:

- The first variation is whether the machine saves water from the last wash to use in the next load or is a fill-and-dump machine that dumps all of its water after each load. Fill and dump machines are inherently inefficient.
- The second variation is how dishes are sanitized. One of the types most commonly found in small restaurants is the chemical machine, which typically uses a chlorine-based disinfectant. The other is the high-temperature machine, which uses 180° F water for sanitation and uses a booster heater to achieve these high temperatures. Chemical machines tend to use more water. Based upon information from the National Sanitation Foundation (NSF) and studies by the Food Service Technology Center and the CEE, hot-water sanitation machines use less water than chemical-sanitation equipment of the same capacity and type. This is borne out by the new set of commercial dishwasher standards set by the USEPA's Energy Star program, which lists both energy and water-use standards for all but flight-type dishwashers. An independent study of flight-type machines found in the NSF data base, done for this publication, indicates that maximum water use should not exceed 185 gph.
- The third variation has to do with the basic design of the washer.
 - » Under-the-counter dishwashers are commonly found in bars, where only glassware is washed, or in small restaurants serving fewer than 60 people a day. They cost \$3,500 to \$4,000 each.
 - » With the door-type machine, a rack of dishes is hand-loaded into the machine, and the cycle is started by hand. These are primarily found in restaurants that serve fewer than 150 customers a day. The cost can range from \$4,000 to \$10,000.

- » The C-Line or conveyor pulls the rack of dishes through the washer and pushes the clean rack out the other side. Larger restaurants serving between 150 and 300 people a day commonly use these, which cost from \$12,000 to \$50,000 per machine.
- » Flight machines are designed for service to many hundreds or even thousands of people per day and are typically found in large institutional facilities, hospitals, and large hotels with banquet facilities. Their costs range from \$50,000 to well over \$100,000.

CEE Commercial Kitchens preliminary annual sales data show about 65 percent of machines are door-type, 12 percent under-the-counter, 18 percent C-Line (conveyor), and 5 percent flight machines. Many door and C-Line machines are rented from companies that also supply the chemicals needed for the dishwashers. Rental costs depend upon how the chemicals are sold in the contract, but for a typical door machine, rents range from \$80-\$100 per month, while C-Line machine rents are \$200 a month. The food-service-facility owner who rents has less opportunity to choose higher-efficiency equipment.

Dishwashing machines have variable lifespans. Door and C-Line machines typically function 7 to 10 years, while flight machines can last 15 or more. However, the rebuild and refurbish market for this equipment is enormous, with many new restaurants purchasing older, less-efficient rebuilt equipment.

C-Line conveyor and flight dishwashers can be equipped with electronic sensors and door switches to stop water flow when the machine is not washing dishes. Steam doors can reduce evaporation by up to 40 percent.

Water-Savings Potential

It is not uncommon for a C-line machine to wash 500 loads a day. Therefore, even a small increase in efficiency can make a big difference. NSF International data show water-use rates ranging from 72 to 852 gph, with the median use for all makes and models being about 280 gph. For other machines, the difference in water use is about 2 gallons per rack. Savings are based upon the number of racks washed per day. Savings realized by choosing an efficient door or conveyor model may range from hundreds to thousands of gpd, depending upon size and usage. Median use for door machines is about 1.5 gallons per rack and, for conveyors, about 1.2 gallons per rack.

The restaurant industry makes extensive use of refurbished dishwashers. Many of these older refurbished models are far from water-efficient. When purchasing or leasing any ware-washing equipment, ensure that it meets both energy- and water-saving standards.

Cost-Effectiveness Analysis

Example: C-Line conveyor high-temperature machine which can wash 900 racks of dishes a day.

- Equipment capital costs: 0.
- Estimated equipment life: 10 years.
- Water and energy savings: The average C-Line conveyor machine uses 1.2 gallons per rack. An efficient machine uses 0.9 gallons per rack or less. Annual operating savings for water, sewer, and avoided water heating are \$1,800.
- Incremental cost per AF of efficient equipment: The benefit is \$4,500 per AF saved.

Example: Flight machine

- Equipment capital costs: 0.
- Estimated equipment life: 10 years.
- Water and energy savings: Operating continuously eight hours a day, an inefficient machine uses 500 gph, while an efficient machine uses 214 gph. The savings is 835,000 gallons per year or 2.6 AF, for an annual operating cost savings of \$15,000.

- Incremental cost per AF of efficient equipment: The benefit is \$4,500 per AF saved.

Example: Door machine

- Equipment capital costs: \$2,500 incremental cost for a machine with a recycle system.
- Estimated equipment life: 10 years.
- Water and energy savings: The machine washes 300 racks a day. A fill-and-dump machine uses 1.5 gallons a rack, while a machine with a water-recycle system uses 0.9 gallons per rack. Annual water savings is 66,000 gallons or 0.2 AF. Annual operating-cost savings of \$1,200, including water, wastewater, and avoided gas water-heating.
- Incremental Cost per AF of Efficient Equipment: The benefit is \$4,000 per AF saved.

Recommendations

Proven Practices for Superior Performance

- Ban the use of fill-and-dump machines.
- Equipment must meet efficiency standards for dishwashing equipment set by the U.S. Environmental Protection Agency Energy Star program.
- For flight-type dishwashing equipment, require a flow-rate not greater than 185 gph.

Washing and Sanitation

Floor Washing

Description of End Use

Washing floors in food-service establishments can use large quantities of water. The common practice has been to mop the kitchen floor with soapy water, then use a high-pressure hose with hot water to rinse the soapy water into the floor drain. This process uses large amounts of water, as well as energy to heat the water, and has a tendency to splash dirty water onto clean equipment. Some literature reports that water use for floor cleaning in a large commercial kitchen can be in the range of 1,000 to 1,500 gpd.

Four approaches can help reduce the amount of water use.

- First is to perform the conventional floor practice more efficiently, including:
 - » Use a broom and dust-pan to clean up solid wastes before mopping.
 - » Install a self-closing nozzle on the wash-down hose, so the water runs only when needed.
 - » Use a new enzyme product that helps break down grease on the floor and require less water for rinsing.
 - » Use a squeegee to push water to the floor drain prior to the final rinse.
- Second is to use the mop and squeegee method only, followed by a rinse with fresh mop water. While sometimes more time consuming, it does eliminate the use of the wash-down hose.
- Third is to use a pressure washer. Especially useful in cleaning floor mats and exhaust-hood filters, they can also be used in place of the standard hose for floor cleaning. Care should be taken not to splash water onto cooking surfaces. A pressure washer is much more water-efficient than a hose hooked to the hot-water faucet, as well as for the occasional need to clean outside areas. In all cases, regulations related to watershed protection and pollution control should be followed.
- Fourth involves the purchase and use of a wet-dry vacuum system or mechanical floor-cleaning system, which can often be used to clean the dining area also. It minimizes water and chemical use. These systems often look like carpet-cleaning equipment, but are designed to

handle heavily soiled solid surfaces. These cost from about \$1,000 to more than \$6,000, depending upon the size and type of equipment purchased.

Water-Savings Potential

When examining ways to reduce water use at a new facility, the choice of floor-cleaning processes must be part of the facility design.

- Any conventional floor cleaning system with a hot-water hose should, at a minimum, have a self-closing valve.
- Choose pressure-washing equipment for floor, exhaust-hood-filter, and floor-mat washing.
- Arrange equipment so squeegeeing can be done easily.
- Use floor-cleaning machines that have a water tank.
- Consider a floor washer or other systems.

Traditional floor-washing systems can use 1,250 gpd. A water-broom and mop system will cut this to under 500 gpd, and a floor-washing system or machine can reduce this to under 250 gallons, for a savings of 750 to 1,000 gpd of hot water. It is difficult to estimate water savings exactly, since it depends upon many parameters and must be done on a case-by-case basis.

Cost-Effectiveness Analysis

- Equipment capital costs: N/A
- Estimated equipment life: N/A
- Water and energy savings: The cost effectiveness of these systems is strongly dependent upon the individual situation. A range for savings would be \$2,000 to \$3,500 per year.
- Incremental cost per AF of efficient equipment: N/A

Recommendations

Proven Practices for Superior Performance

- Require all hoses used for washdown to have self-closing nozzles and limit flow to no more than five gpm.

Additional Practices That Achieve Significant Savings

- Use water brooms that are limited to 3.0 gpm where feasible.
- Use a floor-cleaning machine.
- Use an enzyme cleaning processes.
- Choose pressure-washing equipment for floor, exhaust-hood-filter, and floor-mat washing.
- Arrange equipment so squeegeeing can be done easily.

Hood Washing

Hood-washer systems offer a convenient way to clean slot and extractor hoods. The hood washer sprays soapy hot water over the grease-extractor systems after the hood is turned off for the day. Timing can be pre-set depending upon the amount of grease that collects. Hood-washer systems use from 0.5 to 1.0 gpm of water per linear foot. Hood washers may or may not use less water than conventional manual cleaning methods, depending upon the frequency of washing and how the water use with the hood system compares with the water use of manual cleaning, usually done with a pressure washer. Hood systems have a significant cost, although when properly operated, they may save water.

References

Alto-Shaam. **Combitherm**. www.alto-shaam.com.

Bowser, Tim, P.E. **Food Technology Fact Sheet.**

Energy Star. **Energy Star Calculator.** www.EnergyStar.gov.

_____. www.EnergyStar.gov/ia/products/commercial_food_service/CFS_Full_Service.xls.

Fisher-Nickle Inc. February 2005. **Best Practices – How to Achieve the Most Efficient Uses of Water in Commercial Food Service Facilities.**

_____. www.fishnick.com.

_____. www.fishnick.com/saveenergy/rebates/combis/combis.pdf.

Reed, Clark. October 2005. **Saving Water Counts in Energy Efficiency.** Energy Star. U.S. Environmental Protection Agency.

Sydney Water Australia. September 1, 2005. **Wok Stove and Steamer Water Efficiency Report.**

Sorensen, Greg. July 2006. **Rational Model SCC 62G Combination Oven Performance Test.** Food Service Technology Center. Fisher-Nickel, Inc.

Landscape Water-Use Efficiency

Outdoor water-use efficiency is growing in importance as increasing demand for fresh water strains limited resources in many locales and where outdoor use represents a significant percentage of a water provider's total water demand. Obtaining landscape water-use efficiency over the long term requires proper planning (design) for such landscape elements as:

- functionality
- grading, runoff, soil preparation, and mulches
- plant selection
- irrigation systems
- maintenance

Studies have shown that water-conserving landscapes, known as xeriscapes, can save significant water (50 percent or more) and reduce maintenance costs (up to 30 percent) by following appropriate planning principles, including the following:

- designing for functionality
- preparing soil properly
- selecting plants suited for the climate of the region
- using lawn appropriately
- designing irrigation-systems for efficiency
- using mulches
- employing appropriate maintenance practices

Landscape standards or guidelines incorporating these principles can be approached from three perspectives:

- water budget
- checklist
- a combination of the two

and can be adopted by either planning agencies or water providers.

A water budget establishes limits on allowable consumption in a given landscape area. This approach is best suited for adoption by water providers that can encourage water efficiency through pricing mechanisms. It offers the advantage of design flexibility, but requires financial incentives (surcharges for exceeding established budget) to be effective. Thus, a water provider needs to be prepared to take the necessary steps for program implementation, which involves securing the appropriate resources to monitor use (dedicated metering), determining water budgets, and adopting appropriate pricing structures and billing programs.

To establish a water budget for a given site, it is necessary to know the irrigated area and the region's annual evapotranspiration (ET) rate. ET is the measure of water depletion from the soil due to evaporation and transpiration through plant

Perhaps nowhere are careful planning, implementation, and maintenance more important than in landscapes. Landscapes provide beauty, ameliorate the effects of heat and pollutants, and conserve our watersheds. They need not be "water thirsty" to provide these services.

foliage. The ET rate is determined by such parameters as solar radiation, temperature, wind, humidity, and plant and soil types. While ET varies continuously, annual ET data have been developed by plant type and by region. A plant's supplemental water requirement (annual water budget) is based upon effective precipitation and its ET rate, called net ET. Thus, a water budget can be established for a given area once the plant types and ET rates are known. Since most landscapes have a variety of plant materials, the ET rate for a cool season grass is typically used for reference. ET reference material is cited in the back of this section. A typical landscape water budget for a new landscape allows 80 percent of reference ET per square foot of landscaped area. An exception might be allowed for a large turf site in full sun by allowing 100 percent of reference ET per square foot of landscaped area.

A checklist approach prescribes design criteria. This approach can be adopted by both a planning agency and a water provider and typically involves plan review, site inspection, follow-up monitoring, and enforcement for non-compliance. In this case, a planning agency might provide the plan review and site inspection, and the water provider might provide the monitoring and enforcement. A combination approach involves using a checklist to help meet water-budget objectives.

The checklist following provides an example of what information might be requested of an applicant for water service in order to apply criteria for meeting landscape water-efficiency goals.



Photo by Katherine Jones, Horticulture Program Representative, U.C. Davis

Checklist of Landscape Water-Efficiency Measures

Functionality
<p>Address how landscape is going to be used:</p> <ul style="list-style-type: none"> <input type="checkbox"/> Play, sports field (Is artificial turf appropriate?) <input type="checkbox"/> Park <input type="checkbox"/> Median strip
Soil Preparation
<ul style="list-style-type: none"> <input type="checkbox"/> Conduct soil analysis; amend soil with organic material to a depth of at least six inches to provide plant nutrients, if appropriate
Runoff
<ul style="list-style-type: none"> <input type="checkbox"/> Minimize runoff through use of pervious material, swales, terracing, rain gardens, and berms, as appropriate
Plant Selection and Groupings
<ul style="list-style-type: none"> <input type="checkbox"/> Use plants appropriate to the climate of the region <input type="checkbox"/> Group plants into hydrozones (irrigated areas based on plant water requirements) <input type="checkbox"/> Use water-efficient varieties of turf <input type="checkbox"/> Prohibit use of invasive species
Irrigation
<ul style="list-style-type: none"> <input type="checkbox"/> If reclaimed water is available and appropriate for use, install approved hardware <input type="checkbox"/> If not presently available or not yet appropriate for use, consider installing irrigation hardware adaptable to reclaimed water should circumstances change <input type="checkbox"/> Install separate irrigation meters for properties with more than 5,000 square feet of total irrigated area <input type="checkbox"/> Install irrigation equipment that meets the Irrigation Association design guidelines for maximum irrigation operational uniformity <input type="checkbox"/> For all new nonresidential landscapes not required to have a separate water-service meter, install a private irrigation sub-meter and backflow prevention valve between the point of connection on the domestic water service and the first irrigation valve <input type="checkbox"/> Design all irrigation systems to avoid runoff, over-spray, low-head drainage, and similar conditions where water flows off-site onto adjacent property, non-irrigated areas, walks, roadways, or structures <input type="checkbox"/> Employ drip or low-volume irrigation equipment where it is determined that overhead spray irrigation would result in waste of water due to excessive runoff or overspray <input type="checkbox"/> Follow proper hydrozoning principles when designing irrigation systems in order to water turf and bedded areas separately <input type="checkbox"/> Install a pressure regulator if water-supply pressure exceeds 80 psi <input type="checkbox"/> Match precipitation rates on sprinkler heads within a hydrozone <input type="checkbox"/> Install anti-drain check valves as needed to minimize or prevent low head drainage <input type="checkbox"/> Use Irrigation Association approved "smart controllers" (with dual- or multiple-programming capability to accommodate a five-day schedule, multiple start times, a percent switch, etc.) along with rain sensors, or use weather-based (ET) controllers

Estimated Cost Considerations		
Element	Water-Conserving Landscapes (10,000 sq. ft.)	Turf Landscapes (10,000 sq. ft.)
Initial Costs per Square Foot of Installing Plant Materials (Except Grading)		
Plant materials	\$1.25 – 1.60/sq. ft.	\$0.40/sq. ft.
Mulch and amendments	\$0.10 – 0.20/sq. ft.	Not required
Irrigation system	\$0.30-0.40/sq. ft.	\$0.40/sq. ft.
Smart irrigation controller	\$200-\$6,000	\$200-\$6,000
Annual Maintenance Cost		
Runoff from overhead irrigation system	Low-pressure systems greatly reduce runoff	Likely
Annual water cost based on annual net ET requirement of 39 inches and water cost of \$2.50/Ccf	\$240 (based on irrigating at 30% of ET)	\$800 (based on irrigating at 100% of ET for cool-season grass)
Mowing	Not required	Required weekly
Irrigation repair	Reduced	Certain
Fertilizer	Considerably reduced	Likely
Weed control	Considerably reduced	Some
Mulch topping	Up to 20% replacement	Not required

The table above provides some comparative estimated-cost information.

Following is a discussion of various landscape elements that may impact water-use efficiency, water quality (runoff), energy use, aesthetics, and a site's microclimate. These issues should be considered in developing landscape standards.

Landscape Design Based upon Functionality

Description of End Use

Appropriate landscape design enhances the attractiveness of a property and is friendly to the property users, while providing these additional benefits:

- reduces green-waste production
- provides shade
- improves air quality by capturing dust
- creates habitat for birds and wildlife
- avoids cost of energy to maintain landscapes and to produce water
- reduces seasonal water demand
- retains stormwater
- reduces maintenance costs

The following principles benefit the landscape-design process:

- shape the land so it captures and holds water from rainfall, irrigation, and runoff from impervious surfaces

- ensure that the landscape soil has enough holding capacity to retain received water (see the subsection “Grading, Runoff, Soil Preparation, and Mulches”).
- choose proper landscape plant material to fit climate and use (see subsection on “Plant Selection”).
- install efficient irrigation equipment (see subsection on “Irrigation Systems”).
- maximize use of on-site water sources, e.g., re-irrigate with runoff or use reclaimed process water; use other sources of reclaimed water where available (see subsection on “Irrigation Systems”).

Site designs need to conform to local stormwater management requirements, such as the following:

- maximize infiltration to promote movement of stormwater downward through soils to remove pollutants and restore surface and groundwater flows
- provide retention
- slow runoff
- minimize impervious land cover
- prohibit dumping of improper materials
- retain pollutants
- collect and convey stormwater or use for irrigation

Explanations of these objectives are provided in the “Grading, Runoff, Soil Preparation, and Mulches” subsection.

Good practices for water conservation are in many cases identical to good stormwater-management practices. One common goal is to shape the land and provide sufficient soil depth to slow runoff and retain the water that falls, in order to maximize infiltration into the soil. In most cases soil that retains water is the most cost-effective rainwater-harvesting technique.

Water-Savings Potential Based upon Functionality of Design

The following practices help maximize water savings:

- Shape the land so it captures and holds water it receives from irrigation, rainfall, and runoff from impervious surfaces. Irrigation water should be retained in the soil. Stormwater can be retained in the soil and impoundments.
- Hydrozones comprise distinct groups of plants designed to have the same watering requirements. Use separate stations to irrigate plants that have been grouped together according to their high, medium, or low water needs. When high- and low-water-use plants are mixed in a hydrozone — an area watered by the same irrigation valve or station — it is impossible to apply the correct amount of water.
- Design water features, e.g., fountains, to recirculate water or use recycled wastewater treated to human-contact standards. See “Pools, Spas, and Fountains.”
- Vegetative strips in parking areas and highway medians and between sidewalks and pavement should be mulched, planted with water-thrifty shrubs, and irrigated with low-pressure systems. Avoid using turf on strips less than eight-feet wide or on slopes greater than 10 percent.
- Adjacent to pavement and other hardscapes, use a mulched border at least two-feet wide comprising shrubs, groundcover, or other landscape treatment that is not spray irrigated. This minimizes runoff from errant sprays of overhead sprinklers.



Trees, Groundcover, and Mulch Enhance a Parking Area and Traffic Island
 (Photo source: C. Pike)

Process or Equipment Alternatives	Water-Savings Potential
Mulched borders adjacent to hardscapes and separating turf areas from hardscapes	Medium
Water features using recirculated or reclaimed water	High
Plant materials grouped in hydrozones	High
Narrow strips planted with water-thrifty shrubs and groundcover and irrigated with low-pressure systems	High

Grading, Runoff, Soil Preparation, and Mulches

Grading

The California Master Gardener Handbook advises: “Sometimes the soil to be landscaped has been amended or modified to construct building foundations or roadways, or to create new physical environments such as hills or lakes. Usually these alterations are performed to engineering standards, not horticultural standards. The discrepancy in the two standards often presents considerable problems in establishing and maintaining woody plant materials. Original grading specifications should be reviewed and considered when subsurface changes could cause soil-structure problems, such as extremes in soil texture, soil pH, pesticides, or phytotoxins.”


Steep slopes (greater than 10 percent) are difficult to irrigate properly and frequently promote irrigation runoff. On the other hand, properly graded swales and berms can assist in retaining water on-site and reducing runoff.

Runoff

Some counties and municipalities may require Stormwater Control Plans and may, therefore, include such language as: “Every application for a development project ... or building permit that is subject to the development runoff requirements in the ... NPDES permit shall be accompanied by a Stormwater Control Plan that meets the criteria cited in the ... County Clean Water Program Stormwater Guidebook.”

Stormwater control plans are submitted with applications for planning and zoning review. The Stormwater Control Plan is to be coordinated and integrated with the site plan, drainage plan, and landscaping.

Stormwater runoff is a concern when landforms are covered with impervious materials. Without the ability to soak into soils and be slowed by vegetation, stormwater collects in large volumes that flow downhill at accelerating speeds over impervious surfaces. This means higher storm-peak flows, potentially contributing to downstream flooding and greater erosion rates.



Relationship between Impervious Cover and Surface Runoff
(FISRWG 1998)

The objectives of stormwater control plans are to minimize potential runoff pollution and runoff flows for the life of the project. The targeted pollutants include those deposited in airborne dust, liquids and dust from automobiles, cleaning solutions (e.g., from food service), litter, and trash.

Post-construction stormwater-control measures can be divided into four categories:

- site design
- source controls
- stormwater treatment
- hydro-modification management

Each category may include landscape measures, depending upon site conditions and design.

Depending upon local conditions, factors such as high clay content, soil susceptibility to liquefaction, soil contamination from prior activities, or seismic activity may require stormwater-control measures to be focused on flow filtration and temporary retention rather than deep percolation.

Description of End Use

Stormwater-control measures that affect landscapes include:

- minimizing land disturbance and preserving high-quality open space
- minimizing impervious surfaces by using narrow streets, driveways, and sidewalks
- using pervious surfaces
- clustering structures and paved surfaces together
- using landscaping as a drainage feature
- building bioretention areas
- extending detention basins
- building infiltration trenches
- using media filters
- employing vegetated buffer strips
- using vegetated swales
- building retention ponds and vaults
- using tree-well filters
- employing flow-through planter boxes

Stormwater Water-Savings Potential

A Mediterranean climate may make stormwater an impractical supply without supplementary irrigation during the dry months. Due to concerns about disease, such as West Nile Virus, some agencies may specify a maximum number of days for standing water, based upon the incubation period of local mosquito species.



Turf Block and Paver Mat (Alameda CCWP, 2006)



An Extended Detention Basin and a Vegetative Swale (Alameda CCWP, 2006)

However, by providing proper shaping of the land and proper soil depth and composition, rainfall will be retained in the soil, minimizing stormwater runoff and keeping the soil moist for later plant use, without aggravating potential mosquito problems. This is also the most cost-effective method for harvesting intermittent rainfall in Mediterranean climates.

Green roofs offer a somewhat controversial opportunity to apply landscape features while retaining precipitation (rain and fog) and saving energy used to cool buildings. The City of Chicago extols their success with green roofs, and Leadership in Energy and Environmental Design (LEED) points may be gained from green roofs. Other authorities point out that vegetation on a roof still needs irrigation during dry periods, so at a minimum, green roofs should be considered a part of the landscape when determining irrigation requirements. At this time, the guidebook withholds any recommendations for green roofs.



Green Roof at Kaiser Facility, Oakland, California (Emeryville, 2005)

Soil Preparation


Soils are mixtures of mineral particles, living and dead organic materials, and pore spaces containing water and air. Soils are formed from weathered rock and organic materials as modified by the actions of climate, living organisms, and positions on the landscape over a period of time. Soil texture affects watering and fertilizing schedules and may determine the kinds of plants that grow.

Soil texture characterizes the size of the mineral particles. Sand particles are large enough to be easily seen by the eye, are irregularly shaped, have lots of pore space, and consequently drain well. Clay soils are flattened, platelike, microscopic particles that pack together closely and can hold the greatest volume of water, although drainage is slow. Silt particles are somewhat larger than clay. Loams are mixtures of all three soil-particle sizes.

Description of End Use

Soil acts as a reservoir that holds air and water for plants. The amount of water available to plants is the difference between the amount of water the soil can hold (field capacity) and the point at which plants can no longer draw water from the soil (wilting point). As shown below, sandy soils hold less water at field capacity than clay soils. However, due to their high surface area to volume ratio, water adheres more tightly to clay soils. Therefore, loam soils have the most available water per foot of soil depth.

Water Available to Plants as a Function of Soil Depth and Texture



(California Master Gardener Handbook)

The deeper the soil profile the greater the amount of water available to plants, to the depth that plant roots extend. New landscapes should have at least six inches of soil for good plant growth and effective irrigation. Adding organic matter can improve the water-holding capacity. Compost can improve soil porosity and water infiltration rates, especially in fine-textured or compacted soils. To avoid horizontal water movement at boundaries of soil layers, mix the soil types together at the boundaries, using techniques such as scarification of the underlying layers, before new topsoil is applied. Water will then move downward providing a deeper soil-moisture reservoir for plants. These and other means of adding soil moisture capacity are effective at capturing rainfall (rainwater harvesting) and in irrigation applications (Lower Colorado River Authority, 2007).

Watering to the plant-root depth creates a healthier, more efficient garden. The mix of sand, clay, and silt dramatically affects irrigation schedules. Water drains through porous sandy soils easily, so small amounts of water need to be applied frequently. Clay soils and slopes require small amounts of water to be applied intermittently, otherwise the water runs off the surface. Adding too much fertilizer may negatively affect irrigation efficiency. Fertilizer adds nutrients soils may lack to promote plant growth (primarily nitrogen, phosphorus, and potassium). The faster a plant grows the more water it will require.

Soil amendments influence plant growth by improving the soil's physical characteristics: the ability to provide nutrients, water, and air to plant roots. Sunset's Western Garden Book advises: be generous

when adding organic amendments. When preparing a new planting bed, spread a three- to four-inch layer of amendment over the soil. Some authorities suggest tilling the amendments into the top four to nine inches; others authorities take a more natural approach without tilling. Around established plantings, add organic material by spreading it over the soil surface as mulch. Earthworms, microorganisms, and water will help mix it into the top layer of soil.

Factors to consider when choosing a soil amendment:

- how long the amendment will last in the soil
- soil texture
- soil salinity and plant sensitivity to salts
- salt content and pH of the amendment
- the impact on beneficial soil microorganisms and fauna

Mulches

Mulches are opaque organic or inert materials applied in layers on top of bare soil and around trees and shrubs. The purpose of mulches is to reduce water evaporation, prevent weeds by stopping photosynthesis, buffer soil temperatures, protect irrigation systems from harmful solar rays, and give the garden a finished look. Mulch should be porous to air and water. The coarser the material, the thicker the mulch layer needs to be. Organic mulch, such as shredded cedar bark or compost, will also amend the soil as it decomposes. To prevent crown rot and other problems, avoid applying mulch up against the main stem or trunk of a plant. Mulch is reported to reduce watering demand by 40 to 70 percent.

Alternative irrigation techniques should be used with plants surrounded by mulch. Apply water with bubblers, soaker hoses, or drip lines beneath the mulch to the plant-root areas. Sprinklers are inefficient methods of applying water to mulched areas, since mulch materials restrict water flow and absorb large amounts of water before it is able to reach the soil.

Water-Savings Potential

Example: a 10,000 square foot area planted in shrubs and trees with a four-inch layer of mulch. Mulch substantially reduces labor for weeding, but may need as much as 20 percent replacement each year, as it deteriorates into beneficial organic material for the soil.

- Material Capital Costs: Approximately 100 cu. yd. @ \$10/cu. yd. = \$1,000 (prices actually range from \$0 to \$40/cu. yd.). Add installation labor @ 1 hour/cu. yd. @ \$10/hour = \$1,000. Total cost of installed mulch = \$2,000.
- Estimated Material Life: Five years.
- Water and Energy Savings: Assume: 50 percent water savings due to mulch, traditional shrubs, and ground cover ($K_s=0.8$). Dry season (May through October) ETo of 39 inches; plant species using water at a rate of 80 percent of ETo.

Water Savings Using Mulch		
	With Mulch	Without Mulch
Dry season water use in AF	0.371	0.742
Value of irrigation water	\$381	\$763

Maintenance without mulch requires periodic weed-spraying and weed-removal. The mulch requires as much as 20 percent replacement annually, as the organic material deteriorates into soil amendments. The mulch provides an annual benefit of approximately \$75.

Landscape Element	Water-Savings Potential
Apply mulches to non-turf areas	High
Use soil amendments for good plant health and to minimize watering needs	Medium

Plant Selection

Effective use of plants can soften, mitigate, screen, and enhance a property. Turf is appropriate for sports, recreation, walking, sitting, and picnicking. Trees screen and shade; shrubs and groundcovers screen and provide color. They all help to control erosion. Good design will provide these benefits, consume low amounts of water, and avoid difficult maintenance, as well (Ash 1998).

Select plants that are in keeping with the site's "sense of place." Each location is part of a larger region with its own soils, topography, weather patterns, and microclimates.



Photo source: C. Pike

Choose native or very-well-adapted plants that will thrive on less water in summer. Various plants are adapted to summer fog, cool evenings, or sunny baking-hot days. Many plants are available to create a colorful, interesting, and lush garden, well-suited to the climates and soils found in each region of the country.

When selecting plant species, consider their size at maturity. Avoid the temptation to install shrubs and trees too close together. This may initially fill the space, but will eventually result in crowding, with the avoidable expense of removing shrubs or trees as well as disposing of the solid waste.

Some communities and properties require that tree shade be provided from islands in parking lots. Select varieties that do not drop annoying litter during pollination or shed limbs during summer heat.

Description of End Use

For specific-use landscapes, such as parking lot islands, streetscapes, medians, or buffers, non-turf landscapes are recommended for their ability to thrive on drip or subsurface irrigation. For athletic fields, golf courses, parks, and large recreational areas, unshaded turf is typically required. Where turf is desired, artificial turf should be considered. This can also be used for mixed landscapes.

Water-Savings Potential

Perennials and shrubs require less frequent watering than lawns. For areas where natural turf is desired, select grass species that use less water.

Water-Thrifty Turf Varieties		
Warm-Season Grasses Ks = 60% of ETo	Cool-Season Grasses Ks = 80% of ETo	
Bermudagrass	Annual bluegrass	Kentucky bluegrass
Kikuyugrass	Annual ryegrass	Meadow fescue
Seashore paspalum	Colonial bentgrass	Perennial ryegrass
St. Augustine	Hard fescue	Red fescue
	Highland bentgrass	Tough-stalked bluegrass

Process or Equipment Alternatives	Water-Savings Potential
Use water-thrifty shrubs, trees, and ground cover instead of turf	High
Use water-thrifty shrubs, trees, and ground cover instead of high water-use shrubs, trees, and ground cover	High
Use warm-season instead of cool-season grasses for turf	Medium

Cost-Effectiveness Analysis

- Plant-Material Capital Costs: Installed turf cost (excluding soil preparation and grading) is estimated at \$0.40 per square foot or \$4,000 for a 10,000-square-foot landscape (2007 costs, which can vary from region to region). Non-water-thrifty shrubs and ground covers may cost approximately 15 percent less than the \$1.60 per square foot for water-thrifty species, primarily due to their availability from nurseries.
- Estimated Plant-Material Life: Ten years.
- Water and Energy Savings: See table below.

The following table compares water use for water-thrifty plants with that of water-thirsty plants at 80 percent of ETo and 100 percent ETo; 80 percent ETo is recommended as an upper limit by the CUWCC Landscape Irrigation Taskforce. The calculation uses irrigation efficiencies of 80 percent (a desirable goal) and 65 percent (a more typical performance).

Average Irrigation Season (May – October) Water Use and Water Costs 10,000 square foot area					
Plant type		Budget 80% ET		Budget 100% ET	
	Irrigation System Efficiency (percent)	Gallons/AF	Water Fees*	Gallons/AF	Water Fees*
Low-water-using plants	80	72,500 0.223	\$230	90,600 0.278	\$286
Low-water-using plants	65	89,280 0.274	\$282	111,600 0.342	\$352
Low-water-using plants with mulch	80	36,270 0.111	\$114	45,340 0.139	\$143
Low-water-using plants with mulch	65	44,640 0.137	\$141	55,800 0.171	\$176
Warm-season grasses	80	145,000 0.445	\$458	181,300 0.557	\$572
Warm-season grasses	65	178,560 0.548	\$563	223,200 0.685	\$704
Turf with cool-season grasses	80	193,400 0.594	\$610	241,800 0.742	\$763
Turf with cool-season grasses	65	238,080 0.731	\$751	297,600 0.913	\$939

**Irrigated landscapes that are metered independently from interior uses are spared fees for wastewater services. This table assumes a May to October ETo of 39 inches.*

Because turf is mowed frequently, may require more fertilizer than shrubs, and needs other maintenance procedures, the annual maintenance cost of turf is approximately 25 to 30 percent higher than that for permanent shrubs and ground cover.

Incremental Cost per AF of Water-Efficient Plant Materials*

	Present Value Benefit of Water Savings	Benefit /AF over Plant Lifetime
Low-water-using shrubs vs. thirsty shrubs	\$2,945	\$794
Warm-season grasses vs. thirsty grasses	\$1,178	\$794
Low-water-using shrubs vs. thirsty grasses	\$4,124	\$794

**For simplicity, maintenance costs, such as weeding and mowing, are excluded.*

Irrigation Systems

Irrigation systems replace water in the soil that is used by shrubs, trees, and grass, where natural moisture is inadequate for the intended landscape. Without regard to the type of landscape, the primary guideline for landscape irrigation design is to avoid over-watering by applying:

- the **right amount** of water
- to the **right place**
- at the **right time**

The proper design of an irrigation system takes into account:

- types of plants and their spatial distribution
- slope, soils, and soil amendments
- climate factors, such as wind and ET rates
- zero runoff goal from the area to be irrigated
- adjacent structures, features, and hardscapes

Description of End Use


To replace the soil moisture, an irrigation system receives water from a source and distributes it to plants when desired.

Irrigation-System Components

Typical components of irrigation systems include:

- water meter: measures the volume of water entering the system
- backflow prevention device: prevents potentially contaminated water from an irrigation system from flowing into a potable-water system
- pressure regulator: controls water pressure within set limits
- pressure reducer: reduces water pressure to desired range
- controller: regulates the irrigation cycles to activate the control valves at the times and days selected
- soil moisture sensor: installed at the root zone at strategic locations representing the irrigation zone; signals the controller if irrigation cycles may be omitted
- rain sensor: detects recent rainfall and signals the controller if irrigation cycles may be omitted
- valve: allows water flow when actuated by controller
- anti-drain check valve: prevents water loss from sprinklers or emitters at low spots in the irrigation system
- sprinkler head: emits streams of water through the air to plants
- filter: removes from water oversized particles that might clog emitters
- bubbler: head that emits flows short distances at 0.25-2 gpm
- drip emitter: low-pressure device that emits water drops at rates of 0.5 to 2 gph
- micro-spray: low-pressure device that sprays water a short distance at flows of .5 to 5 gph
- drip or soaker line: tubing that emits water along its length
- zone: a portion of the landscape with the same irrigation requirements

Block Diagram of an Irrigation System



Source: C. Pike


Alternative Irrigation Sources

On-site water may be used as an irrigation source if it is properly separated from potable supplies by backflow preventers or similar devices. Each alternative source requires storage vessels, plumbing, and sometimes filters and pumps to move stored water to the irrigation system. Some alternative sources are:

- air-conditioning condensate
- swimming-pool-filter backwash water
- cooling-tower blow-down water (if water quality will not harm plants and meets local code)
- fountain drain water
- rainwater and stormwater harvested from buildings and hardscapes
- treated gray water from interior and process uses

Irrigation Scheduling

Water needs to be delivered to plants when they need it. Plant water requirements, ET, reflect both evaporation from the soil and plant surfaces and transpiration through plant surfaces. ET varies from one site to another and changes constantly with the weather, especially sunshine, wind, and rainfall. The chart below displays typical 100 percent ET curves for any given year. Irrigation may partially or fully replace natural precipitation during all but the winter months in a typical year for most regions of the country. The timing and quantities of water deliveries are the important goals in proper irrigation scheduling.



Source: CADWR & C. Pike

An important corollary to irrigation scheduling is applying only the amount of water the soil can absorb without runoff. The duration of irrigation depends upon the discharge capacity of the emitters, slope, vegetation density, soil type, and moisture depletion. Steeper slopes and clay soils require multiple short run times. For example, three five-minute applications with an hour between each will allow the soil to absorb more of the applied water than one fifteen-minute application.

Flat ground with sandy soils may allow longer irrigation applications. Whether the irrigation applications are short or long, the total water volume delivered to the root zones should be adequate to restore depleted soil moisture without wasteful runoff.

Water-Savings Potential

Metering and billing deliveries to irrigated systems separately from interior uses are incentives to improve irrigation efficiency.

Smart Controllers (also known as ET controllers, weather-based controllers, smart sprinkler-controllers, and water-smart irrigation-controllers) use weather conditions, current and historic ET, soil-moisture levels, and other factors to adapt water applications to meet the actual needs of plants. The Irrigation Association states that smart controllers may reduce water by 20 to 40 percent annually.

Generally, there are two types of smart controllers (CUWCC, 2006):

- controllers with the irrigation schedule pre-programmed for local conditions using historical weather data, which also permit adjustments in the irrigation schedule with real-time measurements of local factors using precipitation and temperature sensors
- signal-based controllers that receive daily weather data via radio, telephone, cable, cellular, Internet, or pager technology to establish irrigation schedules

Distribution uniformity (DU) measures how evenly water is applied to the landscape. For overhead sprays, the irrigation system should be designed for head-to-head coverage. Ideally, equal amounts of water are applied to each square foot of the zone being irrigated, resulting in a distribution uniformity of 100 percent. However, many factors may result in a lower distribution uniformity, such as improper sprinkler-head spacing, blocked or clogged sprinkler heads, mismatched sprinkler nozzles, or tilted sprinkler heads. DU is evaluated by collecting water in evenly spaced cups from a complete irrigation cycle per zone. The value is typically calculated by dividing the average of the lower quartile of samples by the average of all the samples. Proper system design and installation, as well as regular maintenance, are necessary to achieve high DU. DU is evaluated at least once annually on all well-maintained systems.

Matched precipitation rates of sprinklers — the water volume applied per unit time, for example, gallons per minute — help achieve uniform distribution.

Water budgets compare the amount of water needed by the landscape to the amount of water actually applied. The CUWCC Landscape Irrigation Task Force recommends a site water budget that does not exceed 80 percent of ETo. Water bills should report the customer's water budget and highlight excessive water use to call attention to the need for irrigation-system evaluation.

A site water budget is the sum of the water budgets for each of the zones served by the irrigation system. The budget calculation is:

$$0.8 \times (ET \times K_s \times K_m \times K_d \times Area) / (\text{Irrigation Efficiency})$$

Where:

- ET is measured in inches of water per day, week, month, or year. The amount of irrigation water equals ET minus the effective rainfall.
- Crop or plant coefficient (Ks) is the relative ET for specific plant species. [Many plants do not have specific plant coefficients calculated for them, but are grouped together by horticulturists. A good resource for coefficients for plants other than turfgrass is WUCOLS, produced by the University of California Cooperative Extension (2000).]
- Area is the surface area of the irrigated landscape in square feet.
- Irrigation Efficiency (IE) is the percentage of applied irrigation water actually retained in the root zone. Irrigation efficiency decreases when water is lost due to runoff, when wind evaporates the water as it sprays from emitters, and when water sinks below the root zone due to deep percolation. Sprinkler efficiency may be as high as 70 percent. Drip irrigation systems

are rated at 85 to 90 percent efficiency. Irrigation efficiencies of 80 percent are usually considered good.

- Km is the microclimate factor, comparing local conditions to a standard ET reference site.
- Kd is canopy density, the percent of ground covered by foliage.

Process or Equipment Alternatives	Water-Savings Potential
Water budgets	Medium
Rain-sensing devices on controllers	Low-Medium
Smart controllers	Medium
Matched-precipitation-rate sprinklers	Medium
Low-pressure irrigation systems	High
Anti-drain check-valves	Low-Medium

Cost-Effectiveness Analysis

- **Equipment Capital Costs:** Cost of a low-pressure system is approximately 2/3 that of a high-pressure sprinkler system with the same controller. Costs vary depending upon the types of plants selected and the irrigation systems installed. A low-pressure drip system with water-thrifty plants may cost only 70 percent of a turf and sprinkler system (Santa Monica). Elsewhere water-efficient plants and sprinkler systems may cost \$1.60 per square foot versus \$0.80 per square foot for turf (Ash).
- **Estimated Equipment Life:** Ten years.
- **Water and Energy Savings:** A low-pressure system can be 15 percent more efficient in delivering the right amount of water to the right place at the right time. The annual water-cost saving of a low-pressure system, compared with a sprinkler system, is \$135, given plants of the same Ks factor. Drip systems can be 90 percent efficient versus 75 percent efficiency for overhead sprinklers. For a 10,000-square-foot site, the same plant materials, and water costing \$2.50 per Ccf, the low-pressure system saves \$135 per year in water costs (0.65 AF for drip versus 0.79 AF for sprinklers).
- **Incremental Cost per AF of Efficient Equipment:** Lifetime water savings (equals annual water savings × life of systems) due just to the irrigation equipment is approximately 1.3 AF. Since the low-pressure system is less expensive than the sprinkler system, the payback for the less-expensive system is immediate. The annual operating and repair costs (water + maintenance — fertilizing, mowing, mulch replacement, irrigation parts repair/replacement, etc.) of the low-pressure system are less than for the sprinkler system by approximately \$240, resulting in per AF benefit of \$2,400 for the low-pressure system versus the sprinkler system.

References

Water-Efficient Landscape Guidelines

Bennett, R., and Hazinski, H. 1993. **Water-Efficient Landscape Guidelines**. AWWA.

California Urban Water Conservation Council. 2005. **Water Smart Landscapes for California**. Landscape Taskforce Findings, Recommendations and Actions AB 271.

City of Santa Cruz. 2001. **Water-Efficient Landscaping**. Landscaping Ordinance, Chapter 16.16.

Other References

Alameda Countywide Clean Water Program. August 31, 2006. **C.3 Stormwater Technical Guidance: A Handbook for Developers, Builders and Project Applicants**, version 1.0. www.eoainc.com/download/ACCWP_Tech_guidance-black_text.pdf.

American Society of Landscape Architects. 2007. www.asla.org/nonmembers/publicrelations/factsheetpr.htm.

Ash, Tom. 1998. **Landscape Management for Water Savings**.

California Stormwater Quality Association. 2003. California Storm Water Quality Association Storm Water BMP Handbooks for Industrial Activity, Construction, Municipal Operations and New Development/Redevelopment. www.cabmphandbooks.org/Development.asp.

California Urban Water Conservation Council. August 2006. **Interim Process Evaluation Report on Prop. 13 Smart Controller Programs**.

City of Santa Monica. August 2006. **Garden/Garden: A Comparison of Native and Traditional Gardens in Santa Monica**.

City of Santa Monica. March 2006. **Guide to Successful Drip Irrigation for Landscape Professionals**.

Colorado State University Cooperative Extension. **Choosing a Soil Amendment**. No. 07235. www.ext.colostate.edu/PUBS/GARDEN/07235.html.

Contra Costa County Clean Water Program. December 2006. **Stormwater Quality Requirements for Development Applications**.

East Bay Municipal Utility District. 2004. **Plants and Landscapes for Summer-Dry Climates of the San Francisco Bay Region**.

Federal Interagency Stream Restoration Working Group (FISRWG). October 1998. **Stream Corridor Restoration: Principles, Processes, and Practices**.

GardenGuides.com. **Guide to Selecting a Garden Mulch**. www.gardenguides.com/how-to/tipstechniques/composting/mulch-noframe.asp.

Irrigation Association. **Smart Water Application Technologies**. www.irrigation.org/SWAT/Industry/.

Lower Colorado River Authority. 2007. **LCRA Soil Depth and Soil Amendment Specifications—Background**.

Metro Water Conservation Inc. December 2004. **Yield and Reliability Demonstrated in Xeriscape Final Report**.

New Mexico Office of the State Engineer. 1999. **A Water Conservation Guide for Commercial institutional and Industrial Users**.

Nilsson Associates. **Labor Time Data Handbook**. www.nilssonbooks.com.

San Francisco Bay Regional Water Quality Control Board. Stormwater Program. www.waterboards.ca.gov/sanfranciscobay/programs.html#stormwater.

State of California. **Water Conservation in Landscaping Act**: Assembly *Bill 1881*. September 2006, www.leginfo.ca.gov.

StopWaste.org. **Bay-Friendly Landscape Guidelines**.

Sunset Publishing Corporation. 2001. **Western Garden Book**.

University of California. Agriculture and Natural Resources. 2002. **California Master Gardener Handbook**, publication 3382.

University of California Cooperative Extension. 2000. **A Guide to Estimating Irrigation Water Needs of Landscape Plantings in California**. *WUCOLS*.

Western Policy Research. August 2004. **LADWP Weather-Based Irrigation Controller Pilot Study**.

This page intentionally left blank.

Laundries & Dry-Cleaning Operations

Commercial laundry operations cover a range of applications from laundromats and apartment common laundry-rooms to on-premises laundries for institutions and commercial operations, such as hotels, nursing homes, hospitals, athletic facilities, and prisons. Industrial laundries offer services for the same set of users as on-premises operations, as well as uniform, diaper, and linen services. Dry-cleaning establishments often have on-premises laundry equipment, as well.

Clothes-washing equipment includes:

- top-loading (now being phased out)
- front-loading
- tunnel washers

Methods considered to replace perchloroethylene dry-cleaning operations include:

- supercritical carbon-dioxide technologies
- silicon-based compounds
- wet-cleaning methods similar to front-loading washers

Ways to reduce water consumption by conventional laundries vary from the use of more efficient equipment to water recycling and ozone systems. For dry-cleaning operations, carbon-dioxide and silicon-based technologies nearly eliminate water use as compared with the alternative of wet cleaning.

Description of End Use

In this section the water-use characteristics of each major laundry and dry-cleaning technology are discussed. These include water-saving technologies such as water recycling and ozone equipment.

Coin-operated and multi-family laundries have historically used clothes washers that are similar to home-laundry equipment. Top-load, soft-mount (not bolted to the floor) washers have dominated the market. With the passage of EPACT 2005, soft-mount machines with a horizontal axis and 3.5 cubic feet of volume and top-loading machines with 4.0 cubic feet of volume are regulated for the first time. They must achieve a water factor (WF) of 9.5 gallons or less per cubic foot of washer capacity and a modified energy factor (MEF) of 1.26. As of July 1, 2007, the WF is 8.0 or less, and the MEF is 1.72, according to Energy Star.

Based upon information obtained from five of the major manufacturers of laundromat equipment, it appears that most laundromats are switching to hard-mount (bolted to the floor) equipment and, increasingly, are installing multi-load-capacity washers. The capacity of multi-load washers can exceed 80 pounds per load as compared with less than 20 for conventional equipment. Standards for multi-load equipment and single-load hard-mount equipment were not included

Laundry and dry cleaning operations range from neighborhood coin-operated facilities to huge industrial laundries, such as those found in hotels and hospitals. Dry cleaning operations are undergoing major changes to their processes, due to concerns about chemicals and air quality.

in EPACT 2005. This multi-load equipment is basically the same as used by commercial on-premises and industrial laundries. Multi-load equipment is designed with options for many possible settings and cycles to accommodate a range of washing requirements with large variations in water use. The manufacturer or equipment provider (route operator) must preset the controls for the washing requirement prior to installation to avoid excessive water use.



Wascomat Solid-mount W Model
(above)



**Speed Queen SWFT71 Front-load
Laundromat Washer**

The manufacturers report that a large percentage of multi-family laundry-room equipment will continue to be of the smaller, single-load soft-mount type that is regulated.

Water use by multi-load machines depends upon how the controls are set. All multi-load washers can be set to operate at a number of cycles, including flush, wash, bleach, rinse, scour, and sizing cycles. Also, the water levels can be set differently for each cycle, so water use varies greatly depending upon the setting.



In a detailed study of actual operating laundromats in San Diego, California, in 2006, water use for horizontal-axis machines after a retrofit ranged from 5.2 gallons per cubic foot to as high as 12.1 gallons per cubic foot (Water Management, Inc., Western Policy Research, Koeller and Company). This illustrates the critical need to specify that washers be preset to meet the WF, which can be done by the factory or the route operator who leases the equipment. This equipment can meet a 9.5 gallons per cubic foot water factor if set properly, so it is important for the route operator to know the desired level of water use.

Horizontal-axis machines also reduce energy use, since these front-loaders reduce both hot- and cold-water use. A survey of manufacturers shows that hot water comprises only about 25 percent of water used by laundromat equipment. Switching to horizontal-axis machines does not change this ratio, but the reduction in overall water use — thus the gallons of hot water per pound of laundry — can be reduced by 19 to 29 percent (Water Management, Inc., Western Policy Research, Koeller and Company).


On-Premises Laundries (OPL) use washer-extractors identical to the multi-load equipment used in laundromats, except they have no coin boxes and can be much larger. Load capacities range from 30 to as much as 800 pounds. Such washer-extractors are designed to wash everything from relatively clean hotel towels and bedding to heavily soiled items from nursing homes and commercial kitchens. All equipment in this category uses the horizontal configuration and is, therefore, relatively efficient. Examples of OPL applications include prisons, hotels, hospitals, athletic facilities, food and beverage manufacturers, and uniform washing for businesses. Typical water use for washer-extractor machines ranges from 2 to 4 gallons per pound of laundry washed. Because the items being washed vary greatly, the equipment needs to be adjustable. A study done for the California Urban Water Conservation Council (Riesenberger and Koeller, 2005) illustrates these points. The tables following show the amount of laundry produced by each of the most common OPL operations and laundry characteristics based upon degree of soiling.

On-Premises Laundry Production in Common Operations

Type of Operation	Pounds/Person/Day	Pounds/Room/Day
Hospitals		25
Nursing Homes		25
Motels		23
Hotels		36
University Dorms	20	
Jails	10	
Prisons	12	

After (Riesenberger and Koeller, 2005)

The level of soiling strongly influences the amount of water required, because of the number of cycles needed to wash the items and water levels needed for each cycle. This is illustrated in the following table:



Water Demand Based upon Use of a 400-Pound Braun Washer Extractor

Soiling Level	Heavy	Medium	Light
Cycle	Bed Pads	Terry Cloth	Sheets
Flush	290	290	94
Wash	94	94	94
Wash	94		
Bleach/Rinse	134	134	134
Rinse	134	134	134
Rinse	134	134	134
Rinse	134		
Finish	114	114	114
TOTAL	1128	900	704

After (Riesenberger and Koeller, 2005)

Water Reuse/Recycling and Ozone Systems. Two technologies, water reuse/recycling and ozone, can reduce water use and wastewater volumes. These can also reduce pretreatment costs or requirements and energy use. The first are systems that recycle a portion, or all, of the water for reuse in the next wash. Many companies offer versions of this equipment, and choosing a system that fits a specific laundry requires some analysis. Some companies even offer equipment designed for laundromat operations. Recycle and reuse systems also save energy since the water from the laundry operation is already warm. In one study (*Laundry Today*, 2004) wastewater recovery was determined to be the most promising source of energy conservation in laundry operations.

A simple recycle system recovers the discharge from the final rinse in a multi-cycle operation for use in the first flush or first rinse of the next cycle. More complex systems recover more than 85 percent of the water for reuse. Simple systems rarely incorporate any type of treatment, since the final rinse water tends to be very clean. These systems are limited to a 10 to 35 percent savings (*Laundry Today*, 2005). However, to achieve consistently higher recovery rates, used wash water must be treated to some extent

before reuse. Ecolab's Aquamiser and the Aqua 360 systems are examples. Water is filtered to remove lint and dirt, then reheated and sent for reuse. More complete systems, such as Norchem and AquaRecycle, process wash water to the point that it can be recycled for use in all cycles of the washing process. In the example of the AquaRecycle System below, water is first passed through a lint shaker to remove lint and large particles, then filtered to remove particulates. Then it passes through two filters that remove oil and grease, then soaps and organics. Ozone is added to remove additional organics, and the water is passed through an ultraviolet light system for disinfection. These systems can recycle up to 90 percent of wastewater.

Ozone is gaining wider acceptance in the industry. Ozone is simply three oxygen atoms combined into one unstable molecule, O₃. Because of the short-lived nature of the gas, ozone is always produced on-site in a generator that uses the oxygen molecules in the air, which comprise two oxygen atoms — O₂. The oxygen is passed through an electric field to produce ozone. Ozone is a powerful oxidant that reacts with dirt and organic material to oxidize it. It is also an excellent disinfectant and whitener that reacts with odors, stains, and other organic material in the wash. Ozone is quickly converted back to oxygen gas in the washing process. Unlike ozone in the upper atmosphere, it lasts for only a short time in laundry applications.

With ozone, water temperatures can be reduced, since it works best at around 80° F. This significantly reduces energy use. It also allows for reduced use of detergents and chemicals, so less rinsing is needed thus less water. Ozone systems work well on lightly soiled clothes. For heavily soiled laundry, conventional wet methods with detergent and hot water work best.


The following table presents results of actual tests conducted to evaluate three specific types of equipment for water recycling and ozone. As these results show, the Aqua 360 system saved approximately one-third of the water and energy used, while the more aggressive AquaRecycle system accomplished an 80 percent water savings and an energy savings of over 50 percent. Ozone systems fared less well on water savings, at only about 15 percent, but had a significant energy savings of about 75 percent.

Summary of Savings by Technology and Wash Classification for a 400-Pound Braun Washer

Technology	Soil Class	"Before"		Savings		"After"		Unit Savings	
		Gal/lb	Btu/lb	Water	Energy	Gal/lb	Btu/lb	Gal/lb	Btu/lb
Aqua 360	Heavy	3.22	2570	36%	34%	1.15	1695	1.15	875
Aqua 360	Medium	2.57	1990	32%	30%	0.88	1399	0.88	591
Aqua 360	Light	2.07	1798	36%	20%	0.74	1447	0.74	351
AquaRecycle	Heavy	3.22	2570	84%	50%	2.7	1292	2.7	1278
AquaRecycle	Medium	2.57	1990	70%	57%	1.97	849	1.97	1141
AquaRecycle	Light	2.02	1798	80%	51%	1.61	883	1.61	915
Ozone	Medium	2.57	1990	9%	75%	0.23	502	0.23	1488
Ozone	Light	2.02	1798	11%	76%	0.22	427	0.22	1364

(Riesenberger and Koeller, 2005)

AquaRecycle System



Industrial laundries comprise a special subset of commercial laundries. These are the very large operations that typically offer services to institutional users such as hospitals and prisons and commercial enterprises such as hotels and restaurants. They often offer uniform and linen leasing, cleaning, and related functions. Industrial laundries use horizontal washer extractors identical to those used by OPL operations and also large-volume equipment called tunnel washers. Typical water-use rates range from less than one gallon per pound of laundry to around two gallons. Tunnel washers are very expensive and typically not justified unless the laundry is washing 800 pounds of laundry an hour or more (Pellerin Milnor Corp.).

Dry cleaning is undergoing major restructuring as the use of perchloroethylene as a dry-cleaning agent is phased out due to air-quality concerns. The three replacement technologies are wet cleaning, basically a laundry operation that uses water as the cleaning agent just like a washer; silicon-based technology, which can be used in some existing dry-cleaning equipment that currently uses perchloroethylene; and supercritical carbon dioxide, a new, innovative method of cleaning. The latter two technologies consume no water, so long as air cooling is used in the process-fluid operations.

Water-Savings Potential

EPACT 2005 set the standard for single-load commercial washers that are soft mounted, therefore, states and cities are preempted from setting more stringent standards for this class of machines. However, there are more efficient single-load washers on the market, and a water factor of 8.5 or less could be promoted, though not required.

Since there is no federal standard for single-load washers that are hard mounted or any of the multi-load washers, states and cities can set local standards. A minimum standard WF would be 9.5, but there are enough single-load hard-mount models available to support a local WF standard of between 8 and 8.5.

Multi-load machines can use as much as 12 gallons per cubic foot and range in size from 4 to 12 cubic feet. Water savings of 5 to 20 gallons a load can be achieved by having a local standard of 9.5 gallons per cubic foot.

Tunnel washers can cut water use per pound of laundry by 30 to 60 percent.

Water-recycling equipment can recycle from 10 to 90 percent of the wash water, depending upon the level of treatment provided, and conserves energy by recycling warm water. Ozone equipment reduces water use by 10 to 25 percent, but can also significantly reduce energy and chemical use.

Among the replacements for conventional dry cleaning, the wet-cleaning method uses washer equipment almost identical to normal horizontal washers and uses water in the process. Volumes per cubic foot are lower than those for conventional washer operations, but water is still used. The silicon-based and carbon-dioxide systems do not use water.

Cost-Effectiveness Analysis

Cost analysis considers many variables. Hard-mount equipment is slightly less costly than soft-mount equipment of the same capacity, because it does not need the suspension equipment to allow for high gravity-forced spin speeds. Hard-mount systems can also take advantage of gravity dumping of wash water. These cost differences are small in comparison to overall costs.

Tunnel washers cost hundreds of thousands of dollars, but are designed for efficient washing of large volumes of laundry with lower energy and half the water use. To be cost-effective, most manufacturers recommend that the throughput be in excess of 800 pounds an hour.

To make recycling systems economically viable, the combined water and wastewater costs generally have to be greater than \$4 per thousand gallons.

The AquaRecycle system costs about \$100,000 for a system capable of recycling 15 gpm and more than \$330,000 for a system capable of recycling 250 gpm. This equals about \$12 per nominal pound of capacity. The AquaTex 360 costs slightly less, about \$9.50 per nominal pound of capacity. Ozone systems cost from \$10,000 to \$45,000 per unit, depending upon size.

Recommendations

Proven Practices for Superior Performance

- Require all single-load hard-mount laundromat or other coin- and card-operated machines to have a WF of 8.0 or less.
- Require all multi-load coin- and card-operated machines to have a WF of 9.5 or less and be installed with proper settings to achieve the required WF.

Additional Practices That Achieve Significant Savings

- Promote a WF of 8.0 or less for single-load soft-mount washers.
- Encourage the use of recycle/reuse or ozone equipment when feasible.
- Encourage the use of tunnel washers wherever laundry volume is sufficient.
- Encourage the use of non-wet dry-cleaning.

References

“Energy Utilization.” **Laundry Today**. July/August 2004.

Pellerin Milnor Corp. www.milnor.com/.

Riesenberger, James, and Koeller, John. November 2005. **Commercial Laundry Facilities**.

San Diego Water Authority, Water Management, Inc., Western Policy Research, and Koeller and Company. 2006 **Report on the Monitoring and Assessment of Water Savings from the Coin-Operated Multi-Load Clothes Washers Voucher Initiative Program**.

“Slash Utility Consumption.” **Laundry Today**. July/August 2005, p. 12.

Medical Facilities & Laboratories

Dental and doctors' offices can be very-low water-use facilities if the correct equipment is used. Large general hospitals are much more of a challenge, since many processes in these facilities use water. Hospital water use ranges from 250 to 800 gallons per bed (Marutore). There is significant opportunity in this industry to design more water-efficient facilities. Laboratories present a further opportunity for water efficiency.

This section examines the following types of facilities:

- clinics
- hospitals
- dental offices
- medical laboratories
- veterinary hospitals and clinics
- research and analytical laboratories
- industrial and commercial laboratories
- operations using similar equipment

Medical facilities and laboratories have certain water uses in common with other businesses. These include normal office uses and, in the case of hospitals, operations that closely resemble those of a hotel, with its food-service, laundry, boiler, fire-plumbing systems, air-conditioning, and cooling-tower operations. Beyond that, medical facilities and laboratories have a number of unique water-using activities, including:

- vacuum systems
- medical air and compressor equipment
- sterilizers and central sterile operations
- water-cooled laboratory and therapeutic equipment
- laboratory hood scrubbers
- X-ray equipment and film developers
- water-treatment systems for kidney dialysis and laboratory water
- therapeutic baths and treatments

This section examines the first five of these technologies in detail. Water-savings potential for X-ray equipment is significant and is covered in the section, "Photo and Film Processing." Water-conservation techniques for water-treatment equipment are described in the section, "Water Treatment."

Description of End Use

Vacuum systems are used to remove liquid waste or produce a vacuum to maintain low pressure or evacuate a vessel. These range from the suction devices used by dentists and surgeons to remove body fluids to large surgical-unit vacuum pumps that remove gases used for anesthesia. Most major medical facilities also

The advancement of technologies has contributed greatly to water conservation in medical facilities and laboratories.

have vacuum systems available in every patient room. This means the size of these systems varies significantly also.

The technologies commonly employed include:

- liquid-ring pumps
- dry pumps (vane, piston, non-lubricated)
- claw
- rotary pumps
- scroll pumps



Bulldog QT E-Series Dry Vacuum Pump for Dental Clinics

Liquid-ring pumps were the mainstay of medical and dental vacuum systems until recently. They use a closed impeller that is sealed with water to form the vacuum. The water acts as both a seal and a once-through cooling system. Water requirements are typically in the range of 0.5 to 1.0 gpm per hp.

With rising utility costs there has been a significant shift to the use of dry vacuum systems. For dental offices, pumps range from 1.0 to 4.0 hp, while medical-facility central-vacuum systems can be 5.0 to 20.0 hp. Therefore, in dental offices liquid-ring pumps can use from 0.5 to 4.0 gpm and in medical facilities, as much as 20 gpm. Such systems also require plumbing with a water source and backflow preventers.

In contrast, dry systems, such as piston, vane, and non-lubricated pumps, do not require water to form the seal for the pump. Some larger dry pumps, however, require water for cooling. Dry pumps are often more energy efficient. Since they have to pump only air and not water also, their energy use is typically two-thirds to half that of liquid-ring pumps for the same amount of air pumped.

In some laboratory and medical applications, if high concentrations of oxidative gases are present, either a non-lubricated dry pump or a liquid-ring pump must be used so the gases don't react with the oils. Non-lubricated dry pumps do not use water, are more energy-efficient, and should be used in all cases.

Medical air and compressor equipment is used for a multitude of purposes in most dental and medical facilities. The only water use associated with this type of equipment is for cooling, done with once-through cooling, a radiator-type system, or a closed-loop system, such as a cooling tower or chilled-water loop. Many air compressors today are air-cooled. For water efficiency, use air-cooled or closed-loop systems.

Sterilizers and central sterile operations are found in all medical facilities. The purpose of a sterilizer (sometimes called an autoclave) is to kill pathogens on instruments and equipment used for medical procedures and surgery. Both steam and chemical sterilizers are used, depending upon the materials being sterilized. Chemical sterilization is used for instruments that are sensitive to heat, such as plastic and rubber products, and for instruments such as endoscopes. Steam is used for everything else.

Chemical sterilization has seen dramatic changes in recent years as ethylene oxide (EO) or glutaraldehyde (GA) systems are replaced with non-polluting venturi vacuum systems. Hydrogen peroxide has emerged as one of the most commonly used techniques. Unlike the EO and GA systems, peroxide systems can use mechanical vacuum pumps that use no water. It is important to ensure that mechanical vacuum systems are used (Sterrad).

Steam sterilizers (autoclaves) kill harmful pathogens with live steam that is fed into the equipment's pressure chamber in which instruments and equipment have been placed. There are three major classes of steam sterilizers:

- table-top and stand-mounted
- gravity
- vacuum

Table-top and stand-mounted units use a small reservoir of water and electric heat to produce steam. They tend to be both water- and energy-efficient, but are not large enough for the high rate of production needed in major medical facilities.

Large hospitals, surgical and delivery facilities, and central sterile facilities must use large steam autoclaves fed by the facilities' boiler systems. The live steam injected into the pressure chamber is held for a period of time to ensure sterilization. The steam is then allowed to condense and exit through a steam trap. In busy facilities, fifteen to twenty loads can be sterilized per day. The process of sterilizing a load is called



Steam sterilizer and autoclave

a cycle. In busy facilities, the jacket around the inner chamber is kept hot with live steam even when the chamber is empty, so instruments can be processed on an emergency basis as needed. As the steam in the jacket condenses, the water is released through a steam trap. Usually only a pint or two of condensate is released and then only intermittently. This condensate must be cooled to below 140° F before it can be discharged to the sewer system. In older units, a stream of tap water was continuously run through a valve into the sewer connection to mix with the condensate. Most sterilizers are allowed to cool naturally, and the condensate drains from the chamber by gravity. Some hospitals have installed condensate-return lines, but the layout of many facilities and other difficulties make this practice rare.

Where volume is high or equipment needs to be sterilized quickly, a vacuum can be used to draw on the chamber and dry the instruments and evacuate moisture quickly. Historically, venturi aspirator equipment has been used to produce this vacuum. It works by passing water through a tube that tapers.

Typical flow rates are in the range of 5 to 10 gallons per minute, and the vacuum phase can last up to 30 minutes. Water use per cycle is in the range of 350 to 400 gallons per cycle.

Water-cooled laboratory and therapeutic equipment has historically used once-through cooling. Connecting this equipment to a closed-loop system such as a cooling tower or chilled-water loop is often impractical, but air-cooled chiller units are available. The main conservation techniques to consider with such equipment are to turn water off when not in use and to install equipment so that leaks are obvious.

Laboratory hood scrubbers are used when fumes and substances from exhaust hoods must be removed before the air stream is exhausted to the atmosphere. Both once-through and recirculating scrubber systems are available. When chemicals such as perchlorate are used, special equipment must be used to wash-down the surfaces of the fume hood to prevent an explosion.

Alternative Water Sources

Before beginning a discussion of the water-savings potential of the technologies described above, it is important to remember that the potential to collect and reuse steams from clean but non-potable water is significant in larger medical and laboratory facilities. This approach is promoted by “Labs for the 21st Century,” a joint program of the US EPA and the Department of Energy.


Julabo Recirculating Cooler Model FE1100



Modern Fume Hood



Esco Fume Scrubbers



Non-Potable-Water Collection and Reuse

US EPA Office of Administration and Resources Management. *Laboratories for the 21st Century*. www.Labs21century.gov/toolkit/bp_guide.htm

hp pump, the water used per day can range from 8,640 to 17,280 gallons. Newer liquid-ring pumps try to minimize water use, so their consumption would most likely be in range of 8,600 to 10,000 gpd. Using a dry-vacuum pump will save significant volumes of water or eliminate water use (Tuthill).

Medical Air and Compressor Equipment

Compressors generate significant heat as they compress the air. Smaller units, such as those used in dental and smaller medical facilities, can easily be air cooled. Compressors larger than 10 or 15 hp (Tuthill),

Possible sources of water include:

- any once-through cooling-water discharge
- water from reverse-osmosis units
- foundation drain water
- rain water
- other appropriate sources

Using reclaimed water from municipal sources is also possible for irrigation and cooling-tower makeup, as well as toilet and urinal flushing. The following diagram is for illustrative purposes only. Such a system must be equipped with proper backflow prevention and pumps where pressurized output is needed.

Water-Savings Potential

For the equipment described in the section above, the following water savings are possible:

Vacuum Systems

Dry systems do not use water for the pump seal but can use water for cooling the pump. Water-use rates for a liquid-ring pump range from 0.5 to 1.0 gpm per hp. Even this will be totally eliminated if no cooling water is used. Pumps should never be cooled with a once-through system. If a water-using system must be used, it should be hooked to a closed-loop or radiator-type system. The typical dental unit with a 1.5 hp liquid-ring pump can use 360 to 720 gpd (Sable Industries). For a large medical facility with a 12

however, often require water cooling. Ten hp equals 7.5 kW, and a once-through-cooled compressor that size would require a constant stream of 5 to 6 gpm to cool it when in operation. When water cooling is necessary, the compressor cooling system must be hooked to a looped cooling system. If not, water demands for this example could exceed 8,000 gpd.

Sterilizer Operations

Water use per cycle for large vacuum-steam sterilizers ranges from 350 to 400 gallons per cycle (TDK Consulting). Now new equipment often comes equipped with condensate-tempering systems (CTS). Mechanical vacuum pumps and other equipment can be retrofitted with after-purchase equipment (Continental Equipment). To reduce water use per cycle to less than 80 gallons.

The use of CTS on gravity and vacuum sterilizers also reduces water use significantly. Since the typical flow rate for tempering is 0.3 to 1.0 gpm, water use can be in the range of 450 to 1,500 gpd. The installation of a CTS can reduce this water use by 85 percent to 65 to 200 gpd.

Water-cooled Laboratory and Therapeutic Equipment

Daily water use depends upon the type of equipment being cooled and the length of time the equipment is used daily. Flow rates of 0.5 to 5.0 gpm are possible for each piece of equipment. Connecting larger stationary equipment to a closed-loop system is the first logical step in reducing water use to near zero. Recirculating water systems also minimize water use.

Laboratory Hood Scrubbers

Flow rates in scrubbers can be high. Recirculating systems reduce this use to a few gpm when operating.

Cost-Effectiveness Analysis

Vacuum Systems

Because liquid-ring vacuum systems must move both air and water, they are inherently less energy efficient and use significant amounts of water. However, they also tend to be the least expensive vacuum systems, based upon size and capacity (from a search of web sites for such equipment), so there is a true tradeoff between initial cost and operating cost.

A number of dry-vacuum systems are available for dental applications. The cost for a new dry-vacuum pump in the one to two hp size is \$5,000 to \$9,000. By comparison, a liquid-ring pump of the same hp costs \$2,000 to \$4,000. However, because dry systems are more efficient, a one hp dry system can often replace a 1.5 to 2.0 hp liquid-ring system. This partially offsets this cost difference. On an annual basis, dry systems use one-third to one-half less electricity than a liquid-ring pump and have zero water use (Tuthill). As an example, compare a system that requires a 1.5 hp liquid-ring pump with a 1.0 hp dry pump. In an eight hour day, the liquid-ring pump will use 540 gallons of water and 9 kWh of energy. The dry pump will use no water and only 6 kWh.

If the liquid-ring system of a large medical center requires a 23 hp pump, a comparable dry system (piston, vane, or non-lubricated) would require only 12 to 15 hp. Liquid-ring pumps require as much as twice the horsepower of equivalent dry-vacuum pumps because both water and air must be pumped. Liquid-ring pumps in continuous operation use water at a rate of 16,000 to 30,000 gpd.

In one example from a firm that sells all four kinds of pump systems, a 23 hp pump will use about 2.9 million gallons of water per year and 152,000 kWh of power (Tuthill). In contrast, the same tasks could be accomplished by a 12 hp vane pump, which would use no water and only 80,000 kWh of power (Tuthill). The costs for operating these systems will be dramatically different. The liquid-ring system cost would be about \$8,000, while vane and piston pumps would cost twice that. Liquid-ring and dry-vane pumps have

about the same life span of 10 years or fewer, while piston pumps can last several decades (Tuthill). As an example, one medical facility replaced a liquid-ring pump with a dry 10 hp vacuum system. The savings in energy and water were over \$40,000 per year (Deckkler).

Another major cost savings with dry systems is that they do not have to be plumbed for water or have a backflow system. These costs can be from \$200 to over \$2,000, depending upon how much plumbing must be done. Dry systems also eliminate the costs of annual inspections of backflow equipment, which typically cost from \$50 to \$100.

Medical Air and Compressor Equipment

Air-cooled systems do not use water, while once-through systems will use half a gallon to one gallon per horsepower-hour. Hooking up to a closed-loop system can be relatively inexpensive if the water line is readily available or expensive if long runs must be made. Typical costs of a few hundred to one to three thousand dollars can be expected.

Sterilizers and Central Sterile Operations

Most new sterilizers are equipped with water-tempering equipment at the factory, and medium and large vacuum systems come equipped with mechanical vacuum pumps, according to Steris's information on their web site (www.steris.com/).

Water-cooled Laboratory and Therapeutic Equipment

Cooling any piece of equipment with air is always the least expensive method. Where water must be used, hooking to a closed-loop system is the next best option. Cost for doing this is dependent upon the location and availability of chilled water for cooling-tower-loop piping.

Laboratory Hood Scrubbers

Equipment and operating costs for scrubbers vary with application, and case-by-case analyses are necessary. Remember that dry hoods are always less expensive than systems that require scrubbers, because they require no water or sewer hookups and backflow preventers, consume less electricity, and use no water. Typical costs of a few hundred to one to three thousand dollars can be expected.

Recirculating chillers are also available. This equipment has the advantage of very precise temperature control and the ability to achieve low water temperatures if needed. Equipment is rated in watts of energy removed and can vary in size from 1,000 to 10,000 watts. Cost for this equipment ranges from \$2,000 to more than \$8,000, depending upon capacity and brand. The price per watt is in the \$0.60 to \$0.90 range. There is also an electricity cost based upon the electrical-rating wattage of the equipment. For example, a 5,000 watt machine will consume 6.4 kWh in continuous operation, including the heat input from the motor of 3.5 watts removed per watt of motor energy input. Most units will not run continuously and will operate only when there is a heat load from the laboratory or therapeutic equipment being used.

The water savings are also based upon the amount of heat removed. Using the example above, a 5,000 watt machine with once-through cooling and a temperature rise of 10 degrees will use about 6.33 gpd in continuous operation.

Recommendations

Proven Practices for Superior Performance

- Use dry-vacuum systems in medical, dental, and laboratory facilities.
- Air cool or use a radiator cooler or a chilled-loop or cooling-tower system with all vacuum and compressor systems. Once-through cooling with potable water should be prohibited.
- Equip all stand alone steam sterilizers with condensate-tempering systems.
- Equip all vacuum sterilizers with mechanical vacuum systems.

- Cool laboratory equipment with a closed-loop system, such as a chilled-water or cooling-tower system, or with a recirculating chiller unit.
- Equip all hood scrubbers with recirculating systems.
- Perchlorate hoods on fume-hood washdown systems should have self-closing valves.

Additional Practices That Achieve Significant Savings

- Use dry hood-exhaust systems wherever possible.
- Promote the use of digital X-ray equipment (see section on “Photo Finishing and Processing”).
- Recover and reuse water from sources such as RO reject water, air-conditioner condensate, rainwater, foundation drain water, and any other applicable source for use as irrigation water, scrubber-water make-up, and cooling-tower make-up.
- Use dry cooling for all equipment where possible.
- Promote use of condensate-return systems for sterilizers.

References

Arizona Municipal Water Users Association, Black and Veatch. March 2003. **Facility Managers Guide to Water Management**. Version 2.3.

CH2MHill. May 2002. **Air Force Water Conservation Guidebook**.

Center for Maximum Potential Building Systems, Hospitals for a Healthy Environment, Merk Family Fund, New York State Energy Research and Development Authority, et. al. 2007. **Green Guide for Health Care 2.2**.

Continental Equipment Company. Tonganoxie, Kansas. www.sterilizer.net/contact. 800-710-9674.

Deckker Vacuum Technologies, Medical Vacuum Solutions. www.deckker.com.

Donovan, Robert P., Morrison, Dennis J., and Timon, Robert P. November 1998. **Design of Recycling Systems for Spent Rinse Water in Sandia’s Microelectronics Development Laboratory**. International SEMATECH TT# 98113599A-ENG.

Hursh, Debbie. March 2005. **Hazardous and Medical Waste Program, Fact Sheet on Information Papers – Ethylene Oxide (EtO) Sterilizers**. U.S. Army Aberdeen Proving Ground.

Johnson, Greg, Glitsis, Don, Beckwith, Clois, Huff, Winston, and Scoccia, Vince. March 2007. **How to Achieve Water Efficiency Credits**. GGHC/2E Green Building Teleconference Series.

Lessick, Dale. November 2002. **Converting X-Ray Machines from Water Pass-Through to Re-Circulating**. Irvine Ranch Water District. Irvine, California.

Muratore, Tom, and Lorange, Bob. April 2006. **Water Water Everywhere: Water Supply and Usage**. GGHC/H2E Green Building Teleconference Series.

New Mexico. Office of State Engineer. July 1999. **A Water Conservation Guide for Commercial, Institutional and Industrial Water Users**.

North Carolina Department of Environment and Natural Resources, Division of Pollution Prevention. August 1998. **Water Efficiency Manual for Commercial, Industrial, and Institutional Facilities**.

Sable Industries. www.sableindustriesinc.com/.

Sterrad. www.sterrad.com/products_&_services/sterrad/index.asp.

TDK Consulting Services, **The Reduction in Water Consumption of Sterilizer Equipment Resulting from the Installation of Water-Mizer Systems.** Parkville, Missouri.

Torke, Ted. September 1994. **Best Management Practices for Hospitals and Medical Facilities.** Palo Alto Regional Water Quality Control Plant.

Tschudi, William, and Rumsey, Peter. **Using Benchmarking to Identify Energy Efficiency Opportunities in Clean Rooms, The Labs 21 Approach.** Laboratories for the 21 Century (Labs 21) U.S. Environmental Protection Agency. http://www.Labs21century.gov/toolkit/bp_guide.htm.

Tuthill Vacuum and Blower Systems, Vacuum Solutions. Springfield, Missouri.

U.S. Navy. **Navy Water Conservation Guide for Shore Facilities.** portal.navfac.navy.mil/pls/portal/docs/PAGE/NAVFAC/NAVFAC_WW_PP/NAVFAC_NFESC_PP/ENVIRONMENTAL/EQIFS/WASTEWATER/08_WASTEWATER/lowflow.pdf.

Water Conservation at Tufts New England Medical Center (NEMC). www.h2e-online.org/pubs/tuftsh2o.doc.

U.S. Environmental Protection Agency, Region 9. 2002. **Replacing Ethylene Oxide and Glutaraldehyde.** www.ciwmb.ca.gov/wpie/Healthcare/EPAEtOGlut.pdf.

This page intentionally left blank.

Metering of Individual Units

Metering of Irrigation Use and Individual Dwelling Units at Apartments, Condominiums, Townhouses, Mobile-home Parks, and Commercial Facilities

From a water management perspective it makes sense to meter as many end uses of water as practical. This includes separating and metering irrigation use from other uses since efficiency standards can be established for landscapes based on irrigated area. That said, this discussion focuses on the metering of individual dwelling units at commercial and multi-family properties since it is important to understand many of the issues involved before implementing an expanded metering program targeted for this sector.

Most water providers currently bill apartments, condominiums, townhouses, mobile-home parks, and commercial properties through one or several master meters. Charges for water are allocated and included in the occupants' monthly rent. Occupants do not receive a water bill from the water provider directly. This practice provides little or no financial incentive to use water efficiently or to report leaks. The effects may be exacerbated during water shortages, when requests by the water provider to curtail usage are not directly conveyed to the occupants or can be easily dismissed.

In many large urban areas, much new residential construction is projected to be multi-family (MF) buildings. If new MF buildings continue to be master-metered and charges for water use allocated, a growing percentage of the urban population will not be directly metered and, therefore, not directly responsible for their own water use. By 2040, this condition may apply to as much as 30 to 50 percent of urban end users of water.

Because these practices neither promote conservation nor provide for awareness of water use and responsibility, water providers may wish to implement a program to meter individual units in new MF and commercial properties to capture the water-saving benefits. One state now requires all new apartments, condominiums, and mixed-use units to be plumbed for meters, and proposed local regulations would require water billing in new apartments and mixed-use buildings to be based upon actual metering and not allocation.

Metering that occurs downstream of a master meter is referred to as "submetering." Programs to meter individual units are not considered submetering if no master meter is used.

Much of the benefit to metering of individual units in multi-family dwellings and shared business spaces has to do with making tenants aware of their resource use and, therefore, having them assume responsibility for conservation.

Water Savings and Other Benefits

A national study on submetering and allocation programs conducted in 2004 found 15 percent water savings (8,000 gallons per dwelling unit) and 21 percent indoor energy savings associated with submetering by third-party billing entities (non-water providers) at existing MF buildings. In new construction, the savings is estimated to be approximately 6,000 gallons per dwelling unit, due to the installation of water-efficient fixtures required by the plumbing code. At sites where the occupants also have some landscaping, such as condominiums, townhouses, and mobile-home parks, the water savings is estimated at 20 percent.

Benefits to the property owner include not having to pay or divide up the water bill and controlling water (and wastewater) costs that are typically exceeding the rate of inflation. The benefits to the occupants are the water (and energy) savings and paying only for the water they use. The water provider will benefit through reduced operating costs and, due to direct pricing signals, the potential for better response in water-shortage emergencies.

Metering other end uses at MF and commercial properties, such as landscape irrigation and cooling-tower make-up and blowdown, also has benefits. Metering landscape irrigation allows for water budgets that can benefit both the water provider and the property owner. A growing trend is for water providers to require developers to install separate meters for irrigation in order to manage irrigation water use. California now requires separate metering of new properties with 5,000 square feet or more of landscaping.

Installing meters on individual units in commercial buildings can benefit customers where, in some cities, they are not charged wastewater fees for evaporated water from cooling towers if the cooling-tower make-up and blowdown water are metered. The same meters can be used to determine cooling-tower cycles of concentration, so operating improvements can be made. Commercial properties typically having only one meter serving multiple occupants include:

- mixed-use facilities with, for example, retail on the first floor and condos or apartments on the upper floors
- shopping and business centers
- airports that have restaurants and other vendors
- marinas

Metering, Billing, and Other Issues

Plumbing Configuration

A building's height and water-heating system usually determine its plumbing configuration. For example, if each unit in a building has a water heater, each unit can be served by one cold-water line. This means that just one meter is needed to record all of that unit's water use. However, in buildings with a common water heater (boiler), each unit is served by two water lines: one for cold water and one for hot water. Thus, two meters are needed to record all the water use in that unit. This makes metering much more expensive, since not only are two meters needed, but also a meter approved for up to 250° F is needed for the hot-water line. Such meters cost approximately \$100 more than cold-water meters. Alternatively just the cold-water line into each unit might be metered, and occupants may be billed for only the cold-water use, which is estimated to be 70 percent of the total. The cold-water line entering the boiler would be metered and the property owner billed for that use. Thus, all use on the property can still be metered using cold-water meters.

Meter Location

Water providers can require MF buildings to have a water meter installed for each unit. For most MF buildings up to three stories, meters can be clustered outside the building at or near ground level or in a vault. For buildings higher than three stories, it is not practical to have meters placed on the ground level, since that would require placing numerous water lines in the walls in long runs up to each floor. An alternative is to install meters in utility rooms on various floors. For example, in a 12-story building, banks of meters could be installed outside the building at ground level to serve the first three floors and in utility rooms on the 5th, 8th, and 11th floors (with each utility room having a bank of meters serving three floors). The meters could then be monitored using remote-read technology. If a water provider were responsible for the meters and the reading-and-billing program, it would need to address meter-accessibility (for meter servicing and turning meters on and off) and liability (leak) issues. For example, all utility rooms should have floor drains in case of leaks. The costs to the developer/owner to meter occupants in buildings higher than three stories will increase by approximately \$300 to \$400 per dwelling unit over three stories or less due to the issues cited above.

Administration

While it is assumed that the water provider will administer an expanded metering and read-and-bill program targeting this sector, it may not always be the case. However, since third-party billing is primarily unregulated in many regions, if a third party administers a program, the water provider should adopt appropriate regulations governing billing services. These should address bill format and information provided, prohibiting resale of water at a profit, level of service charges, late fees, complaint resolution, level of customer service, etc., unless applicable regulations have already been adopted at the county or state level.

Mixed-Use Development, Business Centers, and Malls

Many mixed-use buildings being developed today have businesses on the first floor and condominiums or office space on the upper floors. Submetering, with billing based upon actual water use, is much more equitable for customers in such buildings, where water usage can vary greatly among tenants.

At master-metered business parks and centers, it may be difficult for source-control representatives to determine the type of business in each space. This may lead to unmonitored and unregulated discharges and lost discharge fees. Therefore, another benefit of metering individual units/spaces at business parks is better regulation of wastewater discharges that may not otherwise be detected. Requiring individual water meters for these occupants could eliminate or reduce these issues, especially if there is communication between the water provider and the wastewater authority.

Cost-Effectiveness Analysis

Program costs and benefits can be assessed from four perspectives:

- the builder/owner
- the water provider
- the occupant
- the community

It is usually more cost-effective to meter individual units in buildings of less than four stories because the meter can be located outside the building at ground level. It is also more-cost effective, in terms of

capturing water savings, to meter those units (condominiums, townhouses, mobile-home parks) where the occupant is also responsible for outdoor irrigation.

Builder/Owner

The cost of requiring the owner to meter new construction can vary considerably and is estimated at \$100 to \$500 per dwelling unit, considering space for the meters, their installation, and meter-reading equipment (if appropriate), the potential need for utility rooms, and the type of meter-reading program and its associated hardware/software. These costs could be partially or totally offset by connection-fee (also known as a system-capacity charge) credits due to projections of lower water use related to the metering program.

Occupant

Occupants save on both water and energy use. Average water savings is estimated at 15 percent and average energy savings at 21 percent. The value of these savings will vary from region to region depending upon water and energy costs. However, these may be partially or completely offset by service charges associated with the cost of the metering program.

Water Provider

The water provider will realize various benefits through certain avoided costs (reduced operating costs and potentially reduced capital costs). Water-provider costs are passed on to end users through the water rates in service and volume charges.

Community

From the community perspective, program benefits (including customer water and energy savings, the utility's avoided costs, and improved water-consumption-management capability for the utility during water shortages) approximately equal program costs (meters, meter installation, reading and billing, and customer service). Community costs and benefits, while roughly estimated to be about equal, are dependent upon a number of variables, such as the value of the saved water to the utility, the cost of the metering program, and the value of improved response from this sector during a water-shortage emergency. These need to be assessed for merit by each water provider.

Recommendations

Proven Practices for Superior Performance

- Incorporate meters in new cooling-tower installations to measure make-up and blowdown water.
- Install separate irrigation meters for irrigated landscapes of 2,500 square feet or more.

Additional Practices That Achieve Significant Savings

- Meter individual units in new apartments, condominiums, townhouses, mobile-home parks, and mixed-use buildings of less than four stories.
- Meter individual units at commercial centers.

References

Aquacraft. 2004. **National Multiple Family Submetering and Allocation Program Study**. www.aquacraft.com/Projects/submeter.htm.

City of Austin, Texas. December 16, 1999 (adopted). "Installation of Water Meters," Section 2.3.3. **Water and Wastewater Criteria Manual**.

City of Austin, Texas. May 3, 2007. **Water Conservation Task Force Water Conservation Strategies Policy Document**, Recommendation IN-2, p. 10.

East Bay Municipal Utility District. September 2006. **Metering Program for New Non-Single Family Dwelling Units: Findings, Conclusions, and Recommendations**.

Miami-Dade County Consumer Services Department. 1996. **Miami-Dade County Water Remetering Ordinance**, 96-137.

Texas Commission on Environmental Quality. April 13, 2005 (adopted). "Utility Submetering and Allocation," **Utility Regulations**, Chapter 291, Subchapter H.

This page intentionally left blank.

Photo & Film Processing

Millions of images bombard our eyes from a proliferation of media. Media sources include formal portraits, vacation snap shots, movie theaters, cell phones, billboards, newspapers, television, computers, and Internet technologies. This proliferation has occurred in the past decade. Before, what photos did exist required “original art” or “wet processing” to develop and print a visible image. To preserve the image on film, the wet process included: developer, stop bath and fixer and water rinses between each step. A parallel process was used in producing a printed picture. All the steps used copious amounts of water.

With the advent of digital applications, use of aqueous processes to create printed images has substantially diminished, being replaced by technologies that:

- provide electronic images on video screens
- attach pigments directly to viewing surfaces (such as paper, transparent film, fabric) entirely without water
- develop films and print images with “mini-labs” that use very little water

The chart on the following page compares the equipment and flow of processes used in wet chemistry photography with the capture and processing of digital images.


Water-using technologies that have specific potential for water conservation are discussed in this section and include:

- consumer and professional photography
- medical, dental, and veterinary imaging
- commercial printing and advertising

For each technology described in the following pages, alternative water-efficiency methods are scored “High” (better than 50 percent savings), “Medium” (10 to 50 percent savings), or “Low” (less than 10 percent savings) compared with standard technologies and are ranked as “proven practices for superior performance” or “additional practices that achieve significant savings.”

The table on page PFP2, “Water-efficiency measures for photo and film processing,” may be used to guide selection of equipment and processes for photography, imaging, and viewing.

While photo and film processing was once a huge consumer of water, new processes and digital imaging technologies have significantly reduced that consumption.



Photography

Description of End Use

Consumer photo developing and printing shops are widespread in many retail locations, such as drug stores, super markets, quick-print shops, and shopping-mall kiosks. Even with digital cameras, the printed image remains popular. The difference is that the methods of capturing and printing the image have changed.

Historically, photographic prints were the end results of the photographic process. To appreciate the process used in many types of end uses (such as commercial printing, semiconductor production, medical imagery) a brief explanation of the basic photographic process is provided here.

- Light energy (visible, X-ray, ultraviolet, or infrared) radiates a surface capable of recording the energy characteristics, such as intensity, frequency, color, and object shape. Traditionally, the prepared surface has been a film or plate chemically treated with a light-sensitive photographic emulsion. The emulsion is usually composed of silver halide salts and gelatin. Silver compounds are used because they react to visible light.
- The film or plate is chemically “developed” to convert the emulsion to metallic silver in proportion to the amount of energy exposure. Developing is stopped by immersing the film in a “fixing bath,” often of sodium thiosulfate (hypo). The bath preserves the image (usually a negative) on the film or glass, which is then rinsed extensively. An older commercial film-developing sequence with its many rinse and wash-water applications is shown on the following page.

- To produce a print, a light source is transmitted through the developed film onto a sheet of photosensitive paper containing layers of silver emulsions. Like film processing, chemical solutions remove the silver and fix the image on the treated paper.

Unfortunately, silver acts as a biocide to aquatic life and has been identified as a hazardous waste. Therefore, the discharge of solutions containing fixer is regulated by wastewater utilities. EBMUD wastewater regulations require that all “silver rich wastewater (fix, bleach-fix, washless stabilizer and low flow wash) shall receive treatment prior to discharge. Dilution is not allowed as a form of treatment.” “Silver rich wastewater is prohibited from discharging to the sewer.”

Water-Efficiency Measures for Photo and Film Processing

End Water Use	Proven Practices for Superior Performance	Additional Practices That Achieve Significant Savings
Photography		
Image recording		<ul style="list-style-type: none"> • Encourage digital cameras
Printing images	<ul style="list-style-type: none"> • Prohibit discharge of any “fixer” solutions to sanitary sewers • Self-contained “mini-lab” film-developing and printing 	<ul style="list-style-type: none"> • Laser, ink-jet, or other waterless technology to produce printed imagery
Imaging for Medical Hospitals, Clinics, Imaging Labs, Dental Services, and Veterinary Services		
X-ray film	<ul style="list-style-type: none"> • Prohibit old-style wet chemistry imaging systems • Self-contained “mini-lab” film-image developing 	<ul style="list-style-type: none"> • Digital imaging instead of film images
X-ray digital images		<ul style="list-style-type: none"> • Electronic video screens to view electronic images • Laser or ink-jet printing technology to print hard-copy images
Commercial Printing		
Photo processing	<ul style="list-style-type: none"> • Self-contained “mini-labs” that have no plumbing • Computer-to-plate technology for large print shops. 	<ul style="list-style-type: none"> • Digital technology

Water-Savings Potential

Digital photographic technology has changed both the means of recording images and producing printed images. Instead of film, semiconductors sense the light energy and record it as a digital file. Its popularity has dramatically reduced the use of photographic film.

Amateur photographers take most of their film and digital photographic images to popular one-hour centers for developing and printing. The one-hour centers use automated mini-lab machines, which employ these techniques:

- To develop photographic film, wet chemical solutions are added as needed for the volume of film processed. “Washless” or “plumbingless” processing eliminates the need for additional water. A reservoir adjacent to the mini-lab captures spent solutions, which are periodically collected by hazardous-materials services to recover silver compounds.
- To print images, several options are available:
 - » A developed film image is scanned, then the digitized image is sent to a printer.
 - » Developed film is fed into a wet-process mini-lab, which produces prints.
 - » A digitized image is sent to the same type of printer as the scanned image from film.
 - » The printer uses laser or ink-jet technology to produce the image on the paper or other surface of the customer’s choice.

Commercial photo laboratories have also adopted digital-image technology. Their products range widely from poster-size prints and illuminated transparencies for advertising to wraps for vehicles and signage. The images are most often provided to the lab in a digital format, or in the case of original artwork, are scanned or digitally photographed to form a digital image. A variety of printing machines use laser technology to transfer the image to the substrate/surface most suitable for the commercial purpose.

Process Alternatives	Water-Savings Potential*
Recording images with digital cameras instead of film developed in mini-labs	Low
Printing images with laser or ink-jet technology instead of conventional wet printing and high-rinse flow systems	Medium
Printing images with mini-lab systems instead of conventional wet printing and high-rinse flow systems	High
Converting mini-lab systems to digital systems	Low
*High=better than 50 percent savings; Medium=10-50 percent savings; Low=less than 10 percent savings compared with standard technologies	

Recommendations

Proven Practices for Superior Performance

- Prohibit discharge of any “fixer” solutions to sanitary sewers under EBMUD wastewater permits.
- Use self-contained “mini-labs” for film developing.
- Use self-contained “mini-labs” for printing.

Additional Practices That Achieve Significant Savings

- Produce printed imagery using laser, ink-jet, or other comparable technology.

Cost-Effectiveness Analysis

Using mini-labs to develop film has little water savings compared with recording images digitally. The digital advantage is associated with computer communications and image manipulation. Due to the very small water advantage, no economic evaluation is provided.

Likewise, converting mini-labs to laser or ink-jet systems provides the owner with the advantages of computer communications, but saves little water. Therefore, no economic evaluation is provided.

Converting conventional film-developing and photo-printing processes with high-rinse flows offers a substantial opportunity for water savings. However, environmental regulations now prohibit discharge of these silver-laden flows to wastewater systems. New systems no longer have high-rinse flows.

Medical, Dental, and Veterinary Imaging

Description of End Use

Images of the internal organs of living beings have been important tools for medical diagnosis for many years. Medical clinics, hospitals, dental offices, veterinary clinics, and medical-imagery laboratories frequently produce these images.

Medical imaging typically includes X-rays, magnetic resonance imagery (MRI), thermography, and sonograms. Medical images are produced by energy beams interacting with the body. The resultant energy intensity is recorded on film or by sensors placed adjacent the patient. X-rays have been used for many years and were traditionally recorded on transparent film and preserved with wet-process chemistry. MRIs, thermography, sonograms, and other imagery techniques that employ computer technology and video screens rather than printed images have relatively recently been developed. The balance of this discussion will concentrate on X-ray technology.

Conventional X-ray medical applications use coated films that produce visible images when exposed to X-rays. The films then are developed through a wet-chemical photographic process. Most frequently, a full-scale, high-contrast negative is placed on a light source for medical evaluation.

Like photography, X-ray imagery has recently adopted digital technology. This uses a multilayered plate that operates as a scintillator, a compound that absorbs X-rays and converts the energy to visible light. The frequency of the light produced is matched to the sensitivity of a semiconductor that converts the light energy to digital signals that can be presented for medical assessment by:

- transmitting the image via computer networks and video screens
- printing the image on transparent film with dry-laser or ink-jet technology

Some medical-imagery centers continue to use X-ray film with its older style photo chemistry and fresh-water film rinsing. These sites are reluctant to pay the higher initial costs for digital sensors and computer networks. Water-saving recycling systems should be encouraged where digital technology is not employed.

Water-Savings Potential

C & A X-ray, a California-based company, provides the Dow Imaging Water Saver/PlusTM system, a patented water-recycling system for high-volume imagery centers still using wet chemistry and water-rinsing methods. Initially developed when the 1994 Northridge California earthquake interrupted water service to hospitals, the recycling system allows high-volume X-ray processors to operate with substantially reduced water use.

Large hospitals may have several X-ray processing machines, which operate 24 hours per day and seven days a week. Published flow requirements for conventional processing-system fresh-water flows are 0.25 to 1.32 gallons per minute per machine. The flow is typically discharged to wastewater. Although these machines can be fitted with shut-off valves and flow regulators to reduce water waste, these devices are often poorly maintained or not used. The Metropolitan Water District of Southern California and the Los Angeles Department of Water and Power have recognized X-ray-processor water savings of as much as one million gallons per year per machine using the Water Saver/Plus system. In addition

to water savings, the customer may reduce fees paid for wastewater discharge. The Water Saver/Plus system has a list price of \$4,195.

Dental radiography is another use of X-rays with chemical image processing. Dental patients hold “bite sized” pieces of X-ray film enclosed in sanitary packaging in their mouths while the x-ray machine is energized. The film is developed with a table-top-sized “mini lab.” Most offices report they purchase pre-packaged film developer and fixer. These chemicals are periodically replaced, depending upon the number of exposures. Like the photo labs, discharge to sanitary sewers is prohibited. Disposal is accomplished with hazardous-materials services.

According to a 2005 US EPA Region 9 survey of dental radiography in the San Francisco Bay Area, about 28 percent of responding dental offices used digital radiography, and another 19 percent said they were considering changing to digital within the next two years. The survey report cited the advantages of digital radiography as:

- no chemicals
- less radiation
- greater speed
- image-manipulation capability
- less waste

Disadvantages cited were:

- cost
- patient discomfort
- computer dependence
- image quality

An opportune time to change to digital radiography could be when an office is installing or upgrading a computer system.

Process or Equipment Alternatives	Water-Savings Potential
Converting large X-ray chemical-processing systems to digital systems	High
Installing recycling technology, such as Water Saver/Plus, on large X-ray processing systems	High
Converting smaller conventional processing systems to mini-labs	Medium
Converting mini-labs to digital systems	Low
For digital images, use laser or ink-jet printing to produce hard-copy images	Medium
View digital images with video screens	Medium

Recommendations

Proven Practices for Superior Performance

- Use self-contained “mini-lab” image-developing units.

Additional Practices That Achieve Significant Savings

- Produce images using laser or ink-jet printing technology.
- View images on electronic video screens.

Cost-Effectiveness Analysis

Conversion of mini-labs to digital systems provides the owner with advantages associated with computer communications, but saves little water. Due to the very small water advantage, no economic evaluation is provided.

Commercial Printing

Description of End Use

Commercial printing is a major business. Printing establishments include photocopy shops, offset printers, large newspapers, and book publishers. All of them potentially use photographic techniques.

The main technologies of commercial printing are flexography, gravure, screen-printing, lithography, and digital processing. All of them use three major steps: prepress, press (e.g., putting ink on paper), and post-press (e.g., binding). The following discussion focuses on prepress elements, because they use photographic processes.

Historic prepress operations focus on composition: the arrangement of art, photos, and text into the desired format. Once the format and images are assembled, they are photographed. The photographed negative or positive images are next transferred to an image carrier used to produce a plate, cylinder, or screen that has been treated with a light-sensitive coating. Light is transmitted through the negative or positive film to expose the coated plate. The exposed plate is then processed to produce a plate with defined printing and non-printing areas. During processing, the soluble areas of the coating are washed away, while the insoluble areas remain on the plate. The insoluble areas of coating remaining on the plate become the ink carriers during printing.

Water-Savings Potential

The advent of desktop publishing made it possible for text and images to be manipulated easily on personal computers for eventual printing on desktop or commercial presses. The development of digital image-setters enabled print shops to produce negatives for platemaking directly from digital input, skipping the intermediate step of photographing an actual page layout. The development of the digital platesetter (a machine that makes the plate ready for the press) in the late twentieth century eliminated film negatives altogether by exposing printing plates directly from digital input, a process known as “computer-to-plate” (CtP) printing.

Process or Equipment Alternative	Water-Savings Potential
For non-digital photographic printing require self-contained mini-labs instead of high-water-use processing	High
Convert from a wet-photo process to CtP technology	Medium

In addition to reducing production time and improving plate quality, CtP eliminates the chemical image-development process and the accompanying water use. During the past decade, this has been a quickly changing technology.

Cost-Effectiveness Analysis

Conversion from conventional plate creation to CtP has several benefits that may be more valuable than the cost of water. The industry cites these benefits to include:

- eliminating the cost of the processor, including floor space
- eliminating the cost of chemistry
- eliminating processor maintenance
- reducing inventory costs
- eliminating the oven, with its associated energy costs, for baking the plates
- reduced waste disposal
- improved environmental compliance

The transformation to computer equipment and CtP technology has considerable initial cost. In the long run, the capital cost is outweighed by the improvements and their accompanying benefits.

Recommendations

Proven Practices for Superior Performance

- For photo processing, use self-contained “mini lab” units that require no plumbing or washing.
- Employ CtP technology in large print shops.

Additional Practices That Achieve Significant Savings

- Adopt CtP technology.

References

U.S. Environmental Protection Agency. Illinois Waste Management & Research R5. Contact Deb Jacobson, 630-472-5019.

U.S. Environmental Protection Agency. 1995. Office of Compliance Project. **Profile of the Printing Industry. Publication #:** EPA/310-R-95-014 **SIC Code:** 27.

Varian Medical Systems, www.varian.com/xray/prd003b.html.

“Plates process free.” February 2005. **Graphic Arts Monthly**. www.gammag.com/Current/index.php?art=gam0502Fplateprocfree.

“Processor-free CTP.” March 1, 2006. **American Printer**. americanprinter.com/mag/process_free_ctp_0306/.

“What is CTP?” **Webopedia**. www.webopedia.com/TERM/C/computer_to_plate.html.

Digital Data Delivery for Australian Publications. www.3dap.com.au/whatisctp.htm.

Pools, Spas, & Fountains

Pools, spas, hot tubs, fountains, and other types of decorative water features can waste large volumes of water if not properly designed and equipped for efficient operation. Four principles govern good practice:


- design the mechanical equipment to filter, clean, and operate the pool
- design the pool to minimize water loss
- choose alternatives that use less water
- install decorative water features only where they provide tangible benefits

Pools, spas, and fountains require water for make-up, evaporation, splash-out, filling, backwashing the filter, and replacing water lost to leaks.

Six practices and considerations will result in more efficient water use:

- install a meter on the pool make-up line so water use can be monitored and leaks can be identified and repaired;
- choose a filtration system that will minimize water use while accommodating cost considerations;
- include splash troughs that drain back into the pool;
- use a pool cover if it is practicable to do so;
- carefully monitor backwashing to ensure that excessive backwashing times are not used; and
- reuse backwash water for irrigation where possible. The reuse of backwash water for irrigation of a park can make sand filters, which use more water than other types of equipment, the most water-efficient choice, if the backwash water replaces potable water otherwise used for that purpose.

The following diagram shows how a pool works.



© 2002 HowStuffWorks

If it has been determined that a pool or a water feature will provide tangible benefits, the physical design of the feature and the mechanical components chosen can contribute to efficiency and water conservation.


Description of End Use

Refilling Pools: Water is used to refill a pool, spa, or fountain both to make up for water lost through evaporation and splash-out and to replace water lost during filter backwash. Refilling occurs when the pool, spa, or fountain is drained either for periods of non-use or when the dissolved solids (mineral) content of the water has become too high. It is typical to drain and refill a pool every three to six years for maintenance and control of dissolved solids. Drained water can be used for irrigation as long as the dissolved solids are controlled and chemical and chlorine levels are not too high. Allowing a pool to settle until the chlorine concentration of the water is below 2.0 milligrams per liter will place the water within municipal potable-water parameters, at which time it is safe to use for landscape irrigation. It is important to keep the basin, pool, spa, or fountain clean and the water properly treated to avoid needing to drain or dump the water prematurely.

Water and Energy Loss: Evaporation and splash-out vary based upon both weather conditions and activity. In the summer, evaporation alone can amount to five to twelve inches a month, and splash-out can add several inches. This water must be replaced to keep the pool at proper levels. To reduce evaporation:

- design pools to incorporate splash troughs along the edge to catch water that would normally be splashed out onto the deck. The troughs should drain back into the pool system.
- avoid using sprays and finely divided streams of water in fountains and waterfalls. Aeration causes a significant amount of evaporation.
- use shrubs and fences as windbreaks to reduce water losses due to wind evaporation.
- cover pools when not in use to reduce evaporation and keep water cleaner. In the summer, evaporation ranges from five to ten inches a month (The Association of Pool and Spa Professionals). Using a pool cover eliminates almost all evaporation. If a pool is heated, as much as 70 percent of heat is lost through evaporation (U.S. Dept. of Energy – EERE Consumer’s Guide). Covers range from single sheets of plastic to insulated materials. Costs vary from under \$80 for a single-layer vinyl cover to several thousand dollars for covers with automatic retractors. Many pool operators resist using pool covers. Therefore, one advantage of higher-cost retractable covers is that, since they are more convenient to use, they are more likely to be used.

Outdoor Pool Energy Loss Characteristics



www.eere.energy.gov/consumer/your_home/water_heating/index.cfm/mytopic=13140



Filtration and Disinfection: All pools, spas, and fountains should have properly sized equipment to filter and disinfect the water. The three main types of filters are sorptive media, sand, and cartridge. Each has advantages and disadvantages. For two of these, a backwashing system is required to clean the filtration system. Depending upon the type of filtration used, a substantial amount of water may be discharged during this operation. The frequency of backwashing depends upon the level of usage for the pool. Heavily used municipal pools need more frequent backwashing than lightly used motel or even school pools.

Pool Filtration Equipment Comparison

Characteristic	Sorptive Media	Sand	Cartridge
Filtration efficiency	5 microns	30-40 microns	10-20 microns
Media replacement cost	\$0.15 - \$0.50/lb	\$0.50 - \$1.00/lb	\$15 - \$100 each
Use in large public pools	Yes, with proper design	Yes	No, too labor intensive

- Sorptive media filters include conventional diatomaceous earth (DE) or perlite filters and regenerative filters that reuse the filter media. These filters remove particles down to 5 microns in size, while sand and cartridge filters work in the 10- to 40-micron removal range (Pool-Plaza.com). Sorptive media filters have hundreds to sometimes over 1000 fabric-coated tubes inside a pressure container. The medium (DE or perlite) is made into a slurry and mixed with the water in the filter. The medium is then deposited on the tubes by the water being pumped through the filter. Conventional sorptive media filters must have the DE or perlite replaced after each backwash. With regenerative sorptive media filters, the medium is periodically “bumped” off of the filter tubes by backflow, air agitation, mechanical shaking, or a combination of the three. It is then recoated onto the filter cloth. In an example from the Neptune Benson Corporation, the internal filter media recycling occurs about thirty times before the medium is dumped and replaced. No water is lost in the recoating process. When the medium is flushed, only a few hundred gallons of water are needed (Neptune Benson). This makes regenerative sorptive media filters very water-efficient.
- The amount of water used to backwash a filter depends upon the size of the pump, which in turn depends upon the size of the pool. Pool filters are designed to turn the total volume of the pool (pump it through the filter) in a specified amount of time. For large pools, the volume of water is designed to pass through the filter in six hours. Smaller wading pools, spas, and spray-scapes have much higher turnover rates. The filter pump for a 100,000-gallon public pool must have a capacity of 278 gpm. When a filter is backwashed, the same pump is used. Since back pressure is less during backwash, the flow rate of the pump may be slightly higher, but still in the range of 280 gpm. Backwashing the filter for five minutes uses approximately 1,400 gallons of water. Some larger pools are backwashed longer than that because of the size of the filter. Pool filters should be backwashed based upon pressure drop and never on a timer.



Coated Flex Tubes as seen through Defender Viewing Window

the replacement filters range from \$15 to \$100, depending upon the quality and type of filter. Some types of cartridge filters must be replaced each time the pressure falls outside pressure-differential limits; these are not recommended because of the waste of materials. The better type has a reusable filter cartridge. Two sets of filters are needed. When one set is removed for cleaning, it must be soaked in a cleaning solution and then brushed and rinsed off. A significant advantage is that no backwash water is used, and the cleaning process requires less than ten gallons. These filters last two to five years. Drawbacks to cartridge filters are expense and that cleaning is labor intensive.

Reuse of Backwash Water: Where backwash water is produced, it can be used for landscape irrigation if the chlorine content is less than 2.0 milligrams per liter and the dissolved solids are not greater than the plants can tolerate. Lists of plants and their salt tolerance can be found at most land-grant universities. Some entities have proposed to recycle the backwash water back into the pool after settling and filtration. Most health codes prevent this.

Make-up Meters: Make-up water for keeping the pool, spa, or fountain full should be metered to determine whether leaks are occurring. Pools and fountains can leak with no obvious signs other than a mysteriously high water bill. A meter on the make-up (fill) line can quickly identify abnormal use and help monitor water use volumes for backwashing filters and other operations. A length of Plexiglas pipe on the backwash line can help operators determine that backwash valves are completely closed and water is not being lost through the backwash line during normal pool operation.

Alternatives to Pools: Water-saving alternatives include play-scapes that use sprays and other water features activated only when someone is going to use them. Since the water is never more than an inch deep, safety is increased. Although fine spray and mist can increase evaporation, efficiency is obtained when the water is captured and treated after each use. Water is stored in a tank with a filtration and disinfection system. Tank storage also reduces evaporation and chemical use over an open wading pool, where water is dumped and refilled every day (Communications with the City of Austin, Texas).

Manufacturing specifications will tell when to backwash, but the normal range is when pressure drops 10 to 15 psi. Automatic backwash equipment will not backwash a filter until the proper pressure drop has occurred. This minimizes the number of backwashes to only what is needed. The sand needs to be inspected once or twice a year. Sand may last for several years before needing to be completely replaced; however sand may need to be added periodically to replace any lost during backwash (Williams).

- Cartridge filters are not designed for larger size pools like municipal pools. Cartridge filters cost less than sand filters, and



Hayward Cartridge Filter

Water-Savings Potential

Water savings from leak detection are hard to predict, but an investment of less than \$200 to install a meter when a pool is built is wise, since a pool can lose up to 50,000 gallons a month with even a small leak of one gpm. Pool and fountain leaks of over one million gallons a month have been reported (Truesdale). Choosing a proper filter and controls can also result in significant water savings.

A 35,000-gallon pool uses from one to several thousand gallons of water a month for backwashing, if procedures are poorly designed. In contrast, cartridge filters use almost no water, and DE filters use under 100 gallons.

Cost-Effectiveness Analysis

Evaporative loss over a year ranges from 30 to 80 inches. That equals 1.5 to 4.0 gallons per square foot of surface area per year.

Example: a 100-foot by 70-foot pool.

- Evaporative loss is 10,000 to 25,000 gallons per year.
- Pool covers:
 - » reduce evaporation
 - » delay pool draining
 - » extend the time before backwashing is needed
 - » reduce the amount of dust, dirt, leaves, and other material entering the pool
 - » prevent animals from contaminating the water.

Filter costs for a 30,000 to 40,000-gallon pool (not including the pump, which is in the same cost range for all three types of filters) are:

- DE — \$400 to \$800
- Sand — \$250 to \$700
- Cartridge — \$200 to \$400

DE- and perlite-filter operations — DE costs \$0.50 to \$1.00 per pound; perlite costs \$1.00 to \$1.30 a pound (review of costs posted on the web). About 0.125 pounds of DE will coat one square foot of filter (The Schundler Company). Perlite is much less dense. A cubic foot of DE weighs about 20 pounds, while a cubic foot of perlite weighs 2 to 8 pounds. Since the requirement for DE or perlite is based on volume, as little as 0.04 pounds of perlite will coat a square foot of filter. The flow rate through a filter is 1.5 gpm per square foot.

Using a 360,000-gallon pool as a basis, the flow rate would be 1,000 gpm and the filter area would have to be 667 square feet. Such a filter would require 84 pounds of DE or 27 pounds of perlite. Re-charging the filter every 20 to 30 days will require dumping under 1,000 gallons to the drain (Filtrex, Inc.). Based upon 1,000 gallons per backwash and 60 backwashes a year, annual backwash use would be 60,000 gallons. If a pool were in use only part of the year, proportionally fewer backwashes and quantities of water would be required (Neptune Benson).

Sand-filter operations — A sand filter in a heavily used public pool needs to be backwashed about every three days. Using a 360,000-gallon pool as an example and a six-minute backwash, the pool will use about 6,000 gallons every time it is backwashed. In one year, the pool will be backwashed 120 times and will use 720,000 gallons, compared with 60,000 gallons for a regenerative DE or perlite filter. With a sand filter, such a pool would require 12,000 to 18,000 pounds of sand at a cost of \$0.15 to \$0.50 per pound, depending upon the filter design (Neptune Benson).

Filter cartridges cost from \$15 to \$100, depending upon the quality and type of filter. Typical life is 2 to 5 years, with the better (more expensive) filters lasting longer. Many cartridge-filter elements are needed per filter system for a large pool, and several filter systems are needed. Adding labor costs to hand-clean cartridge filters renders them not cost-effective for public pools, although they may be appropriate for small motel or apartment pools (PoolPlaza).

Recommendations

Proven Practices for Superior Performance

- Require all pools, spas, and fountains to be equipped with recirculating filtration equipment.
- Require in-ground pools to be built with splash troughs around the perimeter.
- Require make-up meters to be installed on all pools.

Additional Practices That Achieve Significant Savings

- Use sorptive media filters where possible for all pools, spas, and fountains.
- Use cartridge filters for smaller spas, where the costs of filters and cleaning make them economically feasible.
- Reuse backwash water for irrigation or consider retreatment and reuse in the pool.
- Consider use of alternatives to wading pools, such as spray-scapes.
- Use pool covers, especially during periods when a pool is not in regular use.
- Use shrubs or fences to shade pools and block winds that increase evaporation.

References

California. 2003. **Code of Regulations, Chapter 20 – Public Pools.**

De Haan, William, and Johanningsmeier, Julie S. 1977. **Michigan Category 5A exam on swimming pool management.** Michigan State University, Ann Arbor, Michigan.

Fawcett, Paul. **Clear Vision.** USA Swimming (1 Olympic Plaza, Colorado Springs, Colorado).

Filtrex, Inc. (P.O. Box 2273, Wayne, New Jersey, 07474). **Precoat Media Fact Sheet**, IS 5887 A.

Harris, Tom. “How Swimming Pools Work.” **HowStuffWorks** (One Capital City Plaza, 3350 Peachtree Road, Suite 1500, Atlanta, Georgia 30326). HowStuffWorks.com.

Hoffman, H.W. 2006. **Water Efficient Equipment and Design: A Guide for Non-residential Construction and Development.** City of Austin, Texas. Austin Water Utility.

Neptune Benson (6 Jefferson Drive, Coventry, Rhode Island 02816). **Defender Automatic Regenerative Filter.** Neptunebenson.com.

Northeast Spa & Pool Association (300J Campus Drive, Morganville, New Jersey 07751). www.nespa.org/pdf/industry_pdf/facts_pool_water_usage.pdf.

PoolPlaza.com (10500 Metric Drive, Dallas, Texas). **Filter Comparison Chart.**

Schundler Company, The (P.O. Box 513 Metuchen, New Jersey 08840). 1997. **Swimming Pool Guide.**

Stachecki, Julie, DeHaan, William. 1997. **Michigan Category 5A exam on swimming pool management.** University of Michigan. East Lansing, Michigan. www.pested.msu.edu/Resources/bulletins/pdf/2621/E2621chap8.pdf.

Truesdale, Pat. 2002. **Cases in Water Conservation**. U.S. Environmental Protection Agency.

U.S. Department of Energy. EERE. **Swimming Pool Covers**.

www.eere.energy.gov/consumer/your_home/water_heating/index.cfm/mytopic=13140.

U.S. Department of the Army. 1986. **Repairs and Utilities: Swimming Pool Operation and Maintenance**. TM-5-662.

Williams, Kent. 2006. **Contact the Pumproom Tech** (PO Box 164, New Castle, California 95658).
kent@altarfire.com.

This page intentionally left blank.

Process Water

Water used by industries and businesses to produce a product or affect a process is known as “process water.” This section discusses the following industries and their uses of process water:

- food and beverages
- auto repair and service
- paper manufacturing
- metal finishing

The chapter will not cover opportunities to save water by using efficient plumbing fixtures and irrigation systems, since these are covered elsewhere in this report.

While much of the information herein is specific to the product being manufactured or service being provided, the potential to design water conservation into the process ranges from simply adjusting the equipment or process to use less water to adopting new practices or processes that use no water at all.

Food-and-Beverage Processing

The food-and-beverage-processing industry includes a wide range of products and manufacturing processes:

- bakery/pastry shops
- industrial bakeries
- breweries
- wineries
- soft drink and juice manufacturers
- dairy-food processors
- meat, fish, and poultry processing
- frozen-food producers
- canneries
- snack-food manufacturers
- grocery stores and restaurants that produce food products for sale
- other food and drink processors

The food-and-beverage industry uses water for many purposes. The quality and purity of the water is of primary concern since it is used to make products that will be consumed. Water is also used to clean and sanitize floors, processing equipment, containers, vessels, and the raw food products prior to their processing. Hot water, steam, cooling, and refrigeration also require source water. Designing and building a facility that has a reduced requirement for water includes:

- designing the facility for ease of cleaning
- providing adequate metering, submetering, and process control
- taking advantage of dry methods for cleanup and transport

Few industrial processes involve no need for water. In every industry that uses water, careful planning and design can minimize water waste and optimize the benefits received from the water that is consumed.


- using product- and byproduct-recovery systems
- incorporating water reuse and recycling
- designing for minimal or no water use

Description of End-Use and Water-Savings Examples

Because of the complicated and highly varied nature of the food and beverage manufacturing industry, providing a simple guide to water efficiency that covers all types of facilities is not possible. Before beginning this discussion of water conservation in food processing, one should remember that health and sanitation are overriding concerns. All actions to reduce water use must be measured against this primary consideration.

The following example illustrates ways water can be used in the soft-drink industry. Potable water is first treated to soften it and, if needed, to remove additional minerals. It is chilled and blended with flavorings and sweeteners, then carbonated. Cans or bottles are filled and sealed, then rinsed and sent through a warming bath to avoid creating condensate in the open air and ensure they are dry before packing. The eight major water-using processes are:

- water softening, which requires periodic filter backwash
- water included in the product
- water to clean and rinse cans
- water to warm cans after processing
- water sprayed on the conveyor line as a lubricant
- water to operate cooling towers for refrigeration equipment and boilers for heat
- water to sanitize and clean the plant and vessels
- water for employee sanitation, irrigation, etc. (North Carolina Department of Environment, Health, and Natural Resources, 1998).



Based upon concise.britannica.com/ebc/art-54000

Each of eight major water-using activities in the food- and beverage-manufacturing sector will be described, along with examples from specific industries where appropriate:

- cleaning and sanitation
- thermodynamic processes
- transportation and cleaning of food products
- equipment cleaning
- container (bottles, cans, cartons, etc.) cleaning
- lubricating can and bottle conveyor belts
- can and bottle warming and cooling
- product ingredients

Cleaning and Sanitation

Information on floor cleaning and the cleaning of outdoor areas is found in all sectors (see “Food Service”). Dry cleanup, preventing spills by controlling processing equipment and leaks, and proper storage and handling of ingredients all reduce water needed for cleaning.

The following table summarizes the importance of water for cleaning in four food-processing sectors (Environmental Technology Best Practices Program).

Water Use by Major Food-Processing Types

Type of Process	Percent of Water for Cleaning
Bakery	70
Soft drink	48
Brewing	45
Jam	22

Thermodynamic Processes

Another common use of water is in the production of steam and hot water and in cooling towers, as discussed in the section on Thermodynamic Processes. Metering and submetering are important in understanding how much water is used in each process or type of equipment. Proper process controls are essential to managing water and energy use.

Transportation and Cleaning of Food Products

The use of flumes to both transport and clean produce (fruits and vegetables) is common. Water is also used in the cleaning and processing of meat, poultry, and fish. Common water-conservation techniques begin with reducing water use by:

- recycling transport water
- adjusting design of flumes to minimize water use
- using flumes with parabolic cross sections
- providing surge tanks to avoid water loss
- using float control valves on makeup lines
- use solenoid valves to shut off water when equipment stops

All these techniques can reduce the need for water, but changing the process has even more potential.

- Replace fluming with conveyor belts, pneumatic systems, or other dry techniques to move food products.
- Install sprays to wash food.
- Use mechanical disks and brushes.
- Install counter-flow washing systems.
- Control sprays on belts.
- Control process equipment to reduce waste.

Grocery stores and smaller bakeries should follow good food-service sector washing practices for meats, fruits, vegetables, and other food products before final packaging. Further, ensure that all water-using process equipment has proper level and flow controls (Costello).

As an example, a Minnesota vegetable-processing firm reduced water use for conveying corn by 20 percent, or 1,000 gpd, just by employing proper controls and recycling 20 percent of the water in the flumes (North Carolina Department of Environment and Natural Resources).

Equipment Cleaning

Equipment to be cleaned ranges from large process facilities and equipment to the hand-held equipment and cooking utensils found in smaller bakeries and grocery stores. Smaller utensils should be washed following the ware-washing considerations found in the “Food Service” section. Larger equipment that cannot be disassembled easily must be cleaned in place. Choices of procedures for cleaning equipment can yield multiple advantages including:

- product recovery
- reduced wastewater loading
- reduced water use
- reduced chemical use

Good design and layout of equipment are essential to easy cleaning.

- Design equipment that minimizes spills, leaks, and residual product that must be removed before cleaning.
- For closed systems such as tanks and piping, eliminate “low spots” so equipment can easily and completely drain.
- Provide easy access to all areas of the equipment that must be cleaned.
- Select materials and surfaces that are easily cleaned.
- Change procedures to reduce the need for cleaning.

As an example, a medium-sized bakery in Minnesota used 65 to 100 buckets a day for storing icing. Washing these buckets required approximately three hours of labor each day, and icing that stuck to the bottom and sides was wasted. They replaced the one-bucket-at-a-time preparation method with a large vat. This reduced the number of containers that had to be washed to three large ones and saved up to \$2,000 a year in icing that was being wasted. It also reduced washing time from three hours a day to a few minutes, thus saving water (Minnesota Technical Assistance Program).

Clean-in-place methods range from flooding the equipment with hot water, detergent, and chemicals, to dry cleaning. Dry cleaning as a first step is essential for saving water, since it reduces the water needed in the wet-cleaning phase, sometimes eliminating it completely. Dry cleaning includes:

- removing as much otherwise-wasted product as possible by pouring and storage for future use
- scraping equipment and vessels to remove as much waste as possible

- using dry brushes, cloths, and paper towels to remove waste
- using wet towels

Dry cleaning can be labor intensive, but the labor costs are offset by the potential to recover product, reduce pollution loading, and potentially clean equipment more thoroughly. It also allows employees to closely examine equipment and discover possible mechanical problems at an early stage.

Where water is used for cleaning, it is important to employ the “multiple aliquots” concept, in which it is better to use a number of smaller volumes of water to clean than one very large volume. For mixers, extrusion and molding equipment, conveyor belts, and other open equipment to which one can gain direct access, cleaning should start with physical removal of residual materials and then be followed by wet washing. Four principles of wet cleaning are:

- use high-pressure, low-volume sprays
- install shutoffs on all cleaning equipment
- use detergents and sanitizing chemicals that are easily removed with minimum water
- install and locate drains and sumps so water and wastes enter quickly to prevent the use of a hose as a broom

For closed vessels, pipes, and delivery tubs, cleaning techniques are very different. They require “Clean in Place” (CIP) and “Sanitize in Place” (SIP) methods. Before cleaning a process piping system, it is essential to remove as much of the product as possible. At its simplest, this involves draining the tank or piping system. Designing the piping to eliminate low spots that can trap product is a major aid in this process. Following this, several methods can be employed to remove extra product and clean the vessel and piping. For piping, three methods find common use, including:

- slug rinsing
- air blowing
- “pigging”

Pigging is a process in which a flexible rubber or plastic projectile is forced through a pipe to push the product out. In Europe a technique using “ice pigging” has recently been developed that uses ice slurry. The pig is forced through the pipe with air, water, or cleaning fluids. CIP systems can also be designed to reuse water and chemicals, if product safety allows.

For vessels, a ball that sprays water in all directions has historically been employed for washing. Replacing that with a high-pressure, low-volume rotating spray that washes product down the sides can reduce the amount of water needed. In many cases, this dilute first rinse can be captured and product recovered. In the dairy industry, pasteurization tanks must be filled with hot water after cleaning to pre-pasteurize the vessels. This water is often captured and reused as wash water for other CIP needs, thus saving both water and energy, since the water is already hot.

Vessel-, barrel-, and cask-cleaning water can also be used for irrigation in the winery industry and, to some extent, in the brewing and vegetable- and fruit-processing industries. The use of this water for irrigation also removes solids and BOD from the waste stream and places it where it becomes an asset to growing plant material.

Container (Bottles, Cans, Cartons, etc.) Cleaning

Cleaning bottles, cans, and containers prior to filling is common throughout the industry. For returnable bottles, the use of air bursts to remove loose debris and materials and the reuse of water from can

warming and other operations are common ways to reduce water use. Other methods include use of pressure sprays and steam instead of high-volumes of hot water to clean containers.

One brewery recovered the bottle wash water and used it for washing the crates in which the bottles are placed. This saved more than 4,500 gallons of water a day (Hagler).

Cleaning cans, bottles, and containers after they have been filled offers other opportunities. Some spillage and overfilling is inevitable, but with proper equipment control this can be minimized. Reducing water use to a minimum and passing the wash water through nanofiltration can recover both the sugars and product for use as animal feed or for growing yeast, while the water is cleaned and made available for additional reuse.

Lubricating Can and Bottle Conveyor Belts

One of the most unusual uses of water in the food and beverage industry is as a lubricant for conveyor belts that move cans and bottles, so they can “slip” easily on the high-speed conveyor belts and not tip over. This water is softened and mixed with biocides and soaps before it is sprayed onto the conveyors. Many attempts have been made to use dry lubrication systems or find other ways to move the cans and bottles at the high speeds needed in modern operations, but the use of water as a lubricant remains the standard for this industry. Many have been able to reduce water use or even capture and recover belt lubricant water. In Australia, eight Cadbury Schweppes plants are testing dry lubricant conveyor systems (Smart Water Fund of Australia). For now, ensuring that the spray nozzles are properly sized, well aligned, and equipped with automatic shutoffs is the best that can be done.

Can and Bottle Warming and Cooling

Water has a variety of applications, ranging from cooling or heating cans to use as a heat-transfer agent. This water remains relatively clean and is an excellent source of water for reuse. Water is used to cool cans after they have been removed from pressure cookers in the canning process. In most cases this water is cooled in a cooling tower or a refrigeration unit that employs a cooling tower in the process. In the warming process, cans and bottles from the beverage industry that have been filled with cold liquids are heated so condensate does not form on them and they dry more quickly before packing. These operations offer significant opportunities for reuse for almost all of the other water needs in the operation, except where potable quality is required by regulation. Examples of reuse include:

- first rinse in the wash cycle
- can and bottle shredder and crusher operations
- filter backwash for product filters
- chemical-mixing water
- defrosting of refrigeration coils
- use for equipment or floor cleaning
- flushing out shipment containers and crates
- cleaning of transport truck and rail cars
- gutter and sewer flushing
- fluming and washing of fruits and vegetables
- makeup water for conveyor lubrication systems
- irrigation
- cooling-tower makeup water

Product Ingredients

Most food products contain water and, in the case of the beverage industry, water is usually a major component of the product. To both reduce water use and loading on wastewater systems requires proper instrumentation and control of filling and packaging operations. The solid waste by-products of brewery, winery, fruit and vegetable processing, and meat processing operations, as examples, can often be used as animal feed or be rendered for other uses. Liquid wastes can also find use in other industries, for example, fruit juice by-product can be used to produce alcohol.

Water-Savings Potential

Examples of practices and water savings are provided above. Because of the varied nature of the products and processes found in the food-and-beverage-processing industry, water-savings potential is slightly different for each. These six design principles will help build water efficiency into a facility:

- design the facility for ease of cleaning
- provide adequate metering, submetering, and process control
- set up the facility to take advantage of dry methods for cleanup and transport
- use product and by-product recovery systems
- incorporate water reuse and recycling
- design for minimal or no water use

Cost-Effectiveness Analysis

Because of the highly varied nature of the food-and-beverage-manufacturing industry, a cost analysis across the industry is not possible. However, several cost areas need to be taken into consideration, including these seven:

- water
- wastewater disposal
- pretreatment
- chemicals for cleaning and sanitizing
- solid waste handling
- energy
- potential to produce a marketable by-product

Recommendations

Proven Practices for Superior Performance

- Require that new facilities provide a list of possible areas of water recovery and reuse.
- Require that all major water-using areas be separately metered.
- Require automatic shutoff and solenoid valves on all hoses and water-using equipment, where applicable.

Additional Practices That Achieve Significant Savings

- Use pigging, air blowing, or slug washing as part of CIP systems for process pipes.
- Use floor cleaning and vacuum machines where possible.
- Minimize the use of water-lubricated conveyor belts.
- Minimize the need to use a hose as a broom by installing drains close to areas where liquid discharges are expected.
- Provide pressure-washing equipment in place of washdown hoses.

References

A&B Processing Systems (201 South Wisconsin Ave, Stratford, Wisconsin). **A Guide to Clean In Place (CIP).**

_____. **Product Recovery Systems (Pigging Systems) in the Process Industry.**

Aquacraft, Inc. for the California Department of Water Resources and U.S. Bureau of Reclamation. 2003. **Demonstration of Water Conservation Opportunities in Urban Supermarkets.**

Carawan, Roy E. **Liquid Assets for Your Bakery.** March 1966. North Carolina Cooperative Extension Service Publication No. CD-41.

Commonwealth of Pennsylvania. Department of Environmental Protection. **Water Conservation Ideas for the Beverage Industry.**

Costello, Jim. Spring 2001. "Brewing Up Prevention Ideas." **Newsletter.** University of Minnesota Technical Assistance Program.

Encyclopedia Britannica. "Carbonated Soft-Drink Manufacturing." concise.britannica.com/ebc/art-54000.

Environmental Technology Best Practices Program. **Reducing the Cost of Cleaning in the Food and Drink Industry.** Report No. GG 157. www.etsu.com/etbpp/.

GDS Associates, Chris Brown Consulting, Axiom-Blair Engineering, Inc., Tony Gregg, PE. 2004. **Water Conservation Best Management Practices Guide.** Texas Water Development Board. Austin, Texas.

Galitsky, Christian. 2004. **Best Winery: An Integrated Benchmarking and Energy and Water Management Tool.** Lawrence Berkeley National Laboratory.

Hagler Bailey Consulting. 1997. **Pollution Prevention Diagnostic Assessment — Brewery.** United States Office for International Development. Office of Environmental and Natural Resources.

Hoffman, H. W. (Bill). March 2006. **Building Reduced Water and Wastewater Cost into the Design.** Austin Water Utility. Austin, Texas.

Kentish, Graeme, and Morgan, Peter. October 2006. **Conversion of Product Conveyors from Wet Lubrication to Dry Lubrication.** Cadbury Schweppes, Tullamarie, Victoria, Australia.

Maryland Department of the Environment. **Water Saving Tips for Food Processing Facilities.**

_____. **Water Saving Tips for the Beverage Industry.**

Massachusetts Water Resources Authority. "Beverage/Food Processing Industries." **Water Conservation Bulletin No. 3.**

Minnesota Technical Assistance Program. October 2004. **Best Management Practices — Bakery.** University of Minnesota.

North Carolina Department of Environment and Natural Resources, Division of Pollution Prevention.

August 1998. **Water Efficiency Manual for Commercial, Industrial, and Institutional Facilities.**

Ogunbameru, Gus, Ph.C., Ch.E. 2004. **Best Management Practices for Selected Industries and Additional Resources.** Massachusetts Office of Technical Assistance.

Platts Research and Consulting. 2002. **Management of Energy Cost in Grocery Stores.** McGraw Hill Companies, Inc.

Rausch, Kent D, and Powell, Morgan G. 1997. **Dairy Processing Methods to Reduce Water Use and Liquid Waste Load.** Cooperative Extension Service. Kansas State University. Manhattan, Kansas.

North Carolina Department of Environment, Health, and Natural Resources. August 1995. **A Soft Drink Bottling Company — North Carolina.**

Smart Water Fund of Australia. 2007. “Cadbury Schweppes Australia & New Zealand aims to save over 20,000 kilolitres of water each year thanks to the Smart Water Fund.” www.smartwater.com.au.

Automotive Services

The automotive service and repair industry is one of the most ubiquitous types of commercial enterprises in any city. Establishments include:

- service stations
- oil change/lubrication
- body repair
- tune-up shops
- full-service repair shops
- fleet maintenance
- tire service

The design of a water-efficient shop depends to some extent upon the type of service offered. New air-quality regulations have also meant that shops have switched from solvent-based parts- and brake-cleaning systems to aqueous-based systems. Floor-cleaning with dry methods, preventing spills and leaks from entering the wastewater discharge system, and the proper design of oil separators have as much



Aqueous Parts Washer

fastt.navsea.navy.daps.dla.mil/frames/rec_4.htm

to do with pollution prevention as they do with water conservation. Washing of vehicles is covered in a separate section.

Description of End-Use and Water-Savings Potential

Three areas of operation offer both reduced water- and pollution-loading possibilities:

- proper design of aqueous parts- and brake-cleaning
- preventing pollution and reducing water use in shop-floor cleaning
- proper handling of spent fluids and oils

Aqueous Cleaning Equipment

The development of aqueous parts- and brake-cleaning equipment has been driven by air-quality requirements. Such systems can employ filtration for sludge removal and oil skimming. By filter-cleaning the water, it can be recycled, thus saving on total water-use.

Floor Cleaning

Keeping floors clean in the first place eliminates the need for frequent washing. Methods include:

- installing secondary containers under fluids-storage containers to catch leaks and using drip pans under vehicles being worked on
- using dry cleanup with hydrophobic mops for oil and using absorbent materials (kitty litter, rice hulls, pads, rags, pillows, and mats) to clean up spills
- sealing floors with an epoxy material, which significantly aids in cleanup and prevents oils and liquids from penetrating concrete floors
- providing floor-cleaning equipment that scrubs and vacuums up its own water
- eliminating the use of open hoses for cleanup and using pressure-washing equipment infrequently and for major cleanup events only
- marking drains clearly to ensure that floor drains are clearly differentiated from storm drains and all floor drains are connected to an oil separator

Handling of Spent Fluids

Recovery and recycling of radiator flush-water both saves water and reduces pollution loading. Using storage vessels designed to hold spent antifreeze and other fluids, such as oil and transmission fluid, both eliminates the need to clean and flush these fluids down a drain and is required as part of modern pollution-control methods. Water use in facilities that recycle radiator flush-water has been shown to be less than 10 percent of water use in non-recycling facilities (San Antonio Water System).

Cost-Effectiveness Analysis

A cost analysis of measures to reduce both water use and pollution from the auto-repair industry is now required in part by air-pollution and water-pollution regulations. Offsets to these costs include:

- reduced pretreatment costs
- reduced cost for solvents
- reduced water use

Recommendations

Proven Practices for Superior Performance

- Require new facilities to provide secondary containers to catch drips, leaks, and spills from stored liquids and solvents.
- Require shop floors to be sealed to ensure easy cleanup.
- Require automatic shutoff and solenoid valves on all hoses and water-using equipment, where applicable.
- Require aqueous parts- and brake-cleaning equipment to employ recirculating filtration to minimize the need to dump water.
- Require all drains to be properly identified.
- Have proper facilities for the capture, storage, and recycling of spent fluids, oils, and fuels, including antifreeze and radiator flush-water.

Additional Practices That Achieve Significant Savings

- Have pressure-washing equipment available.
- Have drip pans available at work stations to place under vehicles.

References

- Aqueous parts washer. fastt.navsea.navy.daps.dla.mil/frames/rec_4.htm. FASTT Director Charles E. Tittle, tittlece@navsea.navy.mil, DSN 326, (202)781-1833, ext. 230.
- California Department of Toxic Substance Control. **P2 Opportunities Checklist for Vehicle Maintenance Activities.**
- San Antonio Water System. June 1998. **Water Saver Awards.**
- U.S. Environmental Protection Agency. Region 9. **Auto Repair and Fleet Maintenance Pollution Prevention.** www.epa.gov/region09/waste/p2/autofleet/factauto.html.
- U.S. Navy. **Navy Water Conservation Guide for Shore Facilities.** portal.navfac.navy.mil/pls/portal/docs/PAGE/NAVFAC/NAVFAC_WW_PP/NAVFAC_NFESC_PP/ENVIRONMENTAL/EQIFS/WASTEWATER/08_WASTEWATER/lowflow.pdf

Printing and Paper Manufacturing

Description of End Use

At first glance, printing and paper manufacturing appear to be very different industries, but according to classification by the U.S. Census and the NAICS — North American Industrial Classification System — paper manufacturing ranges from making paper from trees to manufacturing converted paper products, such as paper containers, cups, boxes, bags, coated paper, envelopes, and stationery products. The focus of this discussion is the manufacturing of converted paper products and printing.

Producing paper from pulpwood and other fiber sources is the beginning process for all paper. It is also the most water- and energy-intensive stage in the life of a paper product. Five gallons of water are used to make one pound of paper (Weyerhaeuser). Recycling paper and cardboard products cuts this energy and water use in half (Kinsella). According to Conservatree, an organization that promotes paper recycling, most repulping for recycled paper is done at pulp and paper mills, where paper is made, or in special facilities that use the product to make such things as cellulose insulation or pulp products, such as egg cartons.

At these pulp and paper mills, a mixture of virgin and recycled pulp is rapidly becoming the most common source of paper and cardboard stock for commercial converted products. The majority of these products will be used for printing, ranging from stationery letterheads to paper bags and boxes (California EPA). Examples of finished products include:

- molded pulp products
- cardboard tubes
- roofing paper
- corrugated boxes
- paper bags
- tissue and toweling
- folded boxes
- cellulose padding

- stationery and envelopes
- paper cups and liquid containers

Operations to make these products do not involve the direct production of pulp, but do involve the processing of paper made from these products. The production of products from paper, cardboard stock, or dry pulp represents the types of operations found in most cities. Major operations most commonly involve:

- cutting and folding
- gluing
- coating
- printing

Cutting and folding, along with the handling of paper stock and products, is principally a dry process. Floor cleaning should follow principles outlined in the section on Cleaning and Sanitation. The last three of these operations involve wet or solvent cleaning of some type. The advent of water-soluble paints and inks has reduced volatile-organic-compound (VOC) emissions, but the use of water as a cleaning agent is more prevalent. The same principles used in cleaning equipment in the food and beverage processing industry apply here, with the addition of solvent cleaning, which is still used in many non-aqueous printing processes:

- Properly remove as much waste product as possible by pouring and storing for future use.
- Scrape equipment and vessels to remove as much waste as possible.
- Use dry brushes, cloths, and paper towels to remove waste.
- Use wet towels or solvent-soaked towels.
- Apply water or solvent only to areas to be cleaned.

Flexography, gravure, screen-printing, lithography, and digital processing are all common printing practices used today. To help save water, energy, materials, and time:

- Design the layout of equipment for easy access.
- Ensure that ink containers are easily sealed.
- Provide non-drying aerosol sprays to keep ink fountains from drying overnight.
- Ensure that presses have proper controls, such as automatic ink levelers.

Water-Savings Potential

The practices discussed above reduce water use by decreasing the amount of cleaning required at the end of the press run. Other water-saving design practices are covered in the chapter on Photo and Film Processing under Commercial Printing. Printing operations also produce large amounts of waste heat in cooling the equipment. Large operations often have cooling towers. In these cases, water-saving techniques outlined in the section on Thermodynamic Processes should be referenced.

Cost-Effectiveness Analysis

Each case is unique, and overall cost analysis is not possible. However, the water-saving techniques outlined above will reduce operational costs by:

- reducing water and wastewater bills
- reducing pretreatment costs
- reducing product loss
- reducing chemical use
- eliminating waste

Recommendations

Manufacturing of Recycled-paper Products

- Properly remove as much waste product as possible by pouring and storing for future use.
- Scrape equipment and vessels to remove as much waste as possible.

Printing Operations

- Design the layout of the equipment to provide easy access.
- Provide non-drying aerosol sprays to keep ink fountains from drying overnight.
- Ensure the press has proper controls, such as automatic ink levelers.

See “Photo and Film Processing — Commercial Printing” for additional recommendations.

References

Alameda County Waste Management Authority and Recycling Board. www.stopwaste.org.

California Environmental Protection Agency. **California paper, Paperboard and Pulp Mills That Consume Postconsumer Paper.** www.ciwmb.ca.gov/Paper/Markets/.

City of San Jose, California. Environmental Services Department. **Best Management Practices to Reduce Pollution for Printing and Photo processing Operations.**

Conservatree. **Recycled and Environmental Paper Information.** San Francisco, California. www.conservatree.com/.

Eco-Efficiency Centre, The. Dalhousie University. 2006. **Fact Sheet: Eco-Efficiency in the Printing Industry.** Dartmouth, Nova Scotia.

Kinsella, Susan. **Fact Sheet: Buy Recycled Paper!** Buy Recycled Business Alliance of the National Recycling Coalition.

Weyerhaeuser. 2004. **2004 Roadmap for Sustainability.** www.weyerhaeuser.com/environment/sustainability/2004.

Metal Finishing

The metal-finishing industry offers many opportunities to reduce both water-use and pollution-abatement costs. The plating and anodizing processes involve a multi-tank, multi-step process. Water-saving practices include:

- drag-out control
- good tank design
- efficient rinse practices
- process controls and meters
- chemical recovery
- good exhaust-hood design

As with all industrial and commercial operations, efficient cleaning methods are key practices that will result in reduced water use.

Description of End Use

The classic example for the metal-finishing industry was once the plating of car bumpers (when chrome car bumpers were still manufactured). The industry involves much more than that today. For metals, it

includes electroplating, solution plating, and anodizing, but also printed circuit (wire) board and plastic plating. Chrome, zinc, copper, tin, nickel, gold, and silver are among the more common metals plated onto objects. In some processes objects are plated with two layers of metals, such as an under layer of copper followed by chrome.

One common process in this industry is that parts to be plated are moved sequentially from a treatment tank to a rinse or wash tank to another treatment tank to another rinse tank, until the desired number of plating steps have been accomplished. The photograph from the Corpus Christi, Texas, Army Depot, which follows, illustrates the multi-tank configuration of a typical metal-finishing process.

Water is used for the following process purposes:

- chemical and plating solution make-up
- rinsing
- fume-hood scrubbing
- equipment cleaning



**Corpus Christi Army Depot, Corpus Christi, Texas
Advanced Metal Finishing Processes and Facility**
(original date: 01/26/1998; revision date: 04/14/2003)

The typical sequence for plating an object is:

- Clean the object with baths that remove residual oil and dirt.
- Remove rust or oxidation products.
- Immerse the product in a plating bath through which an electric current is passed.
- Wash the parts.
- Either hang the parts being plated from specially designed racks or place them in perforated or woven baskets or “barrels,” so they can be moved easily from one tank to another.

As chemicals from one step build up in the following rinsing tanks or contaminate the process chemicals, water must be replaced. Fumes produced from all of the tanks, and the acid (pickling) and plating processes in particular, must be safely removed with fume hoods which then pass this contaminated air to scrubber systems to prevent air pollution. The typical configuration for these processes is illustrated on the following page.

Water savings can be realized in six areas:

- Drag-out control involves recovering liquid from parts being processed as they are removed from one tank, but before they enter another. The major reason to dump water is contamination of a rinse or process tank with liquid from the previous tank. Methods include:
 - » designing racks, baskets, and barrels so parts drain and do not retain liquids
 - » using turning, tilting, and “bumping” to remove excess liquid
 - » using drip or drain boards to collect and drain liquids back into the source tank
 - » allowing parts to remain over the tank for a few seconds (dwell time)
 - » washing or blowing contaminants back into process or dead tanks using fogs, sprays, or air knives
 - » using wetting agents
 - » using chemicals or heat to reduce plating-solution viscosity
 - » operating the solutions at minimum possible concentration
- The following tank-design methods reduce water use or allow for better reuse and recovery of metals:
 - » using air or mechanical agitation to promote mixing and good contact
 - » hard plumbing all piping so hoses cannot be left on inadvertently
 - » preventing short-circuiting of fluids
 - » sizing tanks to the minimum for the pieces to be plated
 - » segregating waste streams so both metals and water can be recovered more easily
- Efficient rinsing saves water and chemicals and reduces wastewater costs. Methods involve several technologies, including:
 - » using sprays on flat pieces of metal
 - » counter-current rinsing, where the piece is rinsed in successively less concentrated tanks, with the water from the first tank being used as feed for the second, and so on
 - » reactive rinsing, where the rinse water from the final tank is used for the pickle-rinse tank and the pickle-rinse tank water is used as feed to make up the alkaline-rinse tank (see figure following)
 - » air agitation of the tanks
- Flow- and process-control opportunities include:
 - » installing conductivity controllers to discharge water only if the chemicals have become too concentrated
 - » metering makeup water for good process control and to identify problems
 - » using flow restrictors to limit the amount of water being added

- Chemical and water recovery includes several water-treatment technologies:
 - » filtering plating fluid to remove suspended matter
 - » using membrane technology to recover metals and water
 - » using RO or deionization for the feed water for both rinse and process-fluid tanks to reduce interference from other ions
 - » regenerating spent acids
 - » using RO-reject water for cleanup around, but not in, the tanks
- Exhaust-hood design can also reduce water use by:
 - » Recirculating scrubber liquid
 - » Using scrubber water above plating tanks as make-up water for that process
 - » Using RO-reject water or similar reject streams as make-up water for scrubbers for which scrubber effluent will not be reused

Water-Savings Potential and Cost-Saving Examples

Following are examples from real operations of water-saving projects, their costs, and their savings. Because of the varied nature of this sector, each case must be examined separately, but the basic techniques have proven effective to:

- reduce water and wastewater costs
- reduce pretreatment costs
- reduce energy costs
- reduce chemical cost
- increase chemical and metals recovery rates
- reduce labor costs

Because of the wide variation in process design and operations, a simple cost analysis is not possible. Instead, the following examples are provided:

- Example 1 — A small plating shop in Australia that was using 360 gallons of water a day installed drain boards and a deionizer for \$590. The cost for servicing the deionizer is approximately \$780 per year. These measures cut water use by 65,000 gallons a year and saved over \$1,600 in chemical cost each year for a pay back of 1.3 years (Environmental Protection Agency of Victoria, Australia). [Based upon current U.S. dollars adjusted for inflation and currency conversion rate.]
- Example 2 — A large industrial operation in Illinois installed conductivity controllers on two tanks, reducing water use in the first tank from 5.0 to 0.45 gpm and in a second tank from 2.0 to 0.5 gpm. The total installed cost for the conductivity controllers and valves was \$2,000. This saved over 3 million gallons of water a year (Brown).
- Example 3 — A Minnesota manufacturer installed conductivity controllers for \$2,100 and reduced water use by one million gallons a year (Minnesota Technical Assistance Program).

Recommendations

Proven Practices for Superior Performance

- Meter make-up water in new facilities.
- Employ counter-current rinsing.
- Control drag-out by applying at least two of the practices listed above.
- Use conductivity controllers for rinse tanks.
- Install automatic shutoff on all hoses.
- Recirculate water and/or use waste streams as makeup water for scrubbers.

Additional Practices That Achieve Significant Savings

- Employ good tank design.

- Mix or use air agitation of tank contents.
- Use multiple drag-out reduction methods.
- Install filtration and water-treatment equipment, where applicable.
- Use reactive rinsing.

References

- Brown, Jerry. 2000. **Pollution Prevention Case Study – Conductivity Controller Technology**. TN -72. Chicago, Illinois.
- CH2MHill. May 2002. **Air Force Water Conservation Guidebook**.
- De Deitrich. **Electroplating Rinse Practices and Evaporator Sizing**. www.ddpsic.com.
- Department of Planning and Environmental Protection. Broward County, Florida. October 2003. **Pollution Prevention and Best Management Practices for Metal Finishing Facilities**. Fort Lauderdale, Florida.
- Donovan, Robert P., Morrison, Dennis J., and Timon, Robert P. November 1998. **Design of Recycling Systems for Spent Rinse Water in Sandia’s Microelectronics Development Laboratory**. International SEMATECH TT# 98113599A-ENG.
- Environmental Protection Agency of Victoria, Australia. 1993. **Waste Minimization—Assessment and Opportunities for Industry**. Southbank, Victoria. ISBN 07306-2888-4.
- Minnesota Technical Assistance Program. 1997. **Hoffman Engineering Saves \$32,000 Annually by Reducing Water Use**. www.mntap.umn.edu/intem/projects.
- Narragansett Bay Commission, The. **P2 Facts: Industrial Rinse Water Reduction**. Providence, Rhode Island.
- National Center for Manufacturing Science. 2007. **Printed Wire Board**. Printed Wire Board Resource Center. Ann Arbor, Michigan. Metal Products and Machinery (MP&M) PWB Subcategory. www.pwbrc.org/mpmpwb.cfm.
- New Mexico. Office of State Engineer. July 1999. **A Water Conservation Guide for Commercial, Institutional and Industrial Water Users**.
- North Carolina. Department of Environment and Natural Resources. Division of Pollution Prevention. August 1998. **Water Efficiency Manual for Commercial, Industrial, and Institutional Facilities**.
- Ogunbameru, Gus, Ph.C., Ch.E. 2004. **Best Management Practices for Selected Industries and Additional Resources**. Massachusetts Office of Technical Assistance.
- Rosemont Analytical Inc. 2003. **Water Conservation in Metal Finishing**. Emerson Process Management. Irvine, California.
- Thompson, Chris, and Lickteig, Edward. October 2008. **Recycling High Purity Rinsewater at Samsung Austin Semiconductor**. Samsung Austin Semiconductor. Ultrapure Water. Austin, Texas.

This page intentionally left blank.

Restrooms & Plumbing

Every building with a water supply uses plumbing to convey and control the water. Plumbing fixtures are a ubiquitous part of our daily lives. Almost all buildings used by people have at least one restroom. Examples are schools, hospitals, hotels, service stations, stores, government buildings, places of worship, office buildings, convenience stores, and entertainment sites.

Because of the large numbers of plumbing fixtures and the enormous amounts of water they collectively use, federal and California statutes set water-use standards for some fixtures and appliances. Manufacturers and water interests have continued to examine opportunities for water efficiency and associated energy efficiency. In addition, performance testing for some plumbing fixtures resulted in new specifications, such as the EPA WaterSense specification for high-efficiency toilets (HETs). New specifications for faucets and shower heads are being developed, resulting in a series of improved products. Restroom and plumbing fixtures are prime targets for new design or retrofit with high-efficiency technologies.

Water-using technologies that have specific potential for water conservation are discussed in this section. For each technology, alternative water-efficiency methods are scored “High” (better than 50 percent savings), “Medium” (10-50 percent savings), or “Low” (less than 10 percent savings) compared with standard technologies. These include:

Restroom and Bathroom Fixtures

- Toilets
- Urinals
- Showers and baths
- Floor-drain trap primers

Faucets

- Hand-washing lavatories
- Kitchen and food-service sinks
- Pre-rinse spray valves (*see “Food Service – Scullery”*)
- Janitorial (mop) sinks
- Outdoor faucets (hose-bibs)

Valves and Other Devices

- Emergency shut-off valve access and isolation valves
- Water-heater temperature pressure-relief (TPRVs) and relief valves
- Pumps
- Backflow preventers
- Fire-protection systems
- Surge tanks and other forms of potable water storage

The following checklist may be used for approving selection of equipment for restrooms and bathrooms, as well as plumbing fixtures.

Plumbing fixtures are a ubiquitous part of our daily lives. Restrooms and plumbing fixtures are prime targets for new design or retrofit with high-efficiency technologies.

Checklist of Water-Efficiency Measures for Restrooms and Plumbing Fixtures

End Water Use	Proven Practices	Additional Practices
Restroom and Bathroom Fixtures		
Toilets	<input type="checkbox"/> Not more than 1.3 gallons per flush (gps)	<input type="checkbox"/> Non-potable water for flushing where codes and health departments permit
Urinals	<input type="checkbox"/> 0.5 gallon or less per flush <input type="checkbox"/> Prohibit continuous water-flushing systems <input type="checkbox"/> Prohibit automatic water-flushing systems	<input type="checkbox"/> .25 gallons or 1 liter per flush or less <input type="checkbox"/> Non-potable water for flushing, where codes and health departments permit
Showers and baths	<input type="checkbox"/> Prohibit shower heads that have a flow rate greater than 2.0 gallons per minute (gpm) <input type="checkbox"/> One shower head per personal shower stall (ensure that a properly selected mixing valve is used to reduce scalding hazards) <input type="checkbox"/> For group showers, such as in school gyms and prisons, require individual valves for each shower head	<input type="checkbox"/> Specify use of timers on recirculating hot-water systems for large buildings <input type="checkbox"/> Select point-of-use hot-water heaters for small applications <input type="checkbox"/> Substitute showers for bathtubs whenever possible <input type="checkbox"/> If bathtubs are necessary, use low-volume tubs
Floor-drain trap primers	<input type="checkbox"/> Meet plumbing codes	<input type="checkbox"/> Avoid continuous-flow trap primers <input type="checkbox"/> Install pressure-activated or electronic trap primers, each serving several drains
Faucets		
Hand-washing lavatories	<input type="checkbox"/> Prohibit emitting more than 1.5 gpm at 60 pounds per square inch (psi) or meet the USEPA WaterSense standard, whichever is less, for residential faucets <input type="checkbox"/> Use laminar-flow faucets that use no more than 1.5 gpm, where required in medical facilities <input type="checkbox"/> Use self-closing faucets with flows of 0.5 gpm or less in public restrooms	<input type="checkbox"/> Commercial lavatory faucets should use no more than 1.0 gpm <input type="checkbox"/> Low-flow-rate faucets with unremovable aerators are also available
Kitchen and food-service sinks	<input type="checkbox"/> Flow should not exceed 2.2 gpm	<input type="checkbox"/> Install variable-flow aerators on faucets
Pre-rinse spray valves (see "Food Service – Scullery")	<input type="checkbox"/> Use pre-rinse spray valves for dish rinsing <input type="checkbox"/> Prohibit valves that emit more than the current flow standard (1.5 gpm in 2007)	
Janitorial (mop) sinks	<input type="checkbox"/> Faucet flow not to exceed 2.2 gpm	

End Water Use	Proven Practices	Additional Practices
Outdoor faucets (hose bibs)	<ul style="list-style-type: none"> <input type="checkbox"/> Faucet flow should not exceed 5.0 gpm 	<ul style="list-style-type: none"> <input type="checkbox"/> Install outdoor pipes and fixtures so they can be drained before freezing weather <input type="checkbox"/> For hose bibs attached to walls of heated buildings, use freeze-proof bibs <input type="checkbox"/> Install self-closing nozzles and valves on equipment connected to hose bibs
Valves and Other Devices		
Emergency shut-off valve access and isolation valves	<ul style="list-style-type: none"> <input type="checkbox"/> Meet plumbing codes 	<ul style="list-style-type: none"> <input type="checkbox"/> Add isolation valves to all pieces of water-using equipment, if not provided by the manufacturer <input type="checkbox"/> Place additional emergency shut-off valves near critical water-use areas <input type="checkbox"/> Plainly mark the location of emergency shut-off valves <input type="checkbox"/> Attach information on the valve, stating which portions of the facility are supplied by the valve
Water-heater temperature pressure-relief valves (TPRVs) and relief valves	<ul style="list-style-type: none"> <input type="checkbox"/> Meet plumbing codes 	<ul style="list-style-type: none"> <input type="checkbox"/> Make the outlets to valve-discharge pipes easy to inspect for flow <input type="checkbox"/> Insert visible indicators that will show if the valve has activated
Pumps	<ul style="list-style-type: none"> <input type="checkbox"/> Meet plumbing codes 	<ul style="list-style-type: none"> <input type="checkbox"/> Choose pumps with mechanical seals rather than packing <input type="checkbox"/> Carefully test pumps upon installation and initial operation
Backflow preventers	<ul style="list-style-type: none"> <input type="checkbox"/> Install backflow preventers and vacuum breakers as required by code and utilities 	<ul style="list-style-type: none"> <input type="checkbox"/> Locate devices in easy-to-observe locations, and provide easy access for inspection and testing
Fire-protection systems	<ul style="list-style-type: none"> <input type="checkbox"/> No connections to fire-protection system except for fire protection <input type="checkbox"/> Install flow-detection meters on fire services 	<ul style="list-style-type: none"> <input type="checkbox"/> Conspicuously mark fire-protection-system plumbing
Surge tanks and other forms of potable-water storage		<ul style="list-style-type: none"> <input type="checkbox"/> Provide visible and audible signals when tanks overflow <input type="checkbox"/> Provide monitoring wells to capture and make visible any leakage

Restrooms & Bathroom Fixtures

Water-use standards for plumbing fixtures used in restrooms were set by both federal and California statute and are now included in the Uniform Building Codes. The current code sets the following maximum-flow requirements:

Type of Fixture	California Maximum Rate of Water Use	EPA WaterSense or High-Efficiency (HE) Specification
Toilets (tank-type)	1.6 gpf	1.28 gpf (USEPA WaterSense 2007 standard)
Toilets (flush-valve)	1.6 gpf	1.3 gpf (HE)
Urinals	1.0 gpf	0.5 gpf (HE)
Shower heads (except for safety uses)	2.2 gpm at 60 psi	2.0 gpm (HE)
Lavatory faucets	2.2 gpm at 60 psi	1.5 gpf at 60 psi for lavatory faucets (draft WaterSense)
Self-closing faucets	Public restrooms use self-closing faucets with flows of 0.5 gpm or less	
Metering faucets	0.25 gallons per cycle	

Since these standards were set a decade ago, advances to improve water efficiency in plumbing fixtures have continued. New models have come to the market that improve water efficiency and, sometimes, energy efficiency by as much as 20 percent. The initial cost of the new higher efficiency models is in the same range as the better quality older models. Choice of plumbing fixtures for new structures should be driven not by the minimum standards, but rather by the life-cycle cost for the building operator.

In addition to fixtures that are more water-efficient, non-potable water supplies are being used to flush toilets. These water supplies include treated municipal wastewater and lavatory wash water. To date the acceptance is limited, but the potential for water savings is large.

Toilets

A few models of the early 1990's gave water-efficient toilets a bad name by failing to remove the waste with a single flush. Since then manufacturers have redesigned the shape of the bowl, the diameter and glazing of the trapway, and the water volume used to achieve effective performance. Continued improvements are subjected to improved testing standards for endorsement by water utilities and government agencies. Now, the highest efficiency models have been well documented to perform better than older high-flush-volume toilets (Veritec and Koeller, 2006).

A toilet flush can be actuated by manual mechanical levers, push buttons, or electronic sensors. The hands-free sensors eliminate the need for human contact with the valve, but sometimes flush needlessly while the toilet is still in use. Some studies have shown that these hands-free sensors actually use more water than manually activated models.

Although the primary purpose of toilets is to remove human waste and initiate transportation to a wastewater treatment facility, toilets in public places are often used to dispose of other materials. Toilets for public locations should have a glazed trap of at least two inches diameter — the bigger the diameter the better to prevent clogging.

Major requirements for minimizing water use in toilet operations include: (1) flush the toilet bowl clear, (2) transport waste through pipelines to the sanitary sewer, (3) operate reliably, and (4) have a leak-proof discharge valve.

Description of End Use

Toilets come with a variety of features:

- Floor-mounted or wall-mounted
- Methods of actuating flush:
 - » Traditional lever
 - » Push-buttons
 - » Electronic sensors
- Flush mechanism
- Volume of water used per flush
- Glazing and diameter of the trap
- Models for prison use



Aquia Dual-flush Toilet

Water-Savings Potential

Water consumption for any toilet installation varies with the number of employees, customers, or visitors and the type of activity at the site. An American Water Works Association (AWWA) Research Foundation study found that:

- Office buildings are prime candidates for high-efficiency plumbing fixtures and appliances.
- Restaurant toilet and urinal use is significant and would benefit from high-efficiency devices.
- Supermarket bathrooms receive a surprising amount of use and would benefit from high-efficiency fixtures.
- One-half to three-fourths of hotel indoor water use was for toilets, faucets, and showers. These should be the first targets of a hotel water conservation program. Leakage from stuck flappers in toilets yielded a significant loss of water, with some toilets running for days.

High-efficiency toilets (HETs), dual-flush, and pressure-assisted models all use at least 20 percent less water than ultra-low-flow toilets (ULFTs), at an average of 1.3 gpf.

Some toilets use flush valves or internal tanks to control flush volume. Others use “flapper valves.” Flapper valves have had leakage problems. Leak-free replacement of flapper valves may require the toilet manufacturer name and model number. It is hoped that future flapper-valve materials will resist the chemical and mechanical erosion that causes leaks.

Process or Equipment Alternatives	Water-Savings Potential
HETs using less than 1.3 gallons per flush	Medium
Non-potable water for flushing, where codes and health departments permit	High

Cost-Effectiveness Analysis

Example: HET (1.3 gpf) *versus* 1.6 gpf ULFT in an office building with 50 staff and 50 visitors per day.

- Estimated capital costs: The same for HET and ULFT.
- Estimated equipment lifetime: The same — up to 20 years.
- Water and energy savings: 20 percent water savings.
- Incremental cost per acre foot (AF) of efficient equipment: Zero. Annual savings per toilet are 0.004 AF of water and \$5.87 for water and wastewater charges. Over the toilet's lifetime, the savings achieved may be 0.072 AF and \$117.

Recommendations

Proven Practices for Superior Performance

- Toilets that use not more than 1.28 gallons per flush.

Additional Practices That Achieve Significant Savings

- Use non-potable water for flushing, where codes and health departments permit.

Urinals

Description of End Use

Urinals are made to accept liquid waste, but not solid waste. They come in several configurations and combinations of features:

- Wall-mounted urinals for single-person use. These are flushed after each use, either manually by the user or by automatic actuator.
- Wall mounted troughs for simultaneous multiple-person use. Intended for high-use areas such as sports venues, they are flushed continuously during the high-use period and are controlled with a valve and timer, but not by the user.
- Wall-mounted waterless urinals for single-person use that require neither flushing nor water-supply plumbing.

Water-Savings Potential

Potential for savings depends upon the number of users at the site. Males use urinals more often than they do toilets in buildings with both fixtures available. Based upon U.S. Green Building Council numbers, males use urinals two to three times a day. Facilities where large numbers of males work or gather have the largest potential for water savings.

Process or Equipment Alternatives	Water-Savings Potential
Prohibit continuous water-flushing systems in urinals and toilets	Medium to High
Prohibit automatic optical or motion-sensing flushing systems for toilets and urinals	Medium
Install urinals using 0.5 gpf or less	High
Install urinals using 1.0 pint per flush or waterless urinals	High
Use non-potable water for flushing, where codes and health departments permit	High

Urinal Type	Flush Volume	Cost Range
Automatic-flush urinal	1.0 gpf	\$600-900 with electronic sensor
Electronic-flush valve	N/A	\$160-530
Manual-flush urinal	1.0 gpf	\$300-325
Manual-flush valve	N/a	\$70-200
No water — no flush	0	\$520-600
Automatic-flush urinal with proximity flush sensor	0.5 gpf	\$625
Urinal without flush valve	0.5 gpf	\$300
Trough – 6 foot length	variable	\$1700 with flush pipe and valve

Urinal Dis-charge Volume	Annual Water Volume in Gallons	Annual Savings Compared to 1.0 gpf Urinal	Annual Water & Wastewater Fees at \$2.85/Ccf*	Annual Water & Wastewater Savings Compared with 1.0 gpf Urinal
1.0 gpf	19,500	0	\$74	\$ 0
0.5 gpf	9,750	9,759	\$37	\$37
Waterless	0	19,500	0	\$74

*Ccf = one-hundred cubic feet

Cost-Effectiveness Analysis

Examples: Compare urinals requiring flush volumes of 1.0 gpf, 0.5 gpf, and 0 gpf (waterless).

- Equipment capital costs:
 - » New urinal with automatic flush valve cost is about \$625.
 - » New waterless urinal cost is \$500. Operational costs for sealant fluid and quarterly cartridge replacement are \$240 per year.
- Estimated equipment life: Approximately 10 years for all types, per Federal Emergency Management Agency (FEMA).
- Water and energy savings: Assuming 2 uses per day per male employee, and 25 male employees and 25 male visitors per day, 260 work days per year.
- Water-efficient urinals reduce the need to pump water to higher elevations in high-rise buildings.
- Incremental cost per AF of efficient equipment:
 - » During the 10-year life of the equipment, capital and operating costs of the 0.5 gpf urinal are approximately \$370 less than those of the 1.0 gpf urinal and \$1,275 less than for the waterless urinal.
 - » For the same 10-year period, the benefit of using the 0.5 gpf device *versus* the 1.0 gpf urinal is approximately \$7,450 per AF.

Recommendations

Proven Practices for Superior Performance

- 1 gallon or less per flush urinals are required by code.
- Prohibit continuous water-flushing systems in urinals and toilets.
- Prohibit automatic water-flushing systems in toilets.

Additional Practices That Achieve Significant Savings

- Install urinals using 0.5 gpf or less.
- Use non-potable water for flushing, where codes and health departments permit and where reclaimed water is available.

Showers and Baths

Description of End Use

Both showers and baths are used for personal hygiene. Conventional bathtubs have a water capacity of 40-50 gallons. The hospitality sector touts the relaxation and luxury of infinity and whirlpool baths (approximately 90 gallons per fill). Medical facilities and nursing homes may have tubs with a lift to lower patients into the water. Normally this water is used once, then discharged to waste. Proper mixing valves should be installed in showers to prevent scalding hazards.

Hot tubs are also popular. The water (several hundred gallons) is often circulated through filters and heaters. Disinfectants are added manually or in the recirculation cycle. When not in use, they should be covered to reduce loss of heat and water.

Shower heads are available with a variety of spray patterns, water-droplet sizes, and pulsations. Both shower and bathtub water are used and typically discharged to sanitary wastewater. In locker rooms and similar situations, several people may wash in a communal shower room with multiple shower heads. Tubs come in various sizes. The use of standard-size tubs should be recommended, since they hold, and therefore use, less water.

Excluded from this discussion are shower heads required for emergency cleaning of personnel due to chemical and other contamination.

Water-Savings Potential

Choose shower heads that perform well, are vandal- and tamper-proof, and limit flow to 2.0 or less gpm (at 60 psi) collectively for all shower heads in the shower stall. In locker-room showers, flow to each shower head should be controlled individually by the user.

Select shallower bathtubs that have smaller water capacity. The water level will cover the bather when immersed.

In the hospitality sector, hot water is often circulated from a water heater, through a pipeline loop, to the guest rooms. Unused water returns to the water heater. This provides hot water quickly to the guest showers/baths and reduces the water wasted while waiting for warm water. The circulated hot water should be placed on a timer (may increase energy use).

Where plumbing code and health officials allow, the wastewater from showers and baths may be captured, treated, and redirected for toilet flushing or other non-potable, non-contact uses.

Process or Equipment Alternatives	Water-Savings Potential
Use shower heads that allow not more than 2.0 gpm	3.5 gallons/shower
Install only one shower head per personal shower stall	30 gallons/shower
Install individual valves for each shower head in a gang-type shower	Medium
Specify recirculating hot-water systems for large buildings	High
Select point-of-use hot-water heaters for small applications	Medium
Substitute showers for bathtubs whenever possible	20 gallons/shower
If bathtubs are necessary, use low-volume tubs	15 gallons

Recommendations

Proven Practices for Superior Performance

- Use shower heads that allow flow of not more than 2.0 gpm.
- Install only one shower head per personal shower stall.
- For group showers, install individual valves to control each shower head.


Additional Practices That Achieve Significant Savings

- Specify recirculating hot-water systems for large buildings.
- Select point-of-use hot-water heaters for small applications (do not use on recirculating lines or at the far end of the water line).
- Substitute showers for bathtubs whenever possible.
- If bathtubs are necessary, use low-volume tubs.

Floor-drain Trap Primer

Description of End Use

Floor drains often exist in spaces where regular water use may spill or where floors may be washed frequently. Plumbing codes require traps to prevent gases and odors from seeping from sanitary sewers into the room through the drains. The gas is blocked by water trapped below the drain in an “S” shaped pipe called a “P trap.” In some rooms the trapped water dries up (evaporates) when the floor is seldom washed, damp-mop floor-cleaning methods are used, or little water reaches the drain. This condition may allow the sewer gasses, other odors, and/or vermin to enter the room.



(Adapted from J.R. Smith Manufacturing Co.)

To sustain water in the trap, additional water must be added with a device called a trap primer. A trap primer is a valve or other connection from a water source that allows a small amount of water to flow through pipes to recharge traps of one or more drains. The common types of trap primers include:

- continuous flow
- pressure-drop activated
- flush-valve activated
- electronically timed


Water sources include cold-water pipes, the discharge side of flush valves, or wash-basin drain pipes, depending upon the distance to the drain and the frequency that the supply device provides water. One concern is that a seldom-used valve might provide inadequate water to maintain the trap function. The opposite concern is that continuous-flow primers waste water. Automatic or electronic controllers, such as the Zurn model pictured on the next page, allow the option to set the volume and frequency of flow. Other types of trap primers sense a pressure change in the supply line and allow a small amount of water to trickle to the trap.

Where drains are used as sanitary sewers, such as in animal pens, additional water may be applied to the drain rim to flush debris from the surface of the drain.

Another alternative, where code and conditions permit, is to manually add a fluid, such as water, to the drain. On the other hand, if maintenance staff remembered to add water to the trap, there would be no need for the plumbing codes to call for trap primers.

Water-Savings Potential

The most efficient floor-trap primer will have a connection size and discharge frequency that provides a volume of water only slightly greater than the evaporation from the trap. Most pressure-sensitive, flush-activated or electronic trap primers discharge only a few ounces of water for each outlet during each operating cycle. Primers connected to sink drains use wastewater. However the debris screens to these inlets need to be cleaned periodically.



Zurn Electronic Trap Primer Model Z1020

Sample Water Use of Trap Primers

Primer Type	Number of Actuations per Day	Daily Water Use per Drain Served	Annual Water Use in Gallons
Continuous	Continuous	0.25 gpm yields 360 gallons per day (gpd)	131,400
Flush-activated	Depends upon flush valve use	For 10 flushes: 10 × 1 oz = 0.08 gallons	28
Pressure-sensitive	Depends upon fixture use	For 10 uses: 10 × 1 oz = 0.08 gallons	28
Electronic	1	0.008 Gallons	3

Process or Equipment Alternatives	Water-Savings Potential
Avoid continuous-flow trap primers	High
Install pressure-activated or electronic trap primers, each serving several drains	High

Cost-Effectiveness Analysis

Example: Compare continuous-flow with pressure- or flush-activated trap-flow primers.

- Equipment capital costs: When compared on a per-drain-served basis, the costs are very similar: between \$5 and 20 per drain.
- Estimated equipment life: The same.
- Water and energy savings: Annual water use for a continuous-flow device at 0.25 gpm is 131,400 gallons, compared with 30 gallons per year for a flush-activated primer connected to a flush valve used 10 times per day.
- Incremental cost per AF of efficient equipment: Water and wastewater fee savings (at \$2.85 per Ccf) for 131,370 gallons is \$783 per year or \$1942 per AF.

Recommendations

Proven Practices for Superior Performance

- Meet plumbing code.

Additional Practices That Achieve Significant Savings

- Avoid continuous-flow trap primers.
- Install pressure-activated or electronic trap primers, each serving several drains.

Faucets

Faucets are valves operated by people for indoor purposes. Outdoor hand-operated valves are known as hose bibs.

Hand-Washing Lavatories

Description of End Use

Several types of faucets offer different flow durations and flow rates:

- Manually operated faucets require someone to open the valve and to close the valve.
- Self-closing faucets run as long as the user holds the handle in the open position. Once released, the spring-loaded faucet closes itself.
- Metering faucets are actuated manually or automatically. They deliver a preset amount of water (some models deliver 0.25 gallons during a 5- to 10-second cycle; others models have cycles that can be set to 45 seconds) before shutting off. Operating conditions, such as water pressure, temperature, and flow rate, may affect the timing cycle. Some manufacturers provide a 5-year warranty.
- Automatic faucets sense the proximity of the user and start the flow of water, which is maintained while the user is within sensor range. Then the faucet shuts itself off.
- Drinking-water bubblers operate with self-closing faucets.

Aerators may be added to faucets to entrain air, reduce splash, and reduce the water flow. Common aerator flow rates are 0.5, 1, and 2.2 gpm. An aerator is a circular screen disk attached to the end of the

faucet. Vandal- and tamper-proof aerators should be installed in non-residential buildings. Aerators with manual flow adjustment are available for kitchen faucets.

Because aerators entrain air which may contain pathogens into the water stream, and the pathogens may reside on the internal aerator screens, aerators should not be used in medical facilities. California regulations prohibit aerator use in hospitals, but laminar-flow restrictors may be used to prevent splash and reduce flow without air entrainment. Other aerators should be replaced or at least cleaned every few years.

Water-Savings Potential

- For public restrooms, hand washing for personal hygiene needs a minor flow rate to lubricate the soap, flush grime and bacteria from the skin, and rinse soap from the hands.
- For motel and hotel guest-room bathrooms, the wash basin is used for various hygiene and grooming purposes. The U.S. Environmental Protection Agency (USEPA) WaterSense program reports that flows of no more than 1.5 gallons per minute are adequate.
- For medical buildings, doctors' offices, and light industry or commercial facilities where business practices require regular hand washing, install self-closing faucets that are actuated with a foot pedal.
- Combining a self-closing faucet with a low-flow aerator provides water savings at nominal cost.

Process or Equipment Alternatives	Water-Savings Potential
Public restrooms should use self-closing faucets with flows of 0.5 gpm or less	High
Businesses with high hand-washing demand should use self-closing faucets with foot-pedal actuators	Medium to High
Lavatory faucets should use no more than 1.5 gpm @ 60 psi	Medium
Combination of a self-closing faucet with low-flow aerator or laminar-flow restrictor	Medium



Single-hole metering faucet

(Speakman Faucets www.plumbingsupply.com)



Drinking-water bubbler

(Chicago faucets www.plumbingsupply.com)

Cost-Effectiveness Analysis

Example: Manually operated faucet compared with a metering, self-closing faucet.

- Equipment capital costs: \$75 for manually operated faucet, compared with \$105 for a metering, self-closing faucet.
- Estimated equipment life: 5-15 years; assume 10 years.
- Water and energy savings:
 - » For a busy location, assume 50 uses per day for 260 days per year and a 10-year lifetime.
 - » A metering, self-closing faucet uses 0.25 gallons per cycle. Assume 1 cycle per person. Annual water consumption equals 3,250 gallons (0.01 AF). Over 10 years, consumption will be 32,500 gallons (0.10 AF).
 - » A manual 2.2 gpm faucet will stay on for at least 30 seconds, yielding approximately 1 gallon per use. Annual consumption will be 13,000 gallons (0.04 AF). Over 10 years, the consumption will be 130,000 gallons (0.40 AF).
- Incremental cost per AF of efficient equipment:
 - » Both faucets will incur the same rates for water and wastewater: \$2.85 per 100 cubic feet (748 gallons).
 - » Metering, self-closing faucet — the annual cost of water and wastewater will be \$12.38. Manual faucet — the annual cost of water and wastewater will be \$49.53.
 - » The \$30 difference in capital cost will be recovered in 9 months.
 - » Over its lifetime, the water-efficient equipment will save approximately \$1,100 per AF of water consumed.
 - » If warm water is used, the cost recovery will be accelerated.

Recommendations

Proven Practices for Superior Performance

- Faucets must not emit more than 1.5 gpm.
- Use laminar-flow faucets that use no more than 1.5 gpm, where required in medical buildings.
- Use self-closing faucets with flows not greater than 0.5 gpm in public restrooms.

Kitchen and Food-Service Sinks

Description of End Use

Kitchen sinks often need the full 2.2 gpm flow for filling pots and pans.

A refrigerator, not running water, should be used to thaw food. See “*Food Service — Refrigerators and Freezers.*”

Water-Savings Potential

- Install variable-flow aerators on faucets.
- Install automatic-shutoff faucets for bar sinks.
- Install manual shutoff valves on sink spray hoses. See “*Food Service — Pre-Rinse Spray Valves.*”
- Locate water heaters close to faucets and insulate hot-water lines to reduce water lost while waiting for hot water to flow from the faucet.

Process or Equipment Alternatives	Water Savings Potential
Install variable-flow aerators on faucets	Medium
Install manual shutoff valves on sink spray hoses	High
Install automatic shutoff faucets for bar sinks	Medium to high
Insulate hot-water pipelines and locate water heaters close to faucets	Medium

Cost-Effectiveness Analysis

Variable-flow swivel aerators cost less than \$6 each, compared with less than \$3 for fixed-flow aerators.

Recommendations

Proven Practices for Superior Performance

- Faucet flow should not exceed 2.2 gpm.

Additional Practices That Achieve Significant Savings

- Install variable-flow aerators on faucets.

Pre-Rinse Spray Valves – See “Food Service – Scullery” (Mop) Sinks

Description of End Use

Large wash basins or set tubs used for janitorial purposes provide water to multi-gallon containers for floor cleaning and mops. Large flows of 2.2 gpm are desired. Sometimes hoses are connected from the faucets to minimize splash and spills to the wash buckets.

Water-Savings Potential

Care exercised by the user will help to achieve water savings.

Recommendations

Proven Practices for Superior Performance

- Faucet flow should not exceed 2.2 gallons per minute.

Outdoor Faucets

Description of End Use

Outdoor faucets, often known as hose bibs, sill cocks, water spigots, or hose hydrants, are valves which are often threaded to allow easy connection to hoses, pressure washers, and other equipment. Not subject to the 2.2 gpm flow limitation, flows through hose bibs are determined by the equipment being used.

Water-Savings Potential

For hose bibs where vandalism and unauthorized use is a concern, use a “loose key.” Instead of an attached handle, there is a slot for a removable square key to be used to operate the hose bib. Alternatively, provide a locked box over the hose bib or eliminate hose bibs.

Prevent water waste from broken pipes and fixtures during freezing conditions:

- Install pipes so they can be drained before freezing occurs.
- For hose bibs attached to walls of heated buildings, use freeze-proof bibs that extend through the wall into a warm environment.

- Insulate pipes and plumbing attachments and add heat tape for seasonal use.
- Backflow preventers, meters, and all similar devices should be freeze-resistant and installed so as to guard against freezing.

Equipment, especially hoses, connected to hose bibs should all have self-closing nozzles.

Process or Equipment Alternatives	Water-Savings Potential
Use a “loose key” for hose bibs to reduce vandalism	Medium
For freezing climates, install outdoor pipes and fixtures so they can be drained before freezing weather	High
For freezing climates, use freeze-proof bibs to attach to walls of heated buildings	High
Install self-closing nozzles and valves on equipment connected to hose bibs	High

Cost-Effectiveness Analysis

Most of these recommendations can be achieved with minimal, if any, extra costs.

Example: regular hose bibs compared with freeze-proof hose bibs.

- Equipment capital costs: Minimal \$4 *versus* \$37 for a freeze-proof bib.
- Estimated equipment life: More than 5 years with washer replacements.
- Water and energy savings: Water savings may be achieved, but no wastewater savings.
- Incremental cost per AF of efficient equipment: N/A.

Recommendations

Proven Practices for Superior Performance

- Faucet flow should not exceed 2.2 gpm.

Additional Practices That Achieve Significant Savings

- Use a “loose key” for hose bibs to reduce vandalism.
- Install outdoor pipes and fixtures so they can be drained before freezing weather.
- Use freeze-proof hose bibs when attached to walls of heated buildings.
- Install self-closing nozzles and valves on equipment connected to hose bibs.

Valves and Other Devices

Devices listed in this section are used to limit losses during pipe ruptures, equipment failures, and other emergencies. Unlike much of the other equipment and processes described in this guide, these devices do not readily lend themselves to cost-effectiveness analysis. These controls may be inactive for many months or even years, then their function is immediate. In the meantime, small leaks or overflows may occur. Locate these devices to be easily seen, so leaks may be noted and corrective repairs performed.

Emergency Shutoff Valve and Isolation Valve Accessibility

Description of End Use

Emergency shutoff valves can be used to stop water flow when pipes rupture, connections leak, or equipment fails. During repairs, isolation valves can stop flows to individual pieces of equipment, while avoiding shutting down water to major portions of a building.

Water-Savings Potential

Shutoff valves are relatively cheap compared with the potential damage they can minimize. Their usefulness relates to how well they are marked and their accessibility. Never block access, and plainly mark the location of emergency shutoff valves near the valve site and in the area where the water is used.

If not supplied by the manufacturer, add an isolation valve to each piece of water-using equipment.

Process or Equipment Alternatives	Water-Savings Potential
Add isolation valves to all pieces of water-using equipment if not provided by the manufacturer	Low
Place additional emergency shutoff valves near critical water-use areas	Low
Plainly mark the location of emergency shutoff valves	Low
Attach information on the valve stating which portions of the facility are supplied by the valve	Low

Recommendations

Proven Practices for Superior Performance

- None.

Additional Practices That Achieve Significant Savings

- Add isolation valves to all pieces of water-using equipment if not provided by the manufacturer.
- Place additional emergency shutoff valves near critical water-use areas.
- Plainly mark the location of emergency shutoff valves.
- Attach information on the valve stating which portions of the facility are supplied by the valve.

Water-heater Temperature Pressure-relief Valves (TPRVs) and Relief Valves

Description of End Use

Located on the upper portion of the water tank, this valve prevents the build-up of hazardous pressure by releasing water to an overflow pipe. Water-supply pressure should be within the range recommended by appliance and equipment manufacturers — usually 40 to 60 psi.

Water-Savings Potential

Flows from the valve discharge pipe should be easy to observe. Place visible indicators to show when the valves are actuated and operations need to be corrected.

Process or Equipment Alternatives	Water-Savings Potential
Make valve discharge pipes easy to inspect for flow	Medium
Insert visible indicators that will show if the valve has activated	Low

Recommendations

Proven Practices for Superior Performance

- None.

Additional Practices That Achieve Significant Savings

- Make the outlets to valve discharge pipes easy to inspect for flow.
- Insert visible indicators that will show if the valve has activated.

Pumps

Description of End Use

Pumps are used with many fluids and gasses. Our focus is leakage that may occur from pumps used to move water and to increase water pressure.

Water-Savings Potential

Some vacuum pumps used in health-care facilities use water seals to avoid oil-vapor contamination of the vacuum lines. Choose newer vacuum pumps that do not use water seals. Choose pumps that are air-cooled. If a water-cooled pump is needed, do not use single-pass water-cooling systems. Instead, cool the pump motor with a cooling-water loop. *See “Thermodynamic Processes.”*

Pumps with packing glands have a reputation for leaks and frequent need for replacing the packing. Mechanical seals are superior to packing glands in that they are far less likely to fail and leak.

Process or Equipment Alternatives	Water-Savings Potential
Choose pumps with mechanical seals rather than packing	High
Carefully test pumps upon installation and initial operation to ensure leak-free operation	Medium

Recommendations

Proven Practices for Superior Performance

- None.

Additional Practices That Achieve Significant Savings

- Choose pumps with mechanical seals rather than packing
- Carefully test pumps upon installation and initial operation to ensure leak-free operation.

Backflow Preventers

Description of End Use

Backflow preventers and vacuum breakers are required by code so water supplies will not be contaminated by sources at the point of use. If one end of a hose, pipe, drain-trap primer, submersible pump, or other device could be in non-potable water, and if the back pressure of the non-potable water exceeds the supply pressure, this potentially bacteria-laden or contaminated water could be sucked back into the potable-water supply line.

By health regulation, backflow devices between public-water supplies and private facilities should be inspected and tested on a regular schedule. Check with the local water supplier.

Water-Savings Potential

In non-freezing climates, mount exterior backflow preventers above ground so any leaks may be easily observed. For interior devices, place small wells to collect any leak water where it may be observed and repairs ordered.

Process or Equipment Alternatives	Water-Savings Potential
Place backflow prevention devices in easy-to-observe locations and make access for inspection and testing easy	Low

Recommendations

Proven Practices for Superior Performance

- Backflow preventers and vacuum breakers are required by code.

Additional Practices That Achieve Significant Savings

- Place these devices in easy-to-observe locations, and make inspection and testing easy.

Fire-protection Systems

Description of End Use

On the customer premises, the fire-protection system is typically a dedicated plumbing system. No flow should occur except in case of fire emergency or testing. Connections by the customer for other purposes are prohibited.

Utilities meter and bill fire-protection water-supply lines separately from potable-water supplies for consumption. Flow-detection meters should be installed on fire-service flows to indicate cross connections and improper use of fire water. To have an effective program, these meters need to be read when other meter readings are taken.



Water-Savings Potential

To avoid any cross connections between fire-protection and water-supply plumbing, mark fire-protection plumbing conspicuously.

Install flow indicators to show the presence of leaks. Utilities may require flow-check meters capable of detecting small flows (less than 1 gpm) on the fire-supply line.

Process or Equipment Alternatives

Water-Savings Potential

Allow no connections to fire-protection systems except for fire protection

Place flow-detection meters on fire services

High

Conspicuously mark fire-protection-system plumbing

Low

Recommendations

Proven Practices for Superior Performance

- Allow no connections to fire-protection systems except for fire protection.
- Place flow-detection meters on fire services.

Additional Practices That Achieve Significant Savings

- Conspicuously mark fire-protection-system plumbing.

Surge Tanks and Other Forms of Potable-water Storage

Description of End Use

Storage tanks may be placed atop high-rise buildings to maintain pressure in the building.

Surge tanks absorb the pressure transients (water hammer) of fast-acting valves to reduce plumbing-system damage. Expansion tanks and pressure-relief tanks are safety devices to store expanded heated water and relieve pressure on the plumbing system.

Water-Savings Potential

Tanks and their fittings sometimes leak only intermittently when water pressure is higher. An observation well or collection basin can collect the leakage and provide visible evidence of the leak. Then repairs can be taken.

Altitude-control valves are supposed to sense the level of water in the tank and stop inflow if the storage level exceeds a specified elevation. If the altitude-control valve fails, the tank may overflow with great loss of water and sometimes property damage. The overflow is usually channeled through a pipe to a drain. Install a signal device to show that overflow has occurred.

Process or Equipment Alternatives	Water-Savings Potential
Provide discharge-flow monitors to record evidence and signal when tanks overflow	High
Provide monitoring wells to capture and make visible any leakage	Low

Recommendations

Proven Practices for Superior Performance

- None.

Additional Practices That Achieve Significant Savings

- Provide visible and audible signals when tanks overflow.
- Provide monitoring wells to capture and make any leakage visible.

References

California Urban Water Conservation Council. 2001. **The CII ULFT Savings Study.**

Chicago Faucet. **Chicago Faucet Maintenance and Repair Manual.** www.chicagofaucets.com/Repair_Manual_Wkr.pdf.

East Bay Municipal Utility District. EBMUD Toilet Rebate program.

Hansen, Rob. Zurn Plumbing, personal communication, and internet site www.zurn.com.

New Mexico. Office of the State Engineer. 1999. **A Water Conservation Guide for Commercial Institutional and Industrial Users.**

Plumbing products internet sites:

www.nextag.com

www.plumbingstore.com

www.sloan.com

www.americanstandard-us.com

www.plumbingproducts.com

www.mifab.com

Pacific Northwest National Laboratory. 2005. **Update of Market Assessment for Capturing Water Conservation Opportunities in the Federal Sector.**

U.S. Federal Energy Management Program. www.eere.energy.gov/femp/procurement/eep_toilets_urnals_calc.cfm.

U.S. Environmental Protection Agency. WaterSense Program. 2007. **High-Efficiency Bathroom Sink Faucet Specification.**

U.S. Environmental Protection Agency. WaterSense Program. www.epa.gov/WaterSense/.

Veritec Consulting Inc. November 2006. **Koeller and Company, Maximum Performance (MaP) Testing of Popular Toilets.**

Vickers, A. 2001. **Water Use and Conservation.**

Thermodynamic Processes

Most commercial locations have heating and cooling systems. Many are just for air conditioning comfort of users of the building, but some can be integral to the commercial or industrial use of a facility. This section deals with types of heating and cooling systems which use water as the medium for heat transfer.

Cooling Towers

- Instrumentation and metering
- Cycles of concentration
- Drift eliminators
- Other considerations

Boilers and Water Heating

- Instrumentation and metering
- Cycles of concentration
- Steam traps and condensate return
- Nitrogen oxide and other pollution-control considerations
- Other considerations

Air conditioning, refrigeration, process cooling, and dehumidification produce large quantities of “waste” heat that must be dispersed back into the environment. Heating of living- or workspace, humidification, process heating, and water heating all consume large quantities of energy, as well. The interplay of energy and water can have a significant impact on the efficiency with which each of these resources is used. For perspective, consider a cooling tower as a device used to get rid of *unwanted* energy by evaporating water and a boiler as a way to generate energy that will ultimately be thrown away, most often in the form of *unwanted* hot water or steam. In all of these processes, energy conservation will reduce water use and, conversely, water conservation will reduce energy use.

For example, capturing waste heat being rejected from an air-conditioning system for use in a cooling tower to preheat boiler feed-water will reduce both fuel needed to heat the water and the load on the cooling tower. This will result in reduced make-up water requirements for the tower. In another example, the use of cogeneration, such as using a gas turbine to generate electricity and then using the waste heat from the turbine to heat water, is being practiced today. Cogeneration results in both on-site water and energy savings, since the waste energy is reused and not rejected to a cooling system. Upstream, energy and water savings can also be realized.

In this section, the two major water-using devices found in thermodynamic operations, cooling towers and boilers, will be discussed, with recommendations for significant reductions in water and energy use.

Significant reductions in water and energy use can be realized with wise planning of heating and cooling systems, including cooling towers and boilers.


Cooling Towers

Description of End Use

Cooling towers reject heat (unwanted energy). Their most common applications in the commercial sector are to remove heat generated in a manufacturing process and for air conditioning and refrigeration equipment. Warm water from process or cooling equipment is introduced at the top of a cooling tower and allowed to trickle over a packing material, such as plastic corrugated fill. The water breaks up into a film and droplets to maximize surface area. Air is pulled or blown through the fill material, contacting the warm water and causing evaporative cooling. The water collected in the basin at the bottom of the tower is recirculated to the process or cooling compressor unit. The recirculating water undergoes a temperature change of about 10° Fahrenheit (F) through this process. The water is usually cooled to within 10° F of the wet-bulb temperature, which averages 53° F yearly and 57° F in the summer in the San Francisco Bay area.

There are two basic tower configurations. Counter-flow towers draw air from the bottom, while water is sprayed onto the top of fill material in the tower (see diagram below). With cross-flow towers, air is drawn in from the sides, across the fill, while water is sprayed in from the top in a manner identical to counter-flow configurations. Fans can be located at either the outside or the bottom of the towers (forced-draft) or on top of the tower to draw the air out the top (induced-draft).

Typical Counter-flow Cooling Tower Configuration





Marley Counter-flow Towers



- through make-up from potable and/or non-potable sources
- when rain falls directly on top of the tower (this represents a negligible amount)
- in the case of process cooling, from a leak in the heat exchanger, because the water being cooled is under higher pressure than the water in the cooling-tower loop

There are four ways a cooling tower can lose water which must then be replaced. The equation for make-up water is:

$$M = E + B + D + L$$

Where

M = Make-up

E = Evaporation

B = Blowdown

D = Drift and wind loss

L = Leaks, overflows, and other losses

A tower can lose water through normal cooling-tower operating processes and can be controlled by proper design and operation, as well as by tower and recirculating-water system malfunctions and problems. An alarm to detect water overflowing the stand-pipe can alert operators to this problem, but leaks can occur under the basin, in the process pipes, and even through faulty blow-down valves and leaking pump seals. These leaks can be detected by proper design and the instrumentation used to control the tower.

Evaporation and Blowdown

Evaporation is a function of the heat added to the water. Approximately 1,000 British thermal units (Btus) can evaporate one pound of water or 8,340 Btus to evaporate one gallon of water. One ton-hour is equal to 12,000 Btus. Therefore, 1.44 gallons of evaporation are required to dissipate one ton-hour of rejected heat.

As the water evaporates, the dissolved minerals and salts in the make-up water remain behind. Additional water must be added (make-up) and some of the water in the basin periodically discharged (blow-down) to keep these minerals from building up and causing scaling and corrosion. The concentration of the minerals (salinity) in the blowdown divided by the concentration of the minerals in the make-up water is called the cycle of concentration. This concentration of minerals is called TDS and is reported in milligrams per liter (mg/l) or parts per million (ppm). Since the electrical conductivity of the water is related to its TDS, conductivity measured in microsiemens is often used in place of TDS. For example, if the conductivity of the make-up water is 100 microsiemens and the conductivity of the blowdown is 500 microsiemens, the tower would be operating at five cycles of concentration. For pure salt (sodium chloride) the ratio of TDS to conductivity is 0.5, but this ratio is dependent upon the types of cations and anions present. Multivalent cations, such as calcium and magnesium, will increase this ratio. Hard waters often have a TDS to conductivity (microsiemens) ratio of 0.6 or higher. This simply means the local cooling-tower operator or treatment-chemical provider must be aware of this ratio. Many test for chloride levels as a way to determine where the conductivity should be set.

Chemicals can be added to the tower to prevent scaling and corrosion and to kill bacteria that cause slime to grow on heat-exchange surfaces, including harmful bacteria such as legionella. Side-stream filtration is often used to remove sediment and dirt that accumulates in a tower from particulates, insects, and other debris in the air as it flows through the tower. Since the water is cleaner, it helps reduce biological activity and fouling of the heat-transfer surfaces, which often results in being able to increase the cycles of concentration. The water in the basin can also be treated through side-stream softening, which

keeps hardness and, therefore, scaling under better control and reduces the need to add acid to the tower, which is a conventional chemical treatment process.

Until recently, chemical treatment, softening, and filtration were the only proven methods available for cooling-tower treatment. Some now employ membrane softening or TDS removal to the make-up water by the use of nanofiltration or reverse osmosis. This allows very high cycles of concentration to be achieved in the tower, but the reject streams from the membrane processes can be in the range of 20 to 40 percent of the water treated. If there is another use for these reject streams, such as irrigation, this can prove to be a water-saving technique, but if no such use can be found, the reject stream simply replaces the blowdown stream from the tower as water being discharged to the sewer. New technologies are emerging that hold the promise of significantly reducing or eliminating the use of chemicals. There is still much controversy in the cooling-tower profession about the efficacy of these methods. Some appear to work well for certain water chemistries, but not for others. The user should be cautious and investigate each technology carefully before using it, in order to be sure it works for their system and water chemistry.

Drift and Wind

Another type of water loss derives from drift and wind. It is caused by the entrainment of small droplets of water in the air stream as the fans force air through the tower or from wind blowing through the tower. If no drift eliminators were used, drift loss would range from 0.30 to 0.45 gallons per ton-hour. Manufacturers now offer eliminators that reduce this to approximately 0.001 percent for counter-flow towers and 0.002 percent for cross-flow towers. With these very-efficient eliminators, drift loss becomes negligible. For towers that control blowdown by a set flow volume to the sewer, drift eliminators can save significant volumes of water. Where conductivity controllers are used to manage when blowdown occurs, drift loss will offset blowdown and thus not impact make-up-water volumes. Drift eliminators significantly reduce aerosols containing bacteria such as legionella, as well as particulate deposition and salt deposits.

For air conditioning and refrigeration, the efficiency of the equipment significantly impacts water use, since approximately 90 percent of the compressor-generated heat is rejected to the tower. The more efficient the compressor equipment, the less compressor heat is rejected to the tower. For an inefficient compressor system with an energy-efficiency ratio (EER) of only 12 Btus per watt hour (1.0 kWh/ton-hr), the total evaporation per ton-hour of air conditioning rises from 1.44 gallons to 1.81 gallons. In contrast, a unit with an EER of 24 (0.5 kilowatts/ton-hour) uses half the electricity to produce the same amount of cooling. Evaporation would be decreased to 1.62 gallons per ton-hour: a 10 percent decrease in evaporation. The table below compares EERs to other commonly used terms for air-conditioner efficiencies.

Air-Conditioner Efficiency Comparison

Kilowatts per Ton	Energy Efficiency Ratio (EER)*	Coefficient of Performance
<i>Kilowatt-hours /ton-hour</i>	<i>Btus/Watt-hour</i>	<i>Btus out/Btus in</i>
2.0	6.0	1.8
1.5	8.0	2.3
1.0	12.0	3.5
0.5	24.0	7.0

*EER is the energy-efficiency ratio at the design temperature and is comparable to the other parameters in this table. Seasonal energy-efficiency ratios (SEERs) are adjusted for an assumed seasonal variation in climatic parameters.

Cycles of Concentration

The cycles of concentration also significantly impact water use per ton-hour. For example, if a tower is used to cool a compressor with a 24 EER (0.5 kWh/ton-hour), and the tower is operated at only 2.0 cycles of concentration, water evaporation is 3.4 gallons per ton-hour. At 5.0 cycles of concentration, however, water use would be only 2.0 gallons per ton-hour. Conductivity controllers reduce water use by controlling blowdown rates.

For potable water typically found in the San Francisco Bay area, five cycles of concentration should be achievable. Five cycles of concentration provide a good minimum level of conservation, but if higher levels are economically feasible, more water savings will be achieved. However, for many areas in the world, the quality of the water, high hardness, silica, and TDS may limit the cycles of concentration that can be achieved economically. This will also be true for the use of alternate sources of water, such as reclaimed water. Based upon information provided by Evapco, Marley, and Baltimore Air Coil literature and experts, unless the make-up water is treated by softening or TDS removal prior to being introduced to the tower or by side-stream softening or similar treatments, the cycles of concentration may be limited. For make-up water containing 200 mg/l of hardness, measured as calcium carbonate, four cycles of concentration may be the economic limit. San Antonio, Texas, which has very hard water, requires a minimum of four cycles of concentration for towers operating within its jurisdiction. Also, since very high TDS may require special materials to be used to control corrosion, most commercial tower operators keep the TDS in the tower's basin and recirculating water below 1,500 mg/l. (Remember, the conductivity of the water as it relates to TDS is dependent upon the actual water chemistry.) In a similar manner, manufacturers recommend that silica levels in tower basins and recirculating water, measured as silicon dioxide, be kept below 150 mg/l. The important factor to remember is that the economic level of cycles of concentration will depend upon water and sewer costs, the materials used to construct the tower and heat exchangers, and the cost of the treatment that must be provided.

It is important to look at all the costs associated with operating a cooling tower in order to compare them with the use of an air-cooled unit. The savings in energy must be balanced against the total costs of tower operations, including water and wastewater, chemicals, energy for fans and pumps, labor, capital investment, and adverse impacts, including high dissolved solids in the wastewater, deposition from drift loss, and aerosols containing bacteria such as legionella.


Therefore, all new towers should be properly instrumented with:

- make-up and blowdown meters
- conductivity controllers for blowdown
- overflow alarm systems
- drift eliminators

The effect of both cycles of concentration and compressor efficiency upon water use per ton-hour in a tower with modern drift eliminators is summarized in the figure on the following page.

Facility managers and owners who contract services for cooling-tower operations should include requirements for the minimum cycles of concentration to be achieved by the cooling tower. In regions with high water quality (low TDS), a minimum of five cycles of concentration should be achievable. For water supplies to cooling towers in general, the following guidelines should be followed:

- for make-up waters having less than 200 mg/l (200 ppm) of total hardness, expressed as calcium carbonate, a minimum of 5 cycles of concentration, based upon a ratio of the conductivity of the water being discharged (blowdown) divided by the conductivity of the feed (make-up) water(s), is recommended;



- for make-up waters with more than 200 mg/l of total hardness, expressed as calcium carbonate, a minimum of 3.5 cycles of concentration, based upon a ratio of the conductivity of the water being discharged (blowdown) divided by the conductivity of the feed (make-up) water(s), is recommended, unless side-stream softening or another similar treatment method is employed.

Exception: Where the blowdown's TDS concentration exceeds 1,500 mg/l (1500 ppm) or silica exceeds 150 mg/l (150 ppm) measured as silicon dioxide before the above, cycles of concentration should be limited to achieve these parameters, unless additional water treatment is employed.

Cost-Effectiveness Analysis

Tower operating-cost considerations when selecting an air or water-cooled system include the following:

- Capital cost for towers, installed, is about \$100 per ton. Life expectancy is about 15 years.
- Air-conditioning towers operate about 2,600 hours a year, so capital cost is about 0.25 cents per ton-hour. Refrigeration towers operate about 3,500 hours a year at a capital cost of about .19 cents per ton-hour.
- Towers consume 2.2 gallons of water per ton-hour for a cost of about 1.5 cents per ton-hour.
- Energy use is about 0.04 kWh or 0.3 cents per ton-hour.
- Chemicals, operations and maintenance (O&M) of about 0.15 full-time-equivalent employees (FTE), and other maintenance add an additional 0.5 cents per ton-hour, for a total of about 2.8 cents per ton-hour.



Baltimore Air Coil Cross-Flow Tower

Savings Due to Increased Cooling-tower Efficiency

A detailed analysis of the increase in cooling-tower efficiency will depend upon local conditions. However, if a tower's cycles of concentration increase from 2.0 to 5.0, the water savings will be 1.2 gallons per ton-hour, since the 3.2 gallons needed per ton-hour at 2.0 cycles decreases to 2.0 gallons per ton-hour at 5.0 cycles. The added savings in water and wastewater alone will be 0.9 cents per ton-hour. For a 500-ton tower operating at a 30 percent annual load factor, water use at 2.0 cycles is 4.2 million gallons per year, while the same tower operating at 5.0 cycles will use only 2.6 million gallons, for a savings of 1.6 million gallons a year.

Recommendations

Proven Practices for Superior Performance

- Require a life-cycle analysis, including all operating, capital, and personnel costs, to determine whether the use of a cooling tower is more cost-effective than air cooling.
- Require all cooling towers to be equipped with conductivity controllers, make-up and blow-down meters, and overflow alarms.
- Require towers to be operated at a minimum of five cycles of concentration in regions with high water quality (low TDS) for towers using potable water, depending upon the water chemistry of the make-up water used, including considerations for reclaimed water or on-site sources.
- Require all towers to have high-efficiency drift eliminators that reduce drift loss to less than 0.002 percent of circulating water volume for cross-flow towers and 0.001 percent for counter-flow towers.
- Prohibit cooling towers for single-family residential use.

Unilux Steam Boiler



Fulton Boiler Works Hot-Water Boilers



Additional Practices That Achieve Significant Savings

- Evaluate an entire building or process for maximum energy efficiency, since a more efficient building will reject less heat to the cooling tower.
- Evaluate the possibility of waste-heat recovery, since this heat will be put to beneficial use and will not be rejected to the tower.
- Require operator training.
- Prohibit cooling towers of less than 100 tons for commercial air-conditioning systems.
- Establish a utility-wide monitoring and reporting process.

References

Cooling towers, air-cooled heat exchangers, and industrial coolers (or heat-rejection equipment)

www.seav.sustainability.vic.gov.au/manufacturing/sustainable_manufacturing/resource.asp?action=show_resource&resourcetype=2&resourceid=28.

Hoffman, H. W. (Bill). 1994. **Analyst Manual for Institutional and Commercial Water Use Surveys**. Texas Water Development Board.

Holdaway, Ron, P.E. February 2004. "Water Treatment as Insurance." **Maintenance Magazine**.

Parke, Steven A. **Ozone Treatment for Cooling Towers**. Pacific Northwest National Laboratory. Richland, Washington.

Boilers and Water Heating

Description of End Use

The term "boiler" is used to describe both steam boilers and water-heating systems in many commercial operations. Steam systems are used for process heat for hospitals, large kitchens, bakeries, and dry cleaning. Historically, steam radiators were used for building heat, but their use is limited now. The term is also used in many commercial operations to describe equipment used to heat water for processes, building heating, and hot-water supply.

Steam Boilers

Steam boilers produce steam by boiling water. The temperature of the steam depends upon the level of pressure at which the boiler works. Low-pressure boilers are used for most commercial operations. High-pressure boilers are more commonly used for power generation and industrial processes. Water fed into the boiler is heated and turned into steam, which is then either used in a consumptive manner or condensed and returned to the boiler. Boilers are rated by "boiler horsepower," defined as enough energy to evaporate 34.5 pounds of water at a temperature of 100° Celsius (C) (212° F) into steam at 100° C per hour, or about 33,478.8 Btus per hour, based upon steam tables. About 80 percent of boilers in use today are of the fire-tube type (Alken–Murray).

Boiler feed-water must be treated before it is used to remove oxygen and dissolved gasses (de-aeration), softened to remove hardness that can cause scale, and filtered or clarified to remove particulates. Since very pure water is required for higher-temperature boilers, the water is often passed through an RO system or a deionization resin. Lower-pressure boilers can use water of lesser quality. Chemicals are often added to prevent silica scaling, control corrosion, and scavenge remaining oxygen.




Diagram of a Typical Fire-Tube Boiler

As the water in the boiler turns into steam, dissolved minerals remain behind and the steam leaves as pure water. In a perfect system, the steam would be recondensed and all returned to the boiler. In actual operation, steam is lost or consumed, and more water must be added. To control dissolved solids, some of the water in the boiler must be discharged as blowdown. This water is drawn from near the top of the boiling-water level in the boiler chamber, since this is where the maximum concentration of minerals builds up as the water turns to steam. This is called “top blowdown.” Over time, minerals and rust build up in the bottom of the boiler to form “boiler mud,” which must be removed through a process called bottom blowdown.

Typical top-blowdown rates range from 10 to only 2 percent of boiler feed — equivalent to 10 to 50 cycles of concentration. Many boiler operators practice discretionary continuous top blowdown, in which a valve is left partially open. This practice can waste significant volumes of water. Conductivity meters that can operate at the high temperatures and pressures of a boiler can control this blowdown and minimize water use.

Bottom blowdown, usually a much smaller volume done on a predetermined schedule, is based upon the operational characteristics of the boiler. Bottom blowdown water should be observed periodically to ensure that only “muddy” water is being discharged. The use of blowdown systems to recover heat has been successful with energy recovery, but the high mineral composition of the blowdown makes this water unsuitable for reuse.

Steam does its work by recondensing to water and releasing its heat of vaporization. For efficiency and water- and energy-conservation, this condensate should be returned to the boiler, since it is pure, very-hot water. Adequately sized steam traps coupled with condensate-return pumps comprise a good system. Since condensate can pick up rust, particulates, and other contaminants, condensate polishing with filters or ion-exchange resins is sometimes practiced. According to most codes, if condensate return is not feasible, water must be cooled prior to discharge to a sanitary sewer. This offers additional water-conservation opportunities, as will be seen with steam sterilizers in medical facilities.

Hot-Water Boilers

Hot-water boilers are water-heating systems and do not involve the production of steam. The term “boiler” is used, but these are actually just large water-heaters. There are two major system configurations: open and recirculating. Open systems provide hot water to an end use, such as bathing, laundry, or dishwashing operations. The water is not returned to the heating system. These can either be direct-supply systems or have loop piping where the hot water is circulated with a pump back to the water heater. Open systems are usually found in food service and laundry operations.

Recirculating systems are usually found in hotels and large buildings where having hot water instantaneously is desired. Recirculating systems are also commonly used for building heating, where hot water is supplied for space heating, using either air heat-exchange (either forced or convection) or hydronic floor-heating systems. The water in the closed loop is generally treated to help control corrosion and scaling. Additional water is needed only to make up for leaks and periodic changes of the water.

Water-Savings Potential

Steam boilers offer many unique opportunities for water savings. Conductivity controllers, the proper use of steam traps and condensate-return systems, and good energy-conservation practices can help reduce boiler feed-rates. Conductivity controllers reduce water use by controlling blowdown, while good steam traps and condensate-return systems ensure that high-quality, hot steam condensate is returned. Much depends upon the size and application of the boiler. The amount of make-up water needed depends upon the amount of condensate returned. The following examples illustrate how these improvements in water-use efficiency add up to water savings.

Examples:

1. A boiler produces 5,000 pounds of steam per hour (equal to 599.5 gallons of water at 8.34 pounds per gallon). This is equal to 5.0 million Btus per hour at 1,000 Btus per pound.
2. The conductivity controller for blowdown is set at 10 cycles. This means 10 percent of the water fed to the boiler will be discharged as blowdown.

$$M = CL + B$$

Where:

M = Makeup

CL = Condensate Loss

B = Blowdown

Cycles of concentration also equals M/B. For 10 cycles M/B = 10.1 or blowdown = 1.0 divided by the cycles of concentration = 0.1M

$$M = CL + (0.1M)$$

3. Eighty (80) percent of the condensate is returned.

The boiler produces 5,000 pounds of steam, but only 80 percent is returned. The make-up to replace this is equal to 1,000 pounds, or 119.9 gallons (1,000 pounds/8.34 pounds per gallon).

$$M = 119.9 + 0.1M$$

$$0.9M = 119.9$$

$$M = 119.9/0.9 = 133.2 \text{ gallons}$$

If the return rate is increased to 95 percent, only 250 pounds or 30.1 gallons of condensate would be lost. If the cycles of concentration remain at 10, the make-up water would equal:

$$M = 30.1/0.9 = 34.5 \text{ gallons}$$

or a savings of $133.2 - 34.4 = 78.7$ gallons per hour (gph).

If the cycles of concentration are also increased to 35, the make-up to blowdown ratio would be $1/35 = 0.0286$. Therefore,

$$\text{Blowdown (B)} = M \times 0.0286$$

$$M = 30.1 \text{ gallons} + 0.0286M$$

$$M = 30.1/(1.0.0286) = 30.1/0.9714 = 31.0 \text{ gallons.}$$

This is equal to a savings of 133.2 gallons - 31.0 gallons = 102.2 gallons or 77 percent.

Hot-water boilers produce hot water for all types of uses, ranging from domestic use to building heating with hydronic and convective systems. Each use presents different opportunities for saving water, depending upon the operation of system. The two major water-saving actions related to hot-water boilers are good end-use water conservation and preventing leaks in the distribution system.

Cost-Effectiveness Analysis

Example for Steam-Boiler Conductivity Controllers (taken directly from the Pacific Northwest Pollution Prevention Resource Center, 20057).

Assumptions:

- Automatic conductivity blowdown-control system reduces the blowdown rate from 8 to 6 percent.
- Natural-gas-fired steam boiler operates continuously at 150-psig (pounds per square inch gauge), 100,000 pounds-per-hour.
- Make-up water temperature of 60° F.
- Boiler efficiency of 82 percent.
- No heat exchanger for recovery of heat from blowdown water.

Boiler Feedwater Savings

- Before installing control system:
 - » $100,000 \text{ pounds per hour} / (1-0.08) = 108,695 \text{ pounds per hour.}$
- After installing control system:
 - » $100,000 \text{ pounds per hour} / (1-0.06) = 106,383 \text{ pounds per hour.}$
- Water Saved: $108,695 - 106,383 = 2,312$ pounds per hour.
- At 8,760 operating hours per year, the savings is 20.3 million pounds or 2.4 million gallons per year.

Example for Hot-Water Boiler

Hot-water boilers do not have a blowdown or discharge. These are very large water-heaters. Savings are achieved by reducing hot-water use. The value of the hot water saved includes the energy needed to heat the water and the cost of the water and wastewater.

Recommendations

Proven Practices for Superior Performance

Steam Boilers

- Require steam boilers of 200 boiler horsepower (BHP) or greater to be equipped with conductivity controllers to regulate top blowdown.
- Require steam boilers of 200 BHP or greater to have condensate-return meters.
- Require steam-boiler distribution lines and equipment to be equipped with steam traps meeting all codes.
- Require all steam boilers to have make-up meters on the feedwater lines.
- The cycles of concentration at which a boiler operates is dependent upon water chemistry, boiler operating pressure, temperature, and related factors. Maximizing the cycles of concentration will reduce water use.

Hot-Water Boilers

- Require make-up meters on all cold-water feed lines to boilers (water heaters) of more than 100,000 Btus per hour.
- Require make-up meters on lines feeding closed-loop hot-water systems for heating.

Additional Practices that Achieve Significant Savings

Steam Boilers

- Equip all steam boilers with conductivity controllers.
- Operate all steam boilers at twenty cycles of concentration or greater (5 percent or less of make-up water).

Hot-Water Boilers

- Have boiler (water-heater) temperature and make-up meters clearly visible to the operator.

References

Alken-Murray Corporation. **Why Treat the Water in Your Boiler?** New Hyde Park, New York. www.alken-murray.com/Boilerworks.htm.

Chana, Vinita; White, Stewart; Howe, Carol; and Meenakshe, Jha. **Sustainable Water Management in Commercial Office Buildings.** Institute for Sustainable Futures. www.isf.uts.edu.au/publications/chanan.html.

Clayton Industries (17477 Hurley Street, City of Industry, CA 91744-5106). Web site on boilers. www.claytonindustries.com.

Cohen, Ronnie; Nelson, Barry; and Wolff, Gary. August 2004. **Energy Down the Drain – The Hidden Cost of California’s Water Supply.** Pacific Institute.

Encyclopedia of Alternative Energy & Sustainable Living. www.daviddarling.info/encyclopedia/B/AE_boiler_horsepower.html.

Hoffman, H. W. (Bill). 1994. **Analyst Manual for Institutional and Commercial Water Use Surveys.** Texas Water Development Board.

Hoffman, H. W. (Bill). March 2006. **Building Reduced Water and Wastewater Cost into the Design.** Austin Water Utility. Austin, Texas.

- Hoffman, H. W. (Bill), and Sutton, John T. 2003. **State Energy Conservation Office Suggested Water Efficiency Guidelines for Buildings and Equipment at State Facilities.** Texas State Energy Conservation Office.
- New Mexico. Office of State Engineer. July 1999. **A Water Conservation Guide for Commercial, Institutional and Industrial Water Users.**
- Pacific Northwest Pollution Prevention Research Center. February 2005. **Pollution Prevention Technology Profile: Conductivity Controls in Water Rinsing, Cooling Towers, and Boilers.** Seattle, Washington.
- Pollution Prevention International. March 2004. **Commercial, Institutional, and Industrial Water Use Survey Program Final Report.** For Santa Clara Valley Water District.
- U.S. Department of Energy. EERE. **Install an Automatic Blowdown Control Program.** Industrial Technology Program Tip Sheet 23.
- U.S. Department of Energy. Office of Industrial Technologies. 2002. **Improving Steam System Performance.** www.p2pays.org/ref/21/20921.htm FEMP BMP 6.

This page intentionally left blank.

Water Treatment

Water treatment is used in many commercial operations, including food services, laundries, laboratories, pharmacies, and car washes. The type of treatment depends upon the application and the required water purity. Treatment ranges from simple cartridge filtration to sophisticated systems that produce extremely pure water. For example, ice machines often have cartridge sediment and carbon filters installed on the make-up water so the ice is free of particles and chlorine taste. Some laboratories and the pharmaceutical and electronics industries, however, require “ultrapure water,” which has had all but a few parts per billion of minerals, organics, and other substances removed through a train of treatment, including filtration, carbon filtration, softening, reverse osmosis, and strong acid/base ion exchange, followed by microfiltration and ultraviolet-light disinfection. The following table compares various treatments found in commercial operations.

Many commercial operations require some form of water treatment, either for use in processes or as a component of the end product.

Commercial Water Treatment Examples

	Treatment Process							
	Sediment Filtration	Carbon Filtration	Softening and Ion Exchange	Membrane Process	Distillation	Disinfection	Other	
All Food Service	x	x	x	x			x	
All Laundry & Dry Cleaning	x		x					
Hospital & Laboratory	x	x	x	x	x	x	x	
Car Wash	x		x	x				
Beverage Manufacturing	x	x	x	x		x		
Metal Plating	x	x	x	x			x	
Cooling Tower & Boiler	x		x	x		x	x	
Pool, Spa, & Water Feature	x					x		
Office & Non-process	x	x	x			x	x	

Description of End Use

Each treatment technology offers unique opportunities for water conservation, as described below:

Sediment filtration is one of the most common treatment techniques. Swimming pools, water feeds to commercial ice machines, cooling-tower side-streams, drinking-water, and water-using medical equipment are but a few examples where sediment filters are found. They remove particles down to a few microns in size. The two basic designs use disposable cartridges or granular filter media.

By their nature, cartridge filters are usually not designed for very large flows. Sample uses include pre-filters for ice machines, smaller medical equipment, and smaller swimming pools and spas. Filter material varies from tightly wound fibers to ceramics, fused powdered-metals, or other materials. Such filters are left in place until the sediment buildup causes a predetermined increased pressure drop across the filter, at which time the filter is replaced, backwashed, or removed and cleaned for reuse.




Culligan heavy-duty whole house filter

The second type of sediment filter is often found where larger volumes of water must be processed or higher levels of sediment must be removed. These include granular media such as sand, coated media (DE, cellulose, and perlite), and mixed-bed filters. All of these must be backwashed. The backwash water is generally discharged to the sanitary sewer. In some larger applications, however, the sediment can be allowed to settle out and the clarified water can be reintroduced at the head of the filtration process. Common applications include swimming pools, industrial water treatment, and side-stream filtration for cooling towers.

Carbon filtration removes chlorine, taste, odor, and a variety of organic and heavy-metal compounds from water by adsorption. Activated carbon, which has an enormous surface area per unit volume, attaches to the unwanted materials and holds them on its surfaces. Restaurants and food service providers for hospitals and other institutional operations often use activated carbon for drinking water and ice-machine feed water. It is also used in the beverage industry for taste and odor control.

Activated carbon is also used to remove pollutants in the metal-finishing industry and other operations where pretreatment to remove metals or organics is needed. These systems can employ either disposable cartridges or packed columns, where the activated carbon can be removed and sent for recharge. With both cartridge and packed-column systems, water simply passes through the carbon medium until its adsorptive capacity is used up.

Water softening employs zeolites or ion exchange resins, where calcium and magnesium ions are exchanged for sodium or potassium ions. Softening removes hardness to control scale, improves water for washing, and prevents “hard water” spots. Recharge is done with a salt solution containing sodium or potassium cations, the most common being sodium chloride (table salt). Water is used in the recharging process to make up the brine solutions and to purge the softener of brine prior to being returned to service. All softener systems should be equipped with controllers that are activated based upon the volume treated, not on timers. They should either be adjusted for the hardness of the water supply or be equipped with a hardness controller that actually measures the hardness and volume treated, if the hardness of the feed water varies.



Water Softener System

www.bobvila.com/howto_library


Softeners are commonly found where hardness interferes with water use or where scale formed by hard water could be detrimental. Laundries, car washes, boiler feed-water, laboratory water, hot-water systems for restaurants and food-service establishments, and metal-plating operations commonly employ softening. It is used occasionally for cooling-tower feed-water or in a process called side-stream softening, which helps extend the usefulness of cooling-tower water. (See "Thermodynamic Processes.")

Deionization also employs exchange resins, but it is different from softening. Strong acid/base ion-exchange resins, known as deionization resins, are used to produce extremely pure water for laboratory analysis, kidney dialysis, and feed-water for a number of industrial processes. Water use is similar to that for recharging softening systems, but the discharge water can be much more corrosive. Controls should be based upon the chemistry of the feed water and volume treated, not on timers.


Ion-removal systems operate similarly to ion-exchange systems and have similar water-use patterns. Ion-exchange resins can also remove a variety of ionic contaminants, such as arsenic or fluoride.

Membrane processes include several water-treatment methods. A membrane, usually composed of a polymer material, is used to remove contaminants. All membrane processes have three things in common: there is a feed stream, a retentate or waste stream, and a product called permeate. The type of membrane process used depends upon the size or type of contaminant one wishes to remove, as illustrated by the following diagram.

The example following is for an ultrafiltration membrane, but could represent any of the four membrane processes:



- Microfiltration employs membranes that remove particles of 0.1 to 10 microns in size or larger. It is used in municipal water treatment to remove bacterial and *Giardia lamblia* cysts, and *Cryptosporidium* oocysts. Water is forced through the membrane until the pressure drop reaches a set point. The filter is then backwashed. The membranes also require periodic chemical cleaning. Both the backwash and cleaning processes use water. Retentate or waste volumes are usually a small percentage of the total feed volume. The retentate is often recirculated and only a small stream of “bleed water” is discharged as wastewater. Some ceramic filters can also filter in this range.
- Ultrafiltration operates at higher pressures than microfiltration and removes materials that are much smaller, including viruses and proteins. It is often used to separate milk and whey. These filters must be backwashed and cleaned in a manner similar to microfiltration membranes.
- Nanofiltration membranes have pore sizes midway between those of ultrafiltration and reverse osmosis. Nanofilters are often referred to as “softening” filters, since they are effective in removing multivalent cations such as calcium and magnesium.
- Reverse osmosis (RO) removes salts from a water stream. It finds use wherever very pure water is needed, such as laboratories, medical uses including kidney dialysis, metal plating, boiler feed-water, and a number of related applications. Typically, RO will reject 90 to 95 percent of the salts. RO is also used before strong acid/base deionization for the production of ultrapure water for laboratory, pharmaceutical, and microelectronics manufacturing operations.



Permeate/Feed-Stream/ Retentate Diagram

Koch Membrane Systems

www.kochmembrane.com

Distillation, a process once in common use to make water for laboratory applications, is still found in many laboratories. Electric or gas stills are used. Production quantity depends upon the size of the still. Smaller stills often use once-through condenser water and can waste huge volumes of water to produce a single gallon of distillate. Small and medium size stills use air to cool the coils and have no discharge. These are the most water-efficient stills. Some larger stills have reject streams to prevent scale buildup. These typically dump 15 to 25 percent of the water entering the still.

Disinfection and other technologies can consume small amounts of water, if chemicals are fed in a liquid or slurry form. Chemical disinfection technologies include use of chlorine compounds, ozone, and hydrogen peroxide, as well as pH control with acids and bases and the addition of antiscalants and sequestrates such as sodium hexameta phosphate. Ultraviolet light, heat, and extreme mechanical shear are among other technologies in use.

It is important to examine disinfection requirements. Ultraviolet light, heat, and mechanical shear processes do not use water. Other processes use water to make up the solutions, but this becomes part of the product water and is not lost. However, cleaning chemical storage areas does consume water. The potential for water savings by choosing among disinfection technologies is not great; however, the potential to waste water in cleaning the equipment and storage vessels is a concern which use of waterless methods can lessen.

Water-Savings Potential

The first water-saving possibility for water treatment is to question the need for additional treatment. If treatment is cost-effective, choose methods that need the least amount of cleaning and backwash or that

have reject streams. All membrane processes produce a reject stream, which in the case of nanofiltration and reverse osmosis might be reusable.

Cost-Effectiveness Analysis

Cost analysis depends upon many variables. Equipment costs for water treatment processes vary from tens to hundreds of thousands of dollars. For select industries, some level of purified water is essential to operation and is an unavoidable cost. Since many variables are involved in analyzing water-treatment alternatives, a cost-benefit analysis, including the cost of energy, should be conducted for each application to determine the most feasible water-treatment option.

Recommendations

Proven Practices for Superior Performance

- For all filtration processes, require pressure gauges to determine when to backwash or change cartridges.
- For all filtration processes, base backwash upon pressure differential.
- For all ion-exchange and softening processes, require recharge cycles to be set by volume of water treated or based upon conductivity controllers.
- Require that all softeners be recharged based upon the amount of water they process (demand-based) or by actual measurement of the grains of hardness removed.

Additional Practices That Achieve Significant Savings

- Use water treatment only when necessary.
- Choose a reverse-osmosis or nanofiltration system with the lowest reject rate for its size.
- Choose distillation equipment that recovers at least 85 percent of the feed water.
- Evaluate opportunities to reuse backwash waste streams.

References

APS Water Services Corporation. www.apswater.com/.

Barnstead International (2555 Kerper Boulevard, Dubuque, Iowa USA 52001-1478.). **Classic Electrically Heated Stills — Operations Manual.**

Doulton USA (19541 Cherry Hill Rd., Southfield, MI 48076). www.doultonusa.com/.

Gibbs, Eric L., Ph.D. July 2001. **Preparation of Reagent Water — Design of Laboratory Water Stills.** High = Q, Inc. www.high-q.com/articles.html.

Hoffman, H. W. (Bill), and Sutton, John T. 2003. **State Energy Conservation Office Suggested Water Efficiency Guidelines for Buildings and Equipment at State Facilities.** Texas State Energy Conservation Office. Austin, Texas.

Hoffman, H. W. (Bill). March 2006. **Building Reduced Water and Wastewater Cost into the Design.** Austin Water Utility. Austin, Texas.

Klenck, Thomas. **How Softeners Work.** Ahdorma Water Filters Purification and Treatment (320 Ro- bling St., #401, Brooklyn, New York). www.thewatersite.com/how_they_work_water_softeners.htm.

Koch Membrane Systems. www.kochmembrane.com.

Loretitsch, Gary. **Guidelines for Managing Water in Cooling Systems: For Owners, Operators, and Environmental Engineers.** Puckorius & Associates. San Jose/Santa Clara Water Pollution Control Plant.

Makini, Byron. Fall 2005. **Achieving Zero Liquid Discharge in the Semiconductor Industry.** Columbia University, Department of Earth and Environmental Engineering. New York, New York.

McDermitt, Kery. August 10, 2006. **RO System Helps Unilever Reduce Water Usage.**
WaterandWastewater.com.

McIntyre, James P. August 1998. **Industrial Water Reuse and Wastewater Minimization.** BetzDearborne.

Neptune Benson, **Defender Automatic Regenerative Filter** (6 Jefferson Drive, Coventry, Rhode Island 02816). Neptunebenson.com.

North Carolina Department of Environment and Natural Resources, Division of Pollution Prevention. August 1998. **Water Efficiency Manual for Commercial, Industrial, and Institutional Facilities.**

Pacific Northwest Pollution Prevention Research Center. **Pollution Prevention Technology Profile: Conductivity Controls in Water Rinsing, Cooling.**

Thompson, Chris; and Lickteig, Edward. October 2008. **Recycling High Purity Rinsewater at Samsung Austin Semiconductor.** Ultrapure Water, Samsung Austin Semiconductor. Austin, Texas.

Towers and Boilers. February 2005. Seattle, Washington.

Wilcox, Daniel. 2005. **AMD Austin Water Conservation Summary.** Advanced Microdevices (AMD). Austin, Texas.

Vehicle Washes

Water efficiency in commercial vehicle washes derives from both proper equipment and operational measures. Only equipment choices truly affect new business plans, and operational measures are better addressed in ongoing water-conservation and water-quality programs. Three principal types of commercial vehicle wash are considered here:

- conveyor
- in-bay automatic
- self-service

These include those vehicle washes that are available for public use at stand-alone facilities, as well as those alongside convenience stores, lube shops, and fuel stations. New-vehicle dealers, fleet-vehicle operators, and rental agencies may also have vehicle-wash systems.

Such equipment is also used for truck and bus washing, although fewer of these facilities are available to the public. Most are for washing fleets and are typically located on private property as part of businesses which own, operate, or serve a fleet of vehicles. These can include bus companies, quarries, warehousing operations, and other industrial operations involving transportation. Such controlled facilities sometimes incorporate additional water-saving measures.

When either schools or commercial/retail businesses submit plans for review, it should be determined whether vehicle washes are planned.

Conveyor and in-bay automatic vehicle washes can be constructed as friction or “touch-free.” Friction systems use less water overall, because once wet, the “cloth” is rewetted by each vehicle it touches and does not need additional wetting unless a long period passes between washes. Also, friction washes do not use water under high pressure in the wash cycle, resulting in less water use.

It is cost-effective to build conveyor and in-bay automatic carwashes with water-reclaim systems, which can reduce potable water use by as much as 90 percent, although average savings found in studies are more likely to fall in the range of 50 percent. New vehicle washes with water reclaim systems should clearly indicate in which of the wash/rinse cycles reclaimed water is to be used.

The International Carwash Association summarizes the “Steps in a Professional Car Wash Process” that affect water use as follows:

- pre-soak — automated nozzle or hand-held spray
- wash — high-pressure spray or brushes with detergent solution
- rocker panel/undercarriage — brushes or high-pressure sprays on sides and bottom of vehicle
- first rinse — high-pressure rinse

By their nature, vehicle washes will use large quantities of water. New processes for highly efficient water recovery and high-quality treatment have made great strides in improving the conservation record of this industry.

- wax and sealers — optional surface finish sprays on the vehicle
- final rinse — low-pressure rinse with fresh or membrane-filtered water
- air blowers — air blows over the vehicle to remove water and assist in drying
- hand drying — vehicle is wiped down with towels or chamois cloths on site (in full-service washes these are then laundered in washing machines on-site)

Each of the three types of vehicle washes — conveyor, in-bay, and self-service — is described below, along with the water-savings opportunities related to use of reclaim systems and equipment choices which improve efficiency. An additional section discusses water-reclaim systems used in truck washing, which accounts for a large percentage of vehicle-wash water.

Conveyor Systems

The conveyor vehicle wash, usually installed in a tunnel, includes a series of cloth brushes or curtains and arches from which water is sprayed, while the car is pulled through the tunnel on a conveyor chain. In some “touch-free” vehicle washes, only spray nozzles are found. In full-service conveyor vehicle washes, hand drying usually follows the conveyor processes, and often hand-held wands like those found at self-service vehicle washes are used for the pre-soak.

In friction vehicle washes, the wash and/or pre-soak cycle is accomplished with brushes or soft cloth curtains known as mitters. Conveyors with friction components use less water than frictionless washes because the brushes or curtains pick up water and detergent from earlier vehicles and do not need to be rewetted throughout the day. Mitters can often be installed as curtains in the pre-soak area of the conveyor, and rotating brushes are often found in the wash cycle (although this is not universal).

Timing is a critical component in vehicle wash-water efficiency. In properly calibrated conveyors, nozzles are timed to turn on as the vehicle passes under an arch and to shut off as it exits each arch. Each arch is on for a matter of seconds, since conveyors can process ninety or more cars an hour. Efficiency is also maintained by proper nozzle configuration, alignment, and water pressure. A number of nozzle types can be found in conveyor vehicle washes. Nozzle tips which emit water in a fine, fan-shaped spray appear to use the least water. Nozzles referred to as “guns” or “gatling guns,” however, provide high-flow volumes and should be used only with reclaimed water.

Blowers at the ends of tunnels should be oriented to push water back into the tunnel. Conveyors should have a longer stretch of tunnel after the final-rinse arch, so water that otherwise would be carried out of the tunnel can flow back into the sump and be reclaimed and reused in the vehicle-wash system.

Towel drying is one of the services offered in a full-service conveyor or vehicle-detailing business. In many older car washes, towel-washing sinks were designed to have a constant flow-through of water. A float-ball valve that halts the water flow when it reaches an optimum level is one efficiency measure for such sinks. New vehicle washes should not use flow-through sinks or top-loading washing machines, but should install high-efficiency clothes washers from CEE’s Tier 3. A conveyor wash, referred to by the industry as “exterior-only,” does not offer drying or detailing services. A visual inspection is recommended to confirm whether a vehicle-wash system is a full-service or exterior-only conveyor.

Recommendations

Proven Practices for Superior Performance

- Vehicle-wash-water reclaim systems should, at a minimum, provide water to the pre-soak, undercarriage, and initial wash cycles.

- When present, towel washers should be front-loaded, high-efficiency machines with a CEE rating of Tier 3.
- Spray nozzles on arches should produce a fan-shaped spray, oriented parallel to the arch.
- Gun-type undercarriage nozzles should be limited to use of reclaim water.

Additional Practices That Achieve Significant Savings

- Friction components, such as mitters or brushes, should be used in every conveyor vehicle wash for pre-soak and/or wash cycles.
- Water reclaim systems should have sufficient filtration capacity to provide for use of reclaimed water in all cycles except final rinse.
- In-bay automatics that include a spot-free rinse option should use deionization equipment, rather than water-softening or reverse-osmosis systems, and reject water should be piped to a reclaim-system tank.

In-Bay Automatic Vehicle Washes

With in-bay automatics, the customer stays in the car, while the car remains stationary within the carwash bay during the process. The carwash equipment is mounted on a gantry, which moves over or around the car. In-bay automatics can use either spray nozzles or brushes or a combination of both to wash the vehicle. In-bay automatics also have the greatest variety in basic design, with some machines comprising an entire moveable arch and others having vertical and horizontal arms suspended from the gantry. Yet other designs include spinning arms that are attached to the gantry. The actual wash machinery can vary considerably. Some in-bay automatics move an entire arch over the vehicle, others rotate an arm around the vehicle, and some include spinning arms. In-bay automatics that use brushes typically have spinning bars that roll over and alongside the vehicle.

The number, size, and alignment of nozzles; the water pressure; and the speed of the machinery all affect the water use of in-bay automatics. The number, size, and alignment of nozzles can be specified in design guidelines. Water pressure and speed are operational considerations.

As with the conveyor vehicle-wash, in-bay automatics that use brushes or cloths use less water than frictionless or “touch-free” washes. Some in-bay automatics also reduce water use by employing laser sensors to identify the length of the vehicle being washed, limiting the gantry movement and timing of the wash based upon the sensor signals.

In an in-bay automatic system, all water flows to one pit, and all chemicals mix together. Therefore water reclaim systems can be more costly and a bigger challenge to maintain than in conveyor carwashes.

Recommendations

Proven Practices for Superior Performance

- In-bay automatic vehicle-wash systems should provide reclaimed water to the pre-soak, undercarriage, and initial wash cycles, at a minimum.
- Spray nozzles on arches should produce a fan-shaped spray, oriented parallel to the spray bar.
- Gun-type undercarriage nozzles should be limited to use of reclaimed water.

Additional Practices That Achieve Significant Savings

- Friction components, such as mitters or brushes, should be used for wash cycles in every in-bay vehicle wash.
- Reclaim systems should have sufficient filtration capacity to provide reuse water for all cycles except the final rinse.

- In-bay automatics which include a spot-free rinse option should use deionization equipment, rather than water-softening or RO systems.
- Where RO is used, the reject water should be returned to the recycle system or otherwise be reused in the washing process.

Self-Service Vehicle Washes

Self-service vehicle washes are typically coin-operated and have spray wands and brushes operated by the customer. This same equipment is often found in truck washes, and some dealerships or fleet operations also use spray-wand and brush technology. A typical commercial self-service facility with four-to-six wash bays will have an equipment room where water is mixed with cleaning chemicals and where pumps and treatment equipment are housed. The customer controls whether and for how long low-pressure or high-pressure settings are used. Thus, the vehicle wash owner/operator does not have direct control over water use at the facility. The owner/operator can, however, help reduce water waste by installing the most efficient nozzles.

Self-service vehicle washes use the least water on average per vehicle. This can be attributed to the direct relationship between water use and price in the self-service vehicle wash: the longer the customer runs the wash, the more expensive the service, since they are charged by the minute.

Self-service operators sometimes find evidence of oil dumping or larger debris, like yard waste, in the wash pits. This can occur because customers wash their own cars unattended. In addition to water used in the pre-soak and wash cycles, many self-service operations also offer a spot-free rinse. As with in-bay automatics, reject water from the RO unit can be used in landscape watering, where landscape exists.

Due to the relatively low potential water savings and the potential for organic materials and debris to foul the filters, water-reclaim systems are seldom cost-effective in a self-service vehicle wash. Where zero discharge is required by regulations, self-service operators have installed reclaim systems, but have also hired on-site staff, thereby increasing the cost of doing business.

Recommendations

Proven Practices for Superior Performance

- Based upon pump design, optimum operating pressure nozzle flow-rate should be no more than three gpm.

Additional Practices That Achieve Significant Savings

- Self-service carwashes that include a spot-free rinse option should use deionization equipment, rather than water-softening or RO systems.
- Where RO is used, the reject water should be routed to landscape or used in the wash cycle.

Advanced Water-Reclaim Vehicle Washes in Industrial Settings

This section deals with the following kinds of businesses:

- cement plants, quarries, concrete, and asphalt operations
- bus- and truck-washes in non-public facilities

Conveyor Washes

In addition to the savings already mentioned for conveyor washes, a full-reclaim system can be installed. These have additional filtration for rinse water. They can also be designed so the pit extends outside the

edge of the tunnel, and the driveway and roof gutters direct rainwater into the pit, thus providing rainwater as an alternative water supply.

These types of conveyors can be built in commercial settings, but safety considerations typically preclude their use except on private property. Because the pit would extend outside the area of the tunnel, safety should be improved by placing a steel grate above the pit to prevent workers from accidentally falling in.

Stand-alone Arches and Spray Wands

Some outdoor vehicle washes in industrial or commercial settings restrict public contact and use a single arch to rinse off the vehicle prior to returning it to the public right-of-way. These washes, built on private property, can use aerobic biotreatment in open pits which capture both the wash runoff and the rain that falls on the pit, the pad, and the paved area around the pad. Such “total” reclaim systems can also be designed or used for tire-washing, which reduces entrained dust on vehicles leaving quarries and other industrial facilities.

Water-Savings Potential

The ICA's *Water Use in the Professional Car Wash Study* found that conveyors with water reclaim systems used an average of 49.6 gallons per vehicle, of which 23.7 gallons were reclaimed water. The study also found that in-bay automatics with reclaim systems used an average of 64.0 gallons per vehicle, of which 33.5 gallons were reclaimed water. The California Urban Water Conservation Council analysis of vehicle-wash BMPs indicates an approximate savings of 10 percent for certification programs which require low-flow nozzles on self-serve vehicle washes.

Cost-Effectiveness Analysis

Example: A water reclaim system in a conveyor-type wash, which treats all water except hand-preparation, clear-coat sealant, and final rinses (or approximately 80 percent of a typical wash):

- Equipment capital costs: \$35,000 per reclaim system.
- Estimated equipment life: 10 years.
- Water savings: Approximately 20 percent of previous year's water use at 3,190,000 gallons, for a savings of 2,552,000 gallons. Estimated savings on water and sewer are \$12,760. Cost of operating the systems is approximately \$400 per year.
- Incremental benefit of efficient equipment: 78.3 AF savings over the life of the equipment. Estimating the cost of equipment financed over 10 years at 8 percent interest, the annual savings due to water and wastewater reduction is \$7,260. The benefit is \$927 per AF saved.

Recommendations

Proven Practices for Superior Performance

- Vehicle washes for buses and other commercial vehicles should have filtration systems sufficient to allow all wash and rinse cycles to use reclaimed water.
- Wash pads, parking and staging areas around vehicles, and tire-rinse systems at industrial sites should be designed to capture rainfall and wash water for reuse.

References

Avery, P., and Brown, C. July 2002. **Water Use and Waste Water Characteristics in Professional Car Washes Study: Allston Car Wash, Allston, Massachusetts.** Prepared for the International Carwash Association.

Brown, C. May 2000. **Water Conservation in the Professional Car Wash Industry.** International Carwash Association.

Brown, C. December 2002. **Water Use in the Professional Carwash Industry.** International Carwash Association.

Koeller, J., Brown, C., and Bamezai, A. January 2007. **A Report on Potential Best Management Practices, Annual Report — Year Three.** Prepared for The California Urban Water Conservation Council.