

CITY OF MILLBRAE

REQUIRED LABELING FOR PHOTOVOLTAIC SYSTEMS

Labeling shall comply with CEC Sections 690-5c, 690-10c, 690-17

Labels shall be printed or manufactured so as to be permanent and shall not discolor or be subject to deterioration from exterior / weather conditions.

Hand written marker pen labeling will not be allowed

THE WORD “**WARNING**” SHALL BE PRINTED IN **RED INK**

-WARNING-

SINGLE 120VOLT SUPPLY
DO NOT CONNECT MULTI-WIRE BRANCH CIRCUITS

SINGLE SOURCE
SYSTEMS ONLY

DISCONNECT

Photovoltaic system from utility

TO BE PLACED ON THE
PHOTOVOLTAIC SYSTEM
DISCONNECT TO THE MAIN
ELECTRICAL SERVICE

-WARNING-

**ELECTRIC SHOCK
HAZARD**

-Do not touch terminals-

Terminals on BOTH the line and load sides may be

TO BE PLACED ON THE
DISCONNECT FROM THE SOLAR
PANELS TO THE PHOTOVOLTAIC
SYSTEM

-WARNING-

MULTIPLE POWER SOURCES

A PHOTOVOLTAIC SYSTEM IS PRESENT.
120 VAC and / or 240VAC may be produced.
DC power circuits are present on this site.
Batteries may be present on this site.
Disconnect all power sources before servicing.

TO BE PLACED ON MAIN
ELECTRICAL PANEL
COVER.